


Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure



Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A)(mm)	reactor water level(fuel range)(B)(mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room(mSv/h)	note
12/19 5:00	-2011	-2249			0.1016	0.1855	3.09E+00	2.08E+00	2.53E-01	2.39E-01	0.029	
12/19 11:00	-2013	-2238			0.1016	0.1854	3.09E+00	2.08E+00	2.51E-01	2.39E-01	0.032	
12/19 17:00	-2006	-2233			0.1016	0.1855	3.09E+00	2.08E+00	2.51E-01	2.39E-01	0.031	
12/19 23:00	-2027	-2245			0.1016	0.1855	3.09E+00	2.08E+00	2.51E-01	2.39E-01	0.027	
12/20 5:00	-2050	-2248			0.1016	0.1856	3.08E+00	2.08E+00	2.51E-01	2.39E-01	0.024	
12/20 11:00	-2077	-2243			0.1016	0.1856	3.09E+00	2.08E+00	2.51E-01	2.38E-01	0.028	
12/20 17:00	-2099	-2248			0.1016	0.1858	3.09E+00	2.08E+00	2.50E-01	2.38E-01	0.027	
12/20 23:00	-2139	-2254			0.1016	0.1859	3.08E+00	2.08E+00	2.50E-01	2.38E-01	0.028	
12/21 5:00	-2148	-2253			0.1016	0.1858	3.09E+00	2.08E+00	2.51E-01	2.38E-01	0.026	
12/21 11:00	-2146	-2239			0.1016	0.1859	3.09E+00	2.08E+00	2.51E-01	2.38E-01	0.028	
12/21 17:00	-2116	-2222			0.1016	0.1857	3.09E+00	2.08E+00	2.51E-01	2.38E-01	0.030	
12/21 23:00	-2101	-2220			0.1016	0.1856	3.08E+00	2.08E+00	2.50E-01	2.38E-01	0.026	
12/22 5:00	-2083	-2217			0.1016	0.1854	3.06E+00	2.08E+00	2.51E-01	2.37E-01	0.026	
12/22 11:00	-2052	-2193			0.1016	0.1851	3.06E+00	2.08E+00	2.51E-01	2.37E-01	0.027	
12/22 17:00	-1983	-2167			0.1016	0.1847	3.06E+00	2.08E+00	2.51E-01	2.38E-01	0.027	
12/22 23:00	-1959	-2160			0.1016	0.1843	3.06E+00	2.08E+00	2.51E-01	2.38E-01	0.026	
12/23 5:00	-1983	-2177			0.1016	0.1844	3.06E+00	2.08E+00	2.51E-01	2.37E-01	0.024	
12/23 11:00	-2029	-2199			0.1016	0.1847	3.06E+00	2.08E+00	2.48E-01	2.37E-01	0.026	
12/23 17:00	-2051	-2216			0.1016	0.1848	3.06E+00	2.08E+00	2.48E-01	2.37E-01	0.028	
12/23 23:00	-2079	-2233			0.1016	0.1850	3.06E+00	2.06E+00	2.48E-01	2.37E-01	0.029	
12/24 5:00	-2099	-2249			0.1016	0.1850	3.06E+00	2.06E+00	2.48E-01	2.36E-01	0.029	
12/24 11:00	-2114	-2232			0.1016	0.1852	3.06E+00	2.06E+00	2.48E-01	2.36E-01	0.028	
12/24 17:00	-2062	-2212			0.1016	0.1849	3.06E+00	2.06E+00	2.48E-01	2.36E-01	0.027	
12/24 23:00	-2084	-2231			0.1016	0.1850	3.06E+00	2.06E+00	2.48E-01	2.36E-01	0.026	
12/25 5:00	-2109	-2249			0.1016	0.1851	3.06E+00	2.06E+00	2.48E-01	2.36E-01	0.029	

DS

DS