Temperatures in the Unit 1 Primary Containment Vessel when the amount of core injection water is reduced

Operational Steps: Step 2

Operation Completion Date & Time: 2017/1/5 10:45

Temperatures in the Primary Containment Vessels are measured every hour for 24 hours after completion of each operational step to reduce core injection water. When no abnormalities are found in the data, the temperatures will be measured every six hours as part of regular monitoring.

	Unit 1 Primary Containment Vessel Temperatures (℃)											
	TE-1625A	TE-1625B	TE-1625C	TE-1625D	TE-1625E	TE-1625F	TE-1625G	TE-1625H	TE-1625J	TE-1625K	TE-1625T3	TE-1625T6
2017/1/5 10:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.8
2017/1/5 11:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.6	17.8
2017/1/5 12:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.7	17.8
2017/1/5 13:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.8
2017/1/5 14:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.5	17.8
2017/1/5 15:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.5	17.8
2017/1/5 16:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.6	17.8
2017/1/5 17:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.9
2017/1/5 18:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.7	17.7	17.9
2017/1/5 19:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.6	17.7	17.9
2017/1/5 20:00	17.2	16.7	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.6	17.7	17.8
2017/1/5 21:00	17.2	16.7	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.6	17.6	17.8
2017/1/5 22:00	17.1	16.7	16.7	16.8	16.8	16.5	16.7	23.4	19.7	20.6	17.6	17.8
2017/1/5 23:00	17.1	16.7	16.6	16.7	16.8	16.5	16.6	23.4	19.7	20.6	17.5	17.8
2017/1/6 0:00	17.1	16.7	16.6	16.8	16.8	16.5	16.6	23.3	19.7	20.6	17.5	17.8
2017/1/6 1:00	17.1	16.7	16.6	16.7	16.8	16.5	16.6	23.3	19.7	20.6	17.6	17.8
2017/1/6 2:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.6	17.6	17.8
2017/1/6 3:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 4:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 5:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.9
2017/1/6 6:00	17.1	16.6	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.7	17.9
2017/1/6 7:00	17.1	16.6	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 8:00	17.1	16.6	16.6	16.7	16.7	16.5	16.5	23.3	19.6	20.5	17.5	17.8
2017/1/6 9:00	17.0	16.6	16.6	16.7	16.7	16.4	16.5	23.2	19.5	20.4	17.5	17.7
2017/1/6 10:00	17.0	16.6	16.6	16.6	16.7	16.4	16.5	23.2	19.5	20.5	17.5	17.7
2017/1/6 11:00	17.0	16.6	16.5	16.6	16.7	16.4	16.5	23.3	19.5	20.5	17.5	17.8