Reference

Nuclides Analysis Result of the Radioactive Materials in the Seawater < Coast, Fukushima Daiichi Nuclear Power Station >

(Data summarized on October 25)

Place of Sampling	North of Unit 5-6 Discharge Channel at Fukushima Daiichi NPS (Approx. 30m North of Unit 5-6 Discharge Channel)		Around South Discharge Channel of Fukushima Daiichi NPS (Appox. 330m South of Unit 1-4 Discharge Channel)		Density Limit Specified by the Reactor Regulation (Bq/L)
Time of Sampling	Oct 24, 2012 8:15 AM		Oct 24, 2012 8:00 AM		(The density limit in the water outside the surrounding monitored areas is provided
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor	Density of Sample (Bq/L)	Scaling Factor	in section 6 of Appendix 2.)
I-131 (Approx. 8 days)	ND	-	ND	-	40
Cs-134 (Approx. 2 years)	ND	-	ND	-	60
Cs-137 (Approx. 30 years)	ND	-	ND	-	90

^{*} The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.

I-131: Approx. 0.44Bq/L, Cs-134: Approx.1.1Bq/L, Cs-137: Approx.1.4Bq/L


As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

^{*} Data of other nuclides is under evaluation.

^{*} In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

^{* &}quot;ND" indicates that the measurement result is below the detection limit.

Radioactivity Density of the Seawater at the North of 1F Unit 5-6 Discharge Channel (Bq/L)



Radioactivity Density of the Seawater at 1F South Discharge Channel (Bq/L)

