

## Tritium Analysis Results of Seawater in the Port at Fukushima Daiichi NPS

	Seawater at the north side of Unit 1-4 water intake channel	Seawater obtained between the water intake channel Unit 1 and 2
Sampling date	Jun 24, 2013	Jun 24, 2013
Sampling time	5:50 PM	6:00 PM
Measurement date	Jun 26, 2013	Jun 26, 2013
Measurement amount (Bq/L)	1,500	420