

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 29, 2013	Sep 29, 2013	Sep 29, 2013	Sep 29, 2013	Sep 29, 2013	
Time of sampling	11:22 AM	11:27 AM	11:35 AM	11:25 AM	11:15 AM	
All $\beta$	150	49	130	ND(17)	32	
H-3 (Approx. 12 years)	140,000	400	130	350	1700	

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

