

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-8	F-1*1
Date of Sampling	Oct 3, 2013	Oct 3, 2013	Oct 3, 2013	Oct 3, 2013	Oct 3, 2013		Oct 3, 2013	Oct 3, 2013
Time of sampling	9:55 AM	10:05 AM	11:50 AM	11:40 AM	11:30 AM		12:01 PM	10:15 AM
All β	90	43	55	ND(17)	17		17	ND(17)
H-3 (Approx. 12 years)	130,000	350	140	450	2,400		1,200	110

*1 Sampling at F-1 is for the purpose to investigate influence on the water leak near the H4 area, which was happened in 2012 (we will not continue to monitor this sampling point).

* Data announced this time is provided in a thick-frame. The other data was announced on October 3.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

