

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area						
	E-1	E-2	E-3	E-4	E-5	E-6	E-8
Date of Sampling	Oct 5, 2013	Oct 5, 2013	Oct 5, 2013	Oct 5, 2013	Oct 5, 2013		
Time of sampling	7:55 AM	8:00 AM	8:27 AM	8:18 AM	8:10 AM		
All β	160	19	78	33	ND(19)		
H-3 (Approx. 12 years)	160,000	530	150	190	2,700		

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

