

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013	Oct 9, 2013
Time of sampling	10:05 AM	10:15 AM	10:30 AM	10:40 AM	10:50 AM	9:43 AM	11:43 AM	11:33 AM
All β	230	44	75	43	ND(19)	ND(19)	ND(19)	ND(19)
H-3 (Approx. 12 years)	280,000	420	230	270	2,400	340	840	1,500

* Data announced this time is provided in a thick-frame. The other data was announced on October 9.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

