

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

| | Groundwater around H4 area | | | | | | | |
|------------------------|----------------------------|--------------|--------------|--------------|--------------|-----|-----|-----|
| | E-1 | E-2 | E-3 | E-4 | E-5 | E-6 | E-7 | E-8 |
| Date of Sampling | Oct 13, 2013 | Oct 13, 2013 | Oct 13, 2013 | Oct 13, 2013 | Oct 13, 2013 | | | |
| Time of sampling | 10:15 AM | 10:25 AM | 11:55 AM | 10:49 AM | 10:39 AM | | | |
| All β | 72 | 65 | 86 | 47 | ND(19) | | | |
| H-3 (Approx. 12 years) | 270,000 | 400 | 180 | 390 | 2,500 | | | |

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

