

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 15, 2013	Oct 15, 2013	Oct 15, 2013	Oct 15, 2013	Oct 15, 2013	/	/	/
Time of sampling	9:20 AM	9:30 AM	9:40 AM	9:50 AM	10:00 AM	/	/	/
All $\beta$	90	50	120	93	44	/	/	/
H-3 (Approx. 12 years)	260,000	400	200	270	2,500	/	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

