Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

								Unit: Bq/L
	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 18, 2013	Oct 18, 2013	Oct 18, 2013	Oct 18, 2013	Oct 18, 2013			
Time of sampling	9:55 AM	10:45 AM	9:40 AM	9:30 AM	9:24 AM			
ΑΙΙ β	300,000	49	90	50	29			
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis			

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

