

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 1, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013	Oct 30, 2013
Time of sampling	11:08 AM	11:00 AM	10:52 AM	10:42 AM	10:35 AM	9:49 AM	10:22 AM	10:09 AM
All β	240,000	18	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)
H-3 (Approx. 12 years)	170,000	390	360	650	2,100	220	590	1,300

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4
All β	400,000 [10/17]	650 [9/4]	570 [9/18]	1,300 [9/15]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	370 [10/28]	490 [10/27]

	E-5	E-6	E-7	E-8
All β	100 [9/24]	46 [9/20]	ND	17 [10/3]
H-3 (Approx. 12 years)	2,800 [10/4] [10/17]	340 [9/25] [10/9]	840 [10/9]	1,500 [10/9]

Unit: Bq/L, sampling date is provided in parentheses.

