

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
November 6, 2013
Tokyo Electric Power Company

Unit: Bq/L

| | Groundwater around H4 area | | | | | | | | |
|------------------------|----------------------------|-------------|-------------|-------------|-------------|-----|-----|-----|------|
| | E-1 | E-2 | E-3 | E-4 | E-5 | E-6 | E-7 | E-8 | E-10 |
| Date of Sampling | Nov 4, 2013 | Nov 4, 2013 | Nov 4, 2013 | Nov 4, 2013 | Nov 4, 2013 | | | | |
| Time of sampling | 10:15 AM | 10:25 AM | 10:35 AM | 10:45 AM | 10:36 AM | | | | |
| All β | 320,000 | 49 | ND(17) | ND(17) | ND(17) | | | | |
| H-3 (Approx. 12 years) | 190,000 | 430 | 380 | 1,000 | 1,400 | | | | |

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

| | E-1 | E-2 | E-3 | E-4 | E-5 |
|------------------------|-----------------|------------|------------|--------------|-------------------------|
| All β | 400,000 [10/17] | 650 [9/4] | 570 [9/18] | 1,300 [9/15] | 100 [9/24] |
| H-3 (Approx. 12 years) | 790,000 [10/17] | 530 [10/5] | 440 [11/3] | 860 [11/3] | 2,800 [10/4] [10/17] |

| | E-6 | E-7 | E-8 | E-10 |
|------------------------|----------------------|------------|--------------|--------------|
| All β | 46 [9/20] | ND | 17 [10/3] | 24 [11/3] |
| H-3 (Approx. 12 years) | 340 [9/25] [10/9] | 840 [10/9] | 1,500 [10/9] | 6,700 [11/3] |

Unit: Bq/L, sampling date is provided in parentheses.

