

# Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>  
November 11, 2013  
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area								
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-10
Date of Sampling	Nov 9, 2013	Nov 9, 2013	Nov 9, 2013	Nov 9, 2013	Nov 9, 2013				
Time of sampling	9:37 AM	9:32 AM	9:24 AM	9:16 AM	9:08 AM				
All β	550,000	40	43	31	ND(18)				
H-3 (Approx. 12 years)	240,000	410	440	1,200	3,000				

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

## <Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	460,000 [11/8]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	730 [11/7]	1,200 [11/8]	2,800 [10/4] [10/17] [11/8]

	E-6	E-7	E-8	E-10
All β	46 [9/20]	ND	17 [10/3]	28 [11/6]
H-3 (Approx. 12 years)	340 [9/25] [10/9]	840 [10/9]	1,900 [11/6]	7,700 [11/6]

Unit: Bq/L, sampling date is provided in parentheses.

