

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of June 10 and 11, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Jun 11, 2013										Jun 10, 2013				
Sampled time	Not sampled	10:36 AM	10:55 AM	10:00 AM	10:05 AM	10:10 AM	10:15 AM	9:40 AM	10:30 AM	9:46 AM	9:56 AM	9:19 AM	9:26 AM	9:58 AM	10:17 AM
Chloride concentration (ppm)		9	13	16	17	82	10	10	8	11	11	8	9	16	9
Tritium (Bq/cm ³)		1.2E-1	<7.6E-3	1.1E-2	4.8E-2	9.9E-3	3.1E-2	7.8E-2	4.8E-2	3.7E+0	8.4E-1	6.9E-2	1.1E-1	3.5E-2	6.9E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<3.2E-2	<3.2E-2	<3.2E-2	<3.2E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on June 11 and 12.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.