


Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (1/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 9, 2013	Sep 9, 2013	/	/	/
Time of sampling	9:55 AM	10:15 AM	/	/	/
All β	1,900	22	/	/	/
H-3 (Approx. 12 years)	29,000	350	/	/	/

* Data announced this time is provided in a thick-frame. The other data was announced on September 11.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (2/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 10, 2013	Sep 10, 2013			
Time of sampling	11:15 AM	10:45 AM			
All β	2,000	21			
H-3 (Approx. 12 years)	64000	350			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

