

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 19, 2013	Sep 19, 2013	Sep 19, 2013	Sep 19, 2013	/
Time of sampling	9:15 AM	9:20 AM	9:45 AM	9:55 AM	
All β	340	35	520	78	
H-3 (Approx. 12 years)	70,000	320	ND(130)	260	

* Data announced this time is provided in a thick-frame. The other data was announced on September 20.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

