

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 23, 2013	Sep 23, 2013	Sep 23, 2013	Sep 23, 2013		
Time of sampling	11:35 AM	11:40 AM	11:45 AM	11:50 AM		
All $\beta$	290	19	220	22		
H-3 (Approx. 12 years)	150,000	300	ND(130)	230		

\* Data announced this time is provided in a thick-frame. The other data was announced on September 24.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

