

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013
Time of sampling	8:30 AM	8:32 AM	8:35 AM	8:40 AM	8:45 AM	8:50 AM	9:00 AM	9:05 AM
All β	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)
Tritium	10	130	350	53	50	220	270	740

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

