LINE D. M

Sampling Results Regarding the Water Leak at the Tanks in the H4 area and the B area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

				-							Unit: Bq/L
	Seawater of the	water outletJunction of the drainage channels B and Cuge channeland C	Side ditch next to the tank (X-2)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Junction of the drainage channel C and the side ditch	Sampling points of the inside of drainage channel B					
						Point that showed a high dose equivalent rate on August 21 (B-1)		Point immediately short of the junction with the drainage channel C (B-3)		date in the drainage	Drainage channel C
Date of Sampling	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013	Oct 20, 2013
Time of sampling	9:48 AM	10:21 AM	10:02 AM	10:07 AM	10:16 AM	* Note 4	* Note 4	10:26 AM Note 4	10:33 AM	10:39 AM	9:55 AM
Cs-134(Approx. 2 years)	ND(1.1)	ND(19)	21	44	ND(18)	* Note 4	* Note 4	70 Note 4	ND(18)	ND(18)	ND(19)
Cs-137(Approx.30 years)	ND(1.3)	ND(26)	70	100	ND(26)	* Note 4	* Note 4	160 Note 4	ND(26)	ND(26)	ND(26)
All β	ND(20)	54	1,200	1,600	78	* Note 4	* Note 4	9,800 Note 4	14	ND(13)	59

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

Note 3: Water inflow location of drainage channel to the tank area

Note 4: Collection of accumulated water and cleaning of the ditch are ongoing.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

