


Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Seaside impermeable

— : Location where ground improvement construction was completed, or being implemented (as of April 18, 2014)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Underground water observation hole No.1-17
Date of sampling	Jun 1, 2014	41,791	Jun 1, 2014	Jun 1, 2014	Jun 2, 2014	Jun 1, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 3, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014
Time of sampling	11:22 AM	10:45 AM	10:02 AM	10:25 AM	9:30 AM	9:33 AM	9:58 AM	10:33 AM	10:34 AM	6:38 AM	9:33 AM	9:45 AM	9:58 AM	10:12 AM	9:16 AM
Chloride (unit: ppm)	-	-	-	-	-	-	-	-	-	120	-	-	-	-	-
Cs-134 (Approx. 2 years)	24	ND(0.37)	ND(0.32)	ND(0.42)	ND(0.45)	ND(0.45)	ND(0.41)	5,700	15	2.2	0.50	2.7	17	ND(2.4)	ND(0.52)
Cs-137 (Approx.30 years)	63	ND(0.47)	ND(0.48)	ND(0.56)	ND(0.56)	ND(0.52)	0.56	17,000	41	6.6	1.4	7.2	46	ND(1.1)	1.0
The other Y	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	ND	ND	100	3.8	ND	ND	ND	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	370	0.42	ND	ND	ND	8:24 AM	0.56	ND
	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	3.8	ND	ND	ND	ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	15	1.6
Gross β	230	18	21	ND(17)	ND(18)	ND(17)	160	620,000	36,000	35	36	87	3,600	1,100,000	17,000
H-3 (Approx. 12 years)	3,300	8,400	1,700	ND(110)	26,000	1,200	140,000	8,900	33,000 ^{*1}	ND(110)	9,700	44,000	13,000	9,600	12,000
Sr-90 (Approx. 29 years)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5
Date of sampling	Jun 2, 2014					Jun 3, 2014								
Time of sampling	9:45 AM					9:53 AM								
Chloride (unit: ppm)	-					-								
Cs-134 (Approx. 2 years)	14					ND(0.33)								
Cs-137 (Approx.30 years)	40					ND(0.44)								
The other Y	Mn-54 (Approx. 310 days)	4.2				ND								
	Co-60 (Approx. 5 years)	ND				ND								
	Ru-106 (Approx. 370 days)	ND				ND								
	Sb-125 (Approx. 3 years)	ND				ND								
Gross β	350,000					2,600								
H-3 (Approx. 12 years)	67,000					860								
Sr-90 (Approx. 29 years)	-					-								

* Data announced this time is provided in a thick-frame. The other data was announced on June 2, 3, and 4.

** "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

** "-" indicates that the measurement was out of range.

*1 The highest measurement value (compared to the previous values provided in the handouts published in 'Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection')

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)															
	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Underground water observation hole No.1-17
Date of sampling					Jun 5, 2014		Jun 5, 2014	Jun 5, 2014		Jun 5, 2014	Jun 5, 2014	Jun 5, 2014	Jun 5, 2014	Jun 5, 2014	Jun 5, 2014
Time of sampling					9:30 AM		11:00 AM	10:50 AM		7:00 AM	10:48 AM	10:00 AM	10:20 AM	10:15 AM	10:26 AM
Chloride (unit: ppm)					-		-	-		110	-	-	-	-	-
Cs-134 (Approx. 2 years)					ND(0.41)		ND(0.44)	5,800		1.7	ND(0.40)	3.2	15	ND(2.4)	0.65
Cs-137 (Approx.30 years)					ND(0.44)		0.72	16,000		4.3	1.7	8.3	40	1.4	0.69
The other γ	Mn-54 (Approx. 310 days)				ND		ND	100		ND	ND	ND	ND	ND	ND
	Co-60 (Approx. 5 years)				ND		ND	370		ND	ND	ND	ND	0.53	ND
	Sb-125 (Approx. 3 years)				ND		ND	ND		ND	ND	ND	ND	11	ND
Gross β					ND(17)		130	600,000		24	61	240	3,800	1,000,000	25,000 ^{*1}
H-3 (Approx. 12 years)					Under analysis		Under analysis	Under analysis		Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)					-		-	-		-	-	-	-	-	-


	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5
Date of sampling						Jun 5, 2014								
Time of sampling						9:35 AM								
Chloride (unit: ppm)						-								
Cs-134 (Approx. 2 years)						ND(0.35)								
Cs-137 (Approx.30 years)						ND(0.46)								
The other γ	Mn-54 (Approx. 310 days)					ND								
	Co-60 (Approx. 5 years)					ND								
	Sb-125 (Approx. 3 years)					ND								
Gross β						2,500								
H-3 (Approx. 12 years)						Under analysis								
Sr-90 (Approx. 29 years)						-								

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

*1 The highest measurement value (compared to the previous values provided in the handouts published in 'Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection')

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Seawater)



Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, In front of Unit 2 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (In front of impermeable wall)	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 3, 2014	Jun 3, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014	Jun 2, 2014		
Time of sampling	6:25 AM	6:15 AM	5:57 AM	6:25 AM	6:00 AM	6:35 AM	6:35 AM	6:06 AM	6:11 AM	6:17 AM	6:19 AM	6:14 AM		
Cs-134(Approx. 2 years)	ND(0.68)	ND(1.7)	ND(1.8)	4.1	5.8	5.2	14	3.4	19	13	16	8.5	60	10
Cs-137(Approx.30 years)	1.0	ND(1.8)	ND(2.1)	10	15	15	38	14	56	39	39	27	90	10
Gross β	15	ND(22)	ND(22)	66	100	1,500	1,200	100	1,000	460	340	200		
H-3 (Approx. 12 years)	4.3	5.4	ND(1.7)	130	210	3,800	3,200 ¹	230	2,600 ¹	1,100	680	380	60,000	10,000
Sr-90 (Approx. 29 years)	-	-	-	-	-	-	-	-	-	-	-	-	30	10

Unit: Bq/L

	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Jun 2, 2014												
Time of sampling	5:30 AM												
Cs-134(Approx. 2 years)	ND(0.60)											60	10
Cs-137(Approx.30 years)	ND(0.56)											90	10
Gross β	12												
H-3 (Approx. 12 years)	ND(1.7)											60,000	10,000
Sr-90 (Approx. 29 years)	-											30	10

* Data announced this time is provided in a thick-frame. The other data was announced on June 3 and 4.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm³ to Bq/L]).

*1 The highest measurement value (compared to the previous values provided in the handouts published in 'Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection')

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (4/4)
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, In front of Unit 2 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (In front of impermeable wall)	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	Jun 5, 2014	Jun 5, 2014	/	/	/	/	/		
Time of sampling	/	/	/	/	/	6:56 AM	6:56 AM	/	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	/	/	4.2	28	/	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	12	81	/	/	/	/	/	90	10
Gross β	/	/	/	/	/	1,700	1,100	/	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	/	/	Under analysis	Under analysis	/	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	-	-	/	/	/	/	/	30	10

Unit: Bq/L

	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	/	/	/	/	/	/		
Time of sampling	/	/	/	/	/	/	/	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/	90	10
Gross β	/	/	/	/	/	/	/	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	/	30	10

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm³ to Bq/L]).

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-1-1	Groundwater observation hole No.0-1-2	Groundwater observation hole No.0-2	Groundwater observation hole No.0-3-1	Groundwater observation hole No.0-3-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1 ¹	Groundwater observation hole No.1-2 ²	Groundwater observation hole No.1-3 ³	Groundwater observation hole No.1-4 ⁴	Groundwater observation hole No.1-5 ⁵	Groundwater observation hole No.1-6
Cs-134 (Approx. 2 years)	29 <5/25>	ND	0.61 <3/2>	0.61 [10/13]	0.64 <4/6>	0.82 <1/14>	ND	13 [8/29]	1.9 [7/8]	11,000 [7/9]	10 [9/2]	1.5 [7/8]	310 [8/5]	6,300 <3/31>
Cs-137 (Approx.30 years)	78 <5/25>	ND	1.5 <3/2>	2.2 <1/12>	1.1 <4/6>	2.1 <1/14>	1.4 <1/12>	31 [8/29]	3.6 [7/8]	22,000 [7/9]	24 [9/2]	3.6 [7/8]	650 [8/5]	17,000 <6/2>
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	ND	ND	0.64 <2/20>	ND	1.0 [7/5]	62 [7/5]	ND	ND	320 <2/13> <2/17>
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND	830 <2/20>
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	ND	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12] [8/26]	ND	12 [8/8]	34 <5/19>
Gross β	300 [8/29] <5/18>	21 [12/7]	21 [11/10]	87 [10/13]	ND	67 ^{*1} [12/11]	29 [12/29]	1,900 [5/24]	4,400 [7/8]	900,000 [7/5] [7/9]	160,000 [8/12] [8/15]	380 [8/19]	56,000 [8/5]	860,000 <5/8>
H-3 (Approx. 12 years)	45,000 [8/29]	18,000 [12/7]	74,000 [12/15] <1/19>	6,800 <2/16>	ND	76,000 <2/6>	56,000 <2/23>	500,000 [5/24] [6/7]	630,000 [7/8]	430,000 [9/16]	290,000 [7/12]	98,000 [7/11]	72,000 [8/15]	110,000 <2/6>
Sr-90(Approx. 29 years)	140 [8/8]	7.9 [12/7]	2.6 [11/10]	0.73 [9/2]	1.5 [11/20]	2.3 [12/6]	ND(0.83) [10/27]	1,300 [8/22]	2,300 [6/28]	5,000,000 [7/5]	130,000 [8/8]	200 [7/8]	5,100 [8/22]	-

Unit: Bq/L

	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-10	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-13	Groundwater observation hole No.1-14	Groundwater observation hole No.1-16	Groundwater observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)	Groundwater observation hole No.2	Groundwater observation hole No.2-1 ¹	Groundwater observation hole No.2-2	Groundwater observation hole No.2-3
Cs-134 (Approx. 2 years)	47 [11/25]	170 [9/3]	-	1.1 <1/13>	74 [10/21]	37,000 <2/13>	88 ^{*2} <2/27>	3.1 ^{*1} [12/13]	1.2 [12/5]	110 [9/23]	0.88 <2/26>	0.66 [9/1]	15 <2/12>	2.2 <2/26>
Cs-137 (Approx.30 years)	110 [11/25]	380 [9/3]	-	3.4 <4/28>	170 [10/21]	93,000 <2/13>	230 ^{*2} <2/27>	4.7 <2/17>	2.8 <4/28>	250 [9/23]	2.5 <2/26>	1.1 [8/29] [9/1]	38 <2/12>	5.5 <2/26>
The other y	Ru-106 (Approx. 370 days)	ND	ND	-	ND	5.4 [10/28]	ND	ND	9.2 [10/28]	5.5 <4/21> <5/1>	25 [9/2]	ND	ND	ND
	Mn-54 (Approx. 310 days)	12 <2/3>	ND	-	ND	ND	ND	ND	ND	8.5 <4/28>	ND	ND	ND	0.29 [12/6]
	Co-60 (Approx. 5 years)	1.3 <2/3>	ND	-	ND	0.51 [10/24]	ND	0.44 <5/29>	0.9 [11/7]	0.61 [11/25]	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	-	ND	61 [10/21]	ND	ND	18 <5/29>	2.1 [11/25]	ND	ND	ND	ND
Gross β	59,000 <2/3>	2,100 ^{*2} [11/17]	78 ^{*2} <1/27>	2,300 [12/26]	1,100 <5/5>	260,000 <2/12> <2/13>	4,200 <5/22>	3,100,000 <1/20> <1/30> <2/3>	17,000 <6/2>	700,000 [9/23]	1,700 [7/8]	380 [7/29]	600 <4/16>	1,500 [12/6] <1/8>
H-3 (Approx. 12 years)	25,000 <5/26>	860 ^{*2} [11/14]	270,000 ^{*2} <1/27>	85,000 [9/13]	440,000 [10/31]	88,000 <2/12>	23,000 <2/13>	43,000 [9/26]	32,000 <1/20>	460,000 [8/19]	1,000 <2/23>	440 [8/26]	660 <1/8>	1,700 [12/6]
Sr-90(Approx. 29 years)	20,000 [12/9]	300 [10/3]	-	18 [10/21]	290 [10/21]	Under analysis	98 [12/9]	1,400,000 [12/9]	9.5 [12/9]	-	54 [5/31]	5.9 [7/25]	320 [12/25]	1,200 [12/6]

Unit: Bq/L

	Groundwater observation hole No.2-5	Groundwater observation hole No.2-6	Groundwater observation hole No.2-7	Groundwater observation hole No.2-8	Groundwater observation hole No.2-9	Groundwater pumped up from the well point (between Unit 2 and 3)	Groundwater observation hole No.3	Groundwater observation hole No.3-1 ¹	Groundwater observation hole No.3-2	Groundwater observation hole No.3-3	Groundwater observation hole No.3-4	Groundwater observation hole No.3-5
Cs-134 (Approx. 2 years)	41 <5/7>	17 <3/11>	3.5 <2/23>	0.47 <4/9>	ND	2.0 <4/23>	3.5 [7/25]	1.2 [7/25] [8/8]	12 <5/28>	73 <5/21>	3.3 <5/14>	64 <1/15>
Cs-137 (Approx.30 years)	110 <5/7>	50 <3/11>	9.0 <2/23>	1.3 <4/9>	0.58 ^{*2} <2/11>	4.7 <4/23>	5.9 [8/8]	2.6 [8/1]	33 <5/28>	200 <5/21>	9.4 <5/14>	170 <1/15> <6/4>
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	6.5 ^{*2} <2/11>	ND	ND	ND	ND	ND	-
	Mn-54 (Approx. 310 days)	0.95 <6/4>	ND	ND	ND	ND	ND	ND	ND	ND	0.54 [10/30]	-
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	-
	Sb-125 (Approx. 3 years)	74 <5/7>	ND	ND	ND	ND	ND	1.6 <1/1>	ND	ND	ND	-
Gross β	150,000 <2/12>	3,200 [12/5]	1,000 <5/14> <5/16> <5/18> <5/21> <5/28> <6/4>	4,300 <6/4>	1,700 <2/7>	240,000 [12/12]	1,400 [7/11]	180 [8/1]	2,800 <5/28>	4,900 <4/30>	28 <4/30>	350 <5/28>
H-3 (Approx. 12 years)	7,900 <4/9>	1,200 [11/24] [11/27]	1,100 <1/19>	1,700 <4/6>	13,000 ^{*2} <2/7> <2/11>	5,900 <5/21>	3,200 [2012/12] [12]	460 [8/1]	2,800 <5/14>	8,000 <5/7>	170 [9/18]	170 <1/8>
Sr-90(Approx. 29 years)	Under analysis	Under analysis	ND(1.4) [11/21]	Under analysis	Under analysis	-	8.3 [2012/12] [12]	4.4 [7/23]	Under analysis	-	ND	-

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

^{*1} Analysis result of pumped water.

^{*2} The results are for a reference, since the water was highly turbid. (γ and Gross β were measured after filtration.)

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses. () : 2013, < > : 2014

* *** is provided next to the name of the holes where the sampling could not be performed due to the chemical injection of ground improvement.

<Reference> The Highest Dose Until the Previous Measurement* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, In front of Unit 2 discharge channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (In front of impermeable wall)
Cs-134(Approx. 2 years)	1.8 [6/21]	2.8 [12/2]	5.3 [8/5]	32 [10/11]	11 <5/5>	87 [10/10]	93 [10/10]	3.4 <6/2>	52 [12/21]	37 <5/12>	62 [9/16]	15 <4/14> <5/19>
Cs-137(Approx.30 years)	4.5 <3/17>	5.8 [12/2]	8.6 [8/5]	73 [10/11]	33 <5/12>	200 [10/10]	200 [10/10]	14 <6/2>	110 [10/11] [12/21]	98 <5/12>	140 [9/16]	45 <5/19>
Gross β	17 <1/6>	46 [8/19]	40 [7/3]	320 [8/12]	140 <5/5>	1,900 <5/20>	1,200 <6/3>	100 <6/2>	1,000 <6/2>	590 <5/26>	360 [10/7]	380 <3/10>
H-3 (Approx. 12 years)	8.7 <5/12>	24 [8/19]	340 [6/26]	510 [9/2]	220 <5/5>	4,200 <5/27>	2,900 <6/1>	—	2,500 <5/26>	1,600 <5/26>	770 <4/14>	540 <4/14>
Sr-90 (Approx. 29 years)	4.7 [6/26]	—	7.2 [6/26]	220 [8/19]	—	480 [8/22]	290 [10/20]	—	340 [10/14]	190 [9/23]	140 [6/21]	—

Unit: Bq/L

	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the south breakwater	Southeast side of the north breakwater	South side of the south breakwater
Cs-134(Approx. 2 years)	ND	3.3 [12/24]	3.3 [10/17]	4.4 [12/24]	5.0 [12/2]	3.5 [10/17]	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	3.0 [7/15]	7.3 [10/11]	9.0 [10/17]	10 [12/24]	8.4 [12/2]	7.8 [10/17]	ND	ND	1.6 [10/18]	ND	ND
Gross β	15 <1/13>	69 [8/19]	74 [8/19]	60 [7/4]	69 [8/19]	79 [8/19]	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	5.6 <5/19>	68 [8/19]	67 [8/19]	59 [8/19]	52 [8/19]	60 [8/19]	4.7 [8/14]	1.7 <4/23>	6.4 [10/8]	1.8 <5/29>	2.8 <4/23>
Sr-90 (Approx. 29 years)	0.29 [6/26]	49 [8/19]	—	—	—	—	—	—	—	—	—

* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses. (): 2013, < >: 2014

* "-" indicates that the measurement was out of range.

[Reference] Standard values

Unit: Bq/L

	Cs-134	Cs-137	H-3	Sr-90
Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2)	60	90	60,000	30
WHO Guidelines for drinking-water quality	10	10	10,000	10