


### Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Seaside impermeable

— : Location where ground improvement construction was completed, or being implemented (as of April 18, 2014)

## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9 (note)	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Underground water observation hole No.1-17
Date of sampling					Oct 16		Oct 16	Oct 19			Oct 16	Oct 16	Oct 19	Oct 19	Oct 16
Time of sampling					9:30 AM		9:54 AM	9:15 AM			10:14 AM	9:39 AM	8:45 AM	9:35 AM	10:33 AM
Chloride (unit: ppm)					—		—	—			—	—	—	—	—
Cs-134 (Approx. 2 years)					ND(0.38)		ND(0.38)	60,000			ND(0.37)	2.2	88	ND(1.1)	ND(0.47)
Cs-137 (Approx.30 years)					ND(0.51)		ND(0.57)	180,000			1.2	8.8	280	1.7	ND(0.52)
The other y	Mn-54 (Approx. 310 days)				ND		ND	260			ND	ND	ND	2.7	ND
	Co-60 (Approx. 5 years)				ND		ND	1500			ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)				ND		ND	ND			ND	ND	ND	12	ND
Gross β					42		37	4,700,000			49	190	15,000	710,000	46,000
H-3 (Approx. 12 years)					9,800		200,000	8,300			6,500	36,000	920	4,400	160,000
Sr-90 (Approx. 29 years)					—		—	—			—	—	—	—	—

	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5 (note)	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5(note)
Date of sampling														
Time of sampling														
Chloride (unit: ppm)														
Cs-134 (Approx. 2 years)														
Cs-137 (Approx.30 years)														
The other y	Mn-54 (Approx. 310 days)													
	Co-60 (Approx. 5 years)													
	Sb-125 (Approx. 3 years)													
Gross β														
H-3 (Approx. 12 years)														
Sr-90 (Approx. 29 years)														

\* Data announced this time is provided in a thick-frame. The other data was announced on October 17, and 20, 2014.  
 \* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses, except "the other y"  
 \* "-" indicates that the measurement was out of range.  
 (Note) As of No. 1-9, 2-5, and 3-5, yw was not measured because they are sampled by sampler. Gross β were measured after filtration for references.

## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-3-1	Underground water observation hole No.0-3-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-6	Underground water observation hole No.1-8	Underground water observation hole No.1-9(note)	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Underground water observation hole No.1-17
Date of sampling					Oct 20		Oct 20	Oct 20	Oct 20		Oct 20	Oct 20	Oct 20	Oct 20	Oct 20
Time of sampling					9:30 AM		9:33 AM	10:00 AM	10:12 AM		9:51 AM	9:15 AM	9:25 AM	9:35 AM	10:32 AM
Chloride (unit: ppm)					—		—	—	—		—	—	—	—	—
Cs-134 (Approx. 2 years)					ND(0.38)		ND(0.46)	54,000	5.8		0.69	19	130	5.6	ND(0.51)
Cs-137 (Approx.30 years)					ND(0.51)		ND(0.55)	170,000	21		1.3	51	390 *1	14	ND(0.54)
The other γ	Mn-54 (Approx. 310 days)				ND		ND	240	ND		ND	ND	ND	2.3	ND
	Co-60 (Approx. 5 years)				ND		ND	1,100	ND		ND	ND	ND	ND	ND
	Ru-106 (Approx. 370 days)				ND		4.5	ND	ND		ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)				ND		ND	ND	ND		ND	ND	ND	15	ND
Gross β				43		33	3,500,000	5400		29	410	15,000	630,000	31,000	
H-3 (Approx. 12 years)					Under analysis		Under analysis	Under analysis	Under analysis		Under analysis	Under analysis	Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)					—		—	—	—		—	—	—	—	

	Groundwater pumped up from the well point (between Unit 1 and 2)	Underground water observation hole No.2	Underground water observation hole No.2-2	Underground water observation hole No.2-3	Underground water observation hole No.2-5(note)	Underground water observation hole No.2-6	Underground water observation hole No.2-7	Underground water observation hole No.2-8	Groundwater pumped up from the well point (between Unit 2 and 3)	Underground water observation hole No.3	Underground water observation hole No.3-2	Underground water observation hole No.3-3	Underground water observation hole No.3-4	Underground water observation hole No.3-5(note)
Date of sampling	Oct 20													
Time of sampling	10:00 AM													
Chloride (unit: ppm)	—													
Cs-134 (Approx. 2 years)	1.9													
Cs-137 (Approx.30 years)	6.8													
The other γ	Mn-54 (Approx. 310 days)	2.2												
	Co-60 (Approx. 5 years)	ND												
	Ru-106 (Approx. 370 days)	ND												
	Sb-125 (Approx. 3 years)	ND												
Gross β	360,000													
H-3 (Approx. 12 years)	Under analysis													
Sr-90 (Approx. 29 years)	—													


\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses, except "the other γ"

\* "—" indicates that the measurement was out of range.

(Note) As of No. 1-9, 2-5, and 3-5, γ was not measured because they are sampled by sampler. Gross β were measured after filtration for references.

\*1 The highest measurement value (compared to the previous values provided in the handouts published in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection")

# Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Seawater)



## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 intake channel (in front of impermeable wall)	1F, In front of Unit 2 intake channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (In front of impermeable wall)	1F, Around the south discharge channel	1F, Port entrance	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	/	/	/	/	/	Oct 17		
Time of sampling	/	/	/	/	/	/	/	/	/	/	10:40 AM		
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	ND(1.2)	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	ND(1.4)	90	10
Gross β	/	/	/	/	/	/	/	/	/	/	ND(18)		
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	3.0	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	-	30	10

Unit: Bq/L

	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	1F, Port center	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater		Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Oct 17	Oct 17	Oct 17	Oct 17	/	Oct 17	Oct 17	Oct 17	Oct 17	Oct 17	/		
Time of sampling	10:48 AM	10:53 AM	10:57 AM	10:45 AM	/	8:41 AM	8:45 AM	8:35 AM	8:25 AM	8:30 AM	/		
Cs-134(Approx. 2 years)	ND(1.5)	ND(1.2)	ND(1.4)	ND(2.0)	/	ND(0.60)	ND(0.83)	ND(0.70)	ND(0.72)	ND(0.58)	/	60	10
Cs-137(Approx.30 years)	3.0	1.6	1.8	2.5	/	ND(0.68)	ND(0.93)	ND(0.76)	ND(0.73)	ND(0.59)	/	90	10
Gross β	ND(18)	ND(18)	ND(18)	ND(18)	/	ND(17)	ND(17)	ND(17)	ND(17)	ND(17)	/		
H-3 (Approx. 12 years)	7.4	2.1	3.3	1.9	/	ND(1.6)	ND(1.6)	ND(1.6)	ND(1.6)	ND(1.6)	/	60,000	10,000
Sr-90 (Approx. 29 years)	-	-	-	-	/	-	-	-	-	-	/	30	10

\* Data announced this time is provided in a thick-frame. The other data was announced on

October 18 and 19, 2014.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

\* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm<sup>3</sup> to Bq/L]).

**Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (4/4)  
Seawater**

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 intake channel (in front of impermeable wall)	1F, In front of Unit 2 intake channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (In front of impermeable wall)	1F, Around the south discharge channel	1F, Port entrance	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20		
Time of sampling	5:30 AM	5:26 AM	5:35 AM	6:04 AM	5:40 AM	5:46 AM	5:54 AM	5:51 AM	5:57 AM	4:35 AM	9:12 AM		
Cs-134(Approx. 2 years)	ND(0.66)	ND(2.0)	ND(1.6)	4.2	6.3	3.5	24	24	17	ND(0.76)	ND(1.1)	60	10
Cs-137(Approx.30 years)	ND(0.62)	ND(2.1)	ND(2.0)	15	16	13	78	82	54	ND(0.60)	ND(1.2)	90	10
Gross β	13	21	ND(15)	75	50	61	550	480	220	14	ND(17)		
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	60,000	10,000
Sr-90(Approx. 29 years)	Under analysis	—	—	—	—	—	—	—	—	Under analysis	—	30	10

Unit: Bq/L

	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	1F, Port center	North side of the north breakwater	West side of the port	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater		Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	Oct 20	Oct 20	Oct 20	Oct 20	Oct 20								
Time of sampling	9:21 AM	9:32 AM	9:35 AM	9:17 AM	6:01 AM								
Cs-134(Approx. 2 years)	ND(1.1)	1.4	ND(1.8)	ND(1.2)	ND(1.1)							60	10
Cs-137(Approx.30 years)	ND(1.2)	2.5	3.1	ND(1.2)	3.0							90	10
Gross β	ND(17)	ND(17)	ND(17)	ND(17)	ND(16)								
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis							60,000	10,000
Sr-90(Approx. 29 years)	—	—	—	—	—							30	10

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

\* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm<sup>3</sup> to Bq/L]).

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-1-1	Groundwater observation hole No.0-1-2	Groundwater observation hole No.0-2	Groundwater observation hole No.0-3-1	Groundwater observation hole No.0-3-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1 <sup>*</sup>	Groundwater observation hole No.1-2 <sup>*</sup>	Groundwater observation hole No.1-3 <sup>*</sup>	Groundwater observation hole No.1-4 <sup>*</sup>	Groundwater observation hole No.1-5 <sup>*</sup>	Groundwater observation hole No.1-6
Cs-134 (Approx. 2 years)	29 <5/25>	ND	0.61 <3/2>	0.61 [10/13]	0.64 <4/6>	1.3 <9/25>	0.70 <6/29>	13 [8/29]	1.9 [7/8]	11,000 [7/9]	10 [9/2]	1.5 [7/8]	310 [8/5]	67,000 <10/17>
Cs-137 (Approx.30 years)	78 <5/25>	ND	1.5 <3/2>	2.2 <1/12>	1.1 <4/6>	5.1 <9/25>	1.6 <6/29>	31 [8/29]	3.6 [7/8]	22,000 [7/9]	24 [9/2]	3.6 [7/8]	650 [8/5]	200,000 <10/16>
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	ND	0.64 <2/20>	ND	1.0 [7/5]	62 [7/5]	ND	ND	ND	700 <10/13>
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND	3600 <10/13>
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	ND	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12] [8/28]	ND	12 [8/8]	34 <5/19>
Gross β	300 [8/29] <5/18>	21 [12/7]	24 <6/22>	87 [10/13]	ND	74 <10/9>	44 <6/22>	1,900 [5/24]	4,400 [7/8]	9,300,000 [7/8]	160,000 [8/12] [8/15]	380 [8/19]	56,000 [8/5]	7,800,000 <10/13>
H-3 (Approx. 12 years)	45,000 [8/29]	18,000 [12/7]	74,000 [12/15] <1/19>	6,800 <2/16>	ND	76,000 <2/6>	56,000 <2/23>	500,000 [5/24] [6/7]	630,000 [7/8]	430,000 [9/16]	290,000 [7/12]	98,000 [7/11]	72,000 [8/15]	110,000 <sup>*2</sup> <2/6>
Sr-90(Approx. 29 years)	140 [8/8]	7.9 [12/7]	2.6 [11/10]	0.73 [9/2]	1.5 [11/20]	2.3 [12/6]	ND(0.83) [10/27]	1,300 [8/22]	2,300 [6/28]	5,000,000 [7/5]	130,000 [8/8]	200 [7/8]	5,100 [8/22]	1,100,000 <8/4>

Unit: Bq/L

	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-10	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-13	Groundwater observation hole No.1-14	Groundwater observation hole No.1-15	Groundwater observation hole No.1-16	Groundwater observation hole No.1-17	Groundwater pumped up from the well point (between Unit 1 and 2)	Groundwater observation hole No.2	Groundwater observation hole No.2-1 <sup>*</sup>	Groundwater observation hole No.2-2
Cs-134 (Approx. 2 years)	47 [11/25]	170 [9/3]	-	1.1 <1/13>	74 [10/21]	37,000 <2/13>	130 <10/18>	ND	30 <7/28>	1.4 <7/7>	110 [9/23]	0.88 <2/26>	0.66 [9/1]	15 <2/12>
Cs-137 (Approx.30 years)	110 [11/25]	380 [9/3]	-	3.4 <4/28>	170 [10/21]	93,000 <2/13>	380 <10/18>	0.88 <7/10>	86 <7/28>	3.0 <9/29>	250 [9/23]	2.5 <2/26>	1.1 [8/29] [9/1]	38 <2/12>
The other γ	Ru-106 (Approx. 370 days)	ND	ND	-	ND	5.4 [10/28]	ND	ND	9.2 [10/28]	5.5 <4/21> <5/1>	25 [9/2]	ND	ND	ND
	Mn-54 (Approx. 310 days)	12 <2/3>	ND	-	ND	ND	2.1 <9/8>	ND	11 <8/25>	ND	8.5 <4/28>	ND	ND	ND
	Co-60 (Approx. 5 years)	1.3 <2/3>	ND	-	ND	0.51 [10/24]	ND	0.44 <5/29>	0.9 [11/7]	0.61 [11/25]	0.61 <6/9>	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	-	ND	61 [10/21]	ND	ND	24 <6/16>	2.1 [11/25]	ND	ND	ND	ND
Gross β	59,000 <2/3>	2,100 <sup>*2</sup> [11/17]	78 <sup>*2</sup> <1/27>	2,300 [12/26]	1,100 <5/5>	260,000 <2/12> <2/13>	29,000 <10/3>	110 <7/10>	3,100,000 <1/20> <1/30> <2/3>	1,200,000 <10/9>	1,900,000 [9/23]	1,700 [7/8]	380 [7/29]	600 <4/16>
H-3 (Approx. 12 years)	33,000 <6/2>	860 <sup>*2</sup> [11/14]	270,000 <sup>*2</sup> <1/27>	85,000 [9/13]	440,000 [10/31]	88,000 <2/12>	23,000 <2/13>	74,000 <7/10>	43,000 [9/26]	160,000 <10/13>	460,000 [8/19]	1,000 <2/23>	440 [8/26]	660 <1/8>
Sr-90(Approx. 29 years)	35,000 <2/17>	300 [10/3]	-	170 <8/4>	290 [10/21]	160,000 <2/12>	13,000 <8/4>	Under analysis	2,700,000 <2/13>	170,000 <8/4>	-	54 [5/31]	5.9 [7/25]	320 [12/25]

Unit: Bq/L

	Groundwater observation hole No.2-3	Groundwater observation hole No.2-5	Groundwater observation hole No.2-6	Groundwater observation hole No.2-7	Groundwater observation hole No.2-8	Groundwater observation hole No.2-9	Groundwater pumped up from the well point (between Unit 2 and 3)	Groundwater observation hole No.3	Groundwater observation hole No.3-1 <sup>*</sup>	Groundwater observation hole No.3-2	Groundwater observation hole No.3-3	Groundwater observation hole No.3-4	Groundwater observation hole No.3-5
Cs-134 (Approx. 2 years)	2.2 <2/26>	41 <5/7>	17 <3/11>	3.5 <2/23>	1.3 <7/20>	ND	2.2 <9/7>	3.5 [7/25]	1.2 [7/25] [8/8]	23 <8/27>	180 <7/2>	5.1 <7/23>	100 <7/30>
Cs-137 (Approx.30 years)	5.5 <2/26>	110 <5/7>	50 <3/11>	9.0 <2/23>	3.4 <7/20>	0.58 <sup>*2</sup> <2/11>	5.7 <9/7>	5.9 [8/8]	2.6 [8/1]	68 <9/3>	500 <7/2>	16 <8/27>	310 <7/30>
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	6.5 <sup>*2</sup> <2/11>	ND	ND	ND	ND	ND	-
	Mn-54 (Approx. 310 days)	0.29 [12/6]	0.95 <6/4>	ND	ND	ND	ND	ND	ND	ND	ND	0.54 [10/30]	-
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	-
	Sb-125 (Approx. 3 years)	ND	74 <5/7>	ND	ND	ND	ND	ND	1.6 <1/1>	ND	ND	ND	-
Gross β	1,500 [12/6] <1/8>	150,000 <2/12>	3,200 [12/5]	1,300 <6/20>	5,800 <7/23>	1,700 <2/7>	240,000 [12/12]	1,400 [7/11]	180 [8/1]	3,100 <8/20> <8/28>	8,900 <7/2>	46 <8/13>	510 <7/16>
H-3 (Approx. 12 years)	1,700 [12/6]	7,900 <4/9>	1,900 <8/10>	1,100 <1/19>	1,700 <4/8> <8/6> <8/13>	13,000 <sup>*2</sup> <2/7> <2/11>	12,000 <10/12> <10/15>	3,200 [Dec. 12, 2012]	460 [8/1]	3,700 <7/9>	8,000 <5/7>	170 [9/18]	170 <1/8>
Sr-90(Approx. 29 years)	1,200 [12/6]	34,000 <5/7>	Under analysis	ND(1.4) [11/21]	3,900 <3/30>	1,200 <sup>*2</sup> <2/11>	-	8.3 [Dec. 12, 2012]	4.4 [7/23]	2,000 <4/18>	3,600 <4/30>	ND	200 <5/28>

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

\*1 Analysis result of pumped water.

\*2 The results are for a reference, since the water was highly turbid. (γ and Gross β were measured after filtration.)

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses. ( ) : 2013, < > : 2014

\* \*\*\* is provided next to the name of the holes where the sampling could not be performed due to the chemical injection of ground improvement.

(Note) As of No. 1-9, 2-5, and 3-5, since September 17, γ was not measured because they are sampled by sampler. Gross β were measured after filtration for references.

<Reference> The Highest Dose Until the Previous Measurement\* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5-6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, In front of Unit 1 intake channel (in front of impermeable wall)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, South side of Unit 1-4 water intake channel (in front of impermeable wall)	1F, Around the south discharge channel	1F, Port entrance
Cs-134(Approx. 2 years)	1.8 [6/21]	2.8 [12/2]	5.3 [8/5]	32 [10/11]	12 <6/23>	12 <9/8>	50 <9/22>	62 [9/16]	15 <4/14> <5/19>	1.8 <6/9>	3.3 [12/24]
Cs-137(Approx.30 years)	4.5 <3/17>	5.8 [12/2]	8.6 [8/5]	73 [10/11]	33 <5/12>	40 <9/8>	150 <9/22>	140 [9/16] <9/22>	45 <5/19>	4.9 <6/9>	7.3 [10/11]
Gross β	17 <1/6>	46 [8/19]	40 [7/3]	320 [8/12]	140 <5/5> <7/14> <8/18> <9/1>	160 <8/18>	660 <6/9>	680 <9/22>	380 <3/10>	16 <6/9> <8/4>	69 [8/19]
H-3 (Approx. 12 years)	8.7 <5/12>	24 [8/19]	340 [6/26]	600 [8/18]	460 <8/18>	350 <8/18>	2,500 <6/23>	2,200 <7/21>	810 <8/4>	5.6 <5/19>	68 [8/19]
Sr-90 (Approx. 29 years)	4.7 [6/26]	—	7.2 [6/26]	220 [8/19]	—	—	660 <6/9>	470 <8/4>	—	0.29 [6/26]	49 [8/19]

	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	1F, Port center	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater
Cs-134(Approx. 2 years)	3.3 [10/17]	4.4 [12/24]	5.0 [12/2]	3.5 [10/17]	ND	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	9.0 [10/17]	10.0 [12/24]	8.4 [12/2]	7.8 [10/17]	7.8 <10/7>	ND	0.7 <10/8>	1.6 [10/18]	ND	ND
Gross β	74 [8/19]	60 [7/4]	69 [8/19]	79 [8/19]	58 <10/7>	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	67 [8/19]	59 [8/19]	52 [8/19]	60 [8/19]	54 <10/7>	4.7 [8/14]	1.8 <10/1>	6.4 [10/8]	1.8 <5/29>	2.8 <4/23>
Sr-90 (Approx. 29 years)	—	—	—	—	—	—	—	—	—	—

\* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14, 2013.

● Since some samples are still under analysis, the highest dose of the Strontium-90 is among those previously announced.

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses. ( ): 2013, < >: 2014

\* "-" indicates that the measurement was out of range.

[Reference] Standard values

Unit: Bq/L

	Cs-134	Cs-137	H-3	Sr-90
Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2)	60	90	60,000	30
WHO Guidelines for drinking-water quality	10	10	10,000	10