

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
February 12, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area													Well point	F-1
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12			
Date of Sampling	Feb 10, 2014	Feb 10, 2014	Feb 10, 2014	Feb 10, 2014	Feb 10, 2014	/	/	/	Feb 10, 2014	/	/	/	/	/	/
Time of sampling	9:50 AM	9:45 AM	9:50 AM	9:45 AM	9:40 AM	/	/	/	9:55 AM	/	/	/	/	/	/
Gross β	7,200	ND(15)	ND(15)	18	ND(15)	/	/	/	22	/	/	/	/	/	/
H-3 (Approx. 12 years)	51,000	370	1,700	630	1,800	/	/	/	2,500	/	/	/	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]	21 <1/22>
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	2,800 <1/17>	2,200 [12/7, 12/16, 12/18]	3,100 [11/10, 11/13]	350 [12/18] <1/1>	840 [10/9]

	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Gross β	17 [10/3]	730 [12/27]	29 <1/30>	110<2/5>	37 <1/23>	16,000 [11/28]	24 <1/31>
H-3 (Approx. 12 years)	2,300 [11/13]	51,000 [11/25]	54,000 <1/21>	190<2/5>	2,500 <1/23>	190,000 [11/30]	720 [12/31]

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, <>: 2014

