

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
 March 14, 2014
 Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area													
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Date of Sampling	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014	Mar 12, 2014					
Time of sampling	9:16 AM	9:10 AM	9:04 AM	8:58 AM	8:53 AM	9:35 AM	8:40 AM	8:46 AM	9:20 AM					
Gross β	9,400	19	ND(17)	ND(17)	ND(17)	18	26	17	570					
H-3 (Approx. 12 years)	45,000	290	3,700	2,000	1,300	150	290	840	12,000					

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]	32 <3/5>
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	3,800 <3/13>	2,600 <2/18>	3,100 [11/10,11/13]	350 [12/18] <1/1>	1,100<2/19>
	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Gross β	17 [10/3]	8,300 <2/28>	31 <2/27>	110<2/5>	37 <1/23>	16,000 [11/28]	24 <1/31>
H-3 (Approx. 12 years)	2,300 [11/13]	51,000 [11/25]	54,000 <1/21>	1,000<2/12>	2,900 <2/12>	190,000 [11/30]	770 <2/25>

Unit: Bq/L, sampling date is provided in parentheses.
 []: 2013, < >: 2014

