

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
June 16, 2014
Tokyo Electric Power Company

Unit: Bq/L

| | Groundwater around H4 area | | | | | | | | | | | | | |
|------------------------|----------------------------|--------------|--------------|--------------|--------------|-----|-----|-----|-----|--------------|------|------|------------|-----|
| | E-1 | E-2 | E-3 | E-4 | E-5 | E-6 | E-7 | E-8 | E-9 | E-10 | E-11 | E-12 | Well point | F-1 |
| Date of Sampling | Jun 14, 2014 | Jun 14, 2014 | Jun 14, 2014 | Jun 14, 2014 | Jun 14, 2014 | / | / | / | / | Jun 14, 2014 | / | / | / | / |
| Time of sampling | 9:20 AM | 9:15 AM | 9:00 AM | 8:55 AM | 8:47 AM | / | / | / | / | 9:10 AM | / | / | / | / |
| Gross β | 77,000 | 47 | 37 | 40 | 31 | / | / | / | / | ND(19) | / | / | / | / |
| H-3 (Approx. 12 years) | 6,900 | 270 | 990 | 1,000 | 490 | / | / | / | / | 130 | / | / | / | / |

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

| | | | | | | | |
|------------------------|-----------------|------------------|---------------|------------------|---------------------|-------------------|--------------|
| | E-1 | E-2 | E-3 | E-4 | E-5 | E-6 | E-7 |
| Gross β | 710,000 [11/10] | 650 [9/4] | 570 [9/18] | 1,300 [9/15] | 100 [9/24] | 46 [9/20] | 50 <5/21> |
| H-3 (Approx. 12 years) | 790,000 [10/17] | 530 [10/5] <1/3> | 7,700 <4/28> | 2,600 <2/18,3/1> | 3,100 [11/10,11/13] | 350 [12/18] <1/1> | 1,100 <2/19> |
| | E-8 | E-9 | E-10 | E-11 | E-12 | Well point | F-1 |
| Gross β | 26 <6/11> | 8,300 <2/28> | 160 <4/8> | 110 <2/5> | 37 <1/23> | 16,000 [11/28] | 28 <4/25> |
| H-3 (Approx. 12 years) | 2,300 [11/13] | 51,000 [11/25] | 54,000 <1/21> | 1,000 <2/12> | 2,900 <2/12> | 190,000 [11/30] | 770 <2/25> |

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, <>: 2014

