

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
September 7, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area															
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12	E-13	E-14	Well point	F-1
Date of Sampling	Sep 5, 2014	Sep 5, 2014	Sep 5, 2014	Sep 5, 2014	Sep 5, 2014	/	/	/	Sep 5, 2014	/	/	/	/	/	/	Sep 5, 2014
Time of sampling	8:55 AM	8:50 AM	8:38 AM	8:32 AM	8:27 AM	/	/	/	9:00 AM	/	/	/	/	/	/	8:46 AM
Gross β	13,000	ND(18)	ND(18)	ND(18)	29	/	/	/	690	/	/	/	/	/	/	18
H-3 (Approx. 12 years)	4,500	210	830	440	410	/	/	/	190	/	/	/	/	/	/	250

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]	60 <8/13>	26 <6/11>
H-3 (Approx. 12 years)	790,000[10/17]	530 [10/5] <1/3>	7,700<4/28>	2,600<2/18,3/1>	3,100 [11/10,11/13]	350 [12/18] <1/1>	1,100 <2/19>	2,300 [11/13]

	E-9	E-10	E-11	E-12	E-13	E-14	Well point	F-1
Gross β	8,300 <2/28>	160 <4/8>	110 <2/5>	37 <1/23>	ND	40 <8/20>	16,000[11/28]	36 <8/19>
H-3 (Approx. 12 years)	51,000[11/25]	54,000<1/21>	1,000 <2/12>	2,900 <2/12>	530 <8/20>	640 <8/26>	190,000 [11/30]	770 <2/25>

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, < >: 2014

