

# Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>  
September 18, 2014  
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area															
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12	E-13	E-14	Well point	F-1
Date of Sampling	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014	Sep 16, 2014		Sep 16, 2014			Sep 16, 2014	Sep 16, 2014		9月16日
Time of sampling	10:01 AM	9:52 AM	9:40 AM	9:35 AM	9:32 AM	10:10 AM	9:24 AM	9:15 AM		9:45 AM			10:20 AM	9:10 AM		9:56
Gross β	13,000	22	ND(18)	22	ND(18)	18	19	25		35			ND(18)	25		21
H-3 (Approx. 12 years)	4,100	230	670	420	310	ND(110)	ND(110)	ND(110)		19,000			140	320		290

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	63 <9/9>	60 <8/13>	26 <6/11>
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	7,700 <4/28>	2,600 <2/18,3/1>	3,100 [11/10,11/13]	350 [12/18] <1/1>	1,100 <2/19>	2,300 [11/13]

  

	E-9	E-10	E-11	E-12	E-13	E-14	Well point	F-1
Gross β	8,300 <2/28>	160 <4/8>	110 <2/5>	37 <1/23>	ND	40 <8/20>	16,000 [11/28]	36 <8/19>
H-3 (Approx. 12 years)	51,000 [11/25]	54,000 <1/21>	1,000 <2/12>	2,900 <2/12>	530 <8/20>	640 <8/26>	190,000 [11/30]	770 <2/25>

Unit: Bq/L, sampling date is provided in parentheses.  
[ ]: 2013, < >: 2014

