

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H6 Area in Fukushima Daiichi Nuclear Power Station (Around the H6 Area)


Tokyo Electric Power Company

<Reference>
March 28, 2014

Unit: Bq/L

	Groundwater around H6 area		
	G-1	G-2	G-3
Date of Sampling	/	Mar 26, 2014	Mar 26, 2014
Time of sampling	/	8:37 AM	8:42 AM
Gross β	/	ND(18)	ND(18)
H-3 (Approx. 12 years)	/	4,900	ND(110)

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	G-1	G-2	G-3
Gross β	/	240 <3/20>	35 <3/17>
H-3 (Approx. 12 years)	/	7,000 <3/24,3/25>	150 <3/19>

* The sampling date is provided in parentheses.