

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of November 10 and 11, 2014 )**

	Underground bypass investigation holes			Sea side observation holes								
	a	b	c	①	②	③	④	⑤	⑥	⑦	⑧	
	Nov 11, 2014							Nov 10, 2014				
Sampled time		8:42 AM	8:23 AM	9:31 AM	9:47 AM	7:59 AM	9:03 AM	8:39 AM	8:21 AM	8:56 AM	8:03 AM	
Chloride concentration (ppm)		9	12	6	6	7	12	7	8	14	13	
All $\beta$ (Bq/cm <sup>3</sup> )		<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	
Tritium (Bq/cm <sup>3</sup> )		9.1E-2	<8.0E-3	3.1E-2	4.1E-2	2.4E-1	9.9E-1	3.0E-2	1.1E-1	3.7E-2	1.6E-1	

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced November 12

(Note 2) 0.0E±0 is the same as 0.0 x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.