

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Desalination RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (4.9E-01)	ND (6.4E-01)	Treated water tank	Jul 1, 2014	3:30 PM
Cs-137	ND (6.8E-01)	1.1E+00			
Gross β	1.0E+00	2.8E+00			
Tritium	ND (1.2E+02)	ND (1.1E+02)	Receiving tank	Jun 26, 2014	3:00 PM
Notification density rate*	0.051	0.12			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.