

<Reference>

June 1, 2014

Tokyo Electric Power Company

Sampling Results of Sub-drain Water Regarding Wrong Transfer of Accumulated Water to the Incineration Workshop Building

	East side of the Incineration Workshop Building	
Date of sampling	May 31, 2014	Jun 1, 2014
Time of sampling	7:47 AM	7:40 AM
Gross β (Bq/cm ³)	ND(0.015)	0.034
Tritium (Bq/cm ³)	ND(0.12)	Under analysis

Half-life of tritium: Approx 12 years

* Data announced this time is provided in a thick-frame. The other data was announced on May 31.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

