				Unit: Bq/L
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)
Date of Sampling	May 5, 2014	May 5, 2014		
Time of sampling	7:55 AM	7:50 AM		
Cs-134(Approx. 2 years)	ND(1.1)	ND(16)		
Cs-137(Approx.30 years)	ND(1.2)	ND(23)		
Gross β	ND(17)	ND(13)		

		Unit: Bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Date of Sampling	May 5, 2014	May 5, 2014
Time of sampling	8:05 AM	8:06 AM
Cs-134(Approx. 2 years)	ND(19)	ND(18)
Cs-137(Approx.30 years)	ND(26)	ND(27)
Gross β	68	69

Note 2: Water inflow location of drainage channel to the tank area

<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35	Point near the main gate in the drainage channel C Note 2 (C-0)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>
Gross β	ND	2,500 [10/24]	120 <2/15>

Linit: Ba/L

			Unit: Bq/L
	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]	260 [11/10]
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]	530 [11/10]
Gross β	380 [9/2]	15,000 [10/2]	15,000 [10/14]

^{*} Sampling date is provided in parentheses. []: 2013, <>: 2014



B south area

X-1
Point immediately short of the junction with the drainage channel C

X-2

Side ditch next to the tank

* There is no outflow from the sampling point X-1 and X-2 to the drainage channel C, since they are completely isolated from the drainage channel C.

* The ducting is provided in the dot line.

B-0-1 Point near Fureai Intersection in the drainage channel B

H4 north area

Tank area

Drainage channel B

C-0
Point near the main gate in the drainage channel C

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.