

Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm<sup>3</sup>)

Sampling Location	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4	Sep 5	Sep 6	Sep 7	Sep 8				
①	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
⑤	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND				
⑦	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑧	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				

Cs-134(Bq/cm<sup>3</sup>)

Sampling Location	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4	Sep 5	Sep 6	Sep 7	Sep 8				
①	ND	ND	ND	0.014	ND	0.016	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02				
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
⑤	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND				
⑦	0.023	0.021	0.033	0.031	0.038	0.03	0.018	0.029	0.029	0.039	0.028	0.029	0.024	0.019	0.052	0.052				
⑧	ND	ND	ND	ND	ND	0.015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				

Cs-137(Bq/cm<sup>3</sup>)

Sampling Location	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4	Sep 5	Sep 6	Sep 7	Sep 8				
①	ND	ND	ND	0.034	0.022	0.047	ND	ND	ND	0.028	ND	ND	ND	0.038	ND	0.066				
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
⑤	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND				
⑦	0.077	0.05	0.081	0.13	0.14	0.11	0.055	0.072	0.067	0.093	0.083	0.084	0.077	0.092	0.12	0.13				
⑧	0.021	0.02	ND	ND	0.023	0.024	ND	ND	0.025	0.024	ND	ND	0.03	0.023	0.027	0.032				
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				

\* Hyphen "-" indicates that neither sampling nor measurement was implemented.  
 \* ⑥ was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at ④.  
 \* Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.  
 \* Sampling at ⑧ since May 30, 2011  
 \* Sampling at ⑨ has been done since August 2, 2011  
 \* "ND" indicates that the measurement result is below the detection limit.  
 I-131: Approx. 0.01Bq/cm<sup>3</sup>, Cs-134: Approx.0.01Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup>  
 (September 8, 2014) As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

- <Place of Sampling>  
 ① Southeast of Unit 4 Turbine Building  
 ② Northeast of the Process Main Building  
 ③ Southeast of the Process Main Building  
 ④ Southwest of the Process Main Building  
 ⑤ South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building  
 ⑥ Southwest Part of the On-site Bunker Building  
 ⑦ West Side of the Incineration Workshop Building  
 ⑧ North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building  
 ⑨ Southeast Part of the On-site Bunker Building