## Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

## I-131(Ba/cm^3)

	To Gaptin O																		
Sampling	Dec 07 Dec 08 Dec 09 Dec 10 Dec 11 Dec 12 Dec 13 Dec 14 Dec 15 Dec 16 Dec 17 Dec 18 Dec 19 Dec 20 Dec 21																		
Location	Dec 07	Dec 08	Dec 09	Dec 10	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21				
1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-				
7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				

## Cs-134(Bq/cm^3)

Sampling																		
1	Dec 07	Dec 08	Dec 09	Dec 10	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21			
1	ND	*1	ND	ND	ND													
2	ND	*1	ND	ND	ND													
3	ND	*1	ND	ND	ND													
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND	*1	ND	ND	ND													
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
7	ND	0.027	0.011	0.027	0.024	0.026	0.021	0.034	0.02	0.03	0.014	*1	0.025	0.024	0.013			
8	ND	0.012	0.015	ND	0.01	ND	ND	ND	ND	ND	0.016	*1	ND	ND	ND			
9	ND	*1	ND	ND	ND													

## Cs-137(Bq/cm^3)

Sampling																		
Location	Dec 07	Dec 08	Dec 09	Dec 10	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21			
1	ND	*1	ND	ND	ND													
2	ND	*1	ND	ND	ND													
3	ND	*1	ND	ND	ND													
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	ND	*1	ND	ND	ND													
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
7	0.037	0.045	0.04	0.09	0.086	0.072	0.058	0.081	0.097	0.086	0.067	*1	0.086	0.076	0.034			
8	0.022	0.049	0.03	0.023	0.031	0.024	0.035	0.025	0.022	ND	0.023	*1	0.034	0.03	0.031			
9	ND	*1	ND	ND	ND													

- \* Hyphen "-" indicates that neither sampling nor measurement was implemented.
- \* ⑥ was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- \* Sampling at ① (located in the downstream of the groundwater) has been done since May 26, 2011.
- \* Samping at ® since May 30, 2011
- \* Sampling at 9 has been done since August 2, 2011
- \* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.008Bq/cm<sup>3</sup>, Cs-134: Approx.0.01Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (December 21, 2014)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

- <Place of Sampling>

  Southeast of Unit 4 Turbine Building
  Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- 4 Southwest of the Process Main Building
- ⑤ South Part of the Miscellaneous Solid Waste Volume Reduction Treatment
- © Southwest Part of the On-site Bunker Building

  West Side of the Incineration Workshop Building
- ® North Part of the Miscellaneous Solid Waste Volume Reduction Treatment
- 9 Southeast Part of the On-site Bunker Building