

Results of Water Level Measurement at Sub-drain Pits around Central Radioactive Waste Treatment Facility
(Sep. 1 - Sep. 30, 2013)

(Unit: mm)

Number	No.112 (Northeast of Process Main Building)		No.125 (West of Incineration Workshop Building)		No.133 (West of On- site Bunker Building)		No.150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building)	
	Date- Month	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)
1-Sep	7,600	2,400	7,930	2,070	7,620	2,380	9,950	50	9,980	20	9,960	40	9,960	40
2-Sep	7,600	2,400	7,910	2,090	7,640	2,360	9,950	50	9,980	20	9,960	40	9,960	40
3-Sep	7,600	2,400	7,910	2,090	7,630	2,370	9,950	50	9,980	20	9,950	50	9,970	30
4-Sep	7,600	2,400	7,920	2,080	7,630	2,370	9,950	50	9,980	20	9,960	40	9,970	30
5-Sep	7,150	2,850	7,860	2,140	7,190	2,810	9,950	50	9,970	30	9,950	50	9,960	40
6-Sep	7,150	2,850	7,800	2,200	7,170	2,830	9,950	50	9,950	50	9,930	70	9,940	60
7-Sep	7,150	2,850	7,780	2,220	7,200	2,800	9,950	50	9,940	60	9,920	80	9,930	70
8-Sep	7,200	2,800	7,780	2,220	7,210	2,790	9,950	50	9,960	40	9,940	60	9,930	70
9-Sep	7,200	2,800	7,780	2,220	7,300	2,700	9,950	50	9,960	40	9,940	60	9,930	70
10-Sep	7,250	2,750	7,770	2,230	7,230	2,770	9,900	100	9,950	50	9,930	70	9,930	70
11-Sep	7,250	2,750	7,770	2,230	7,280	2,720	9,900	100	9,940	60	9,920	80	9,930	70
12-Sep	7,300	2,700	7,770	2,230	7,270	2,730	9,900	100	9,940	60	9,920	80	9,920	80
13-Sep	7,300	2,700	7,780	2,220	7,340	2,660	9,950	50	9,990	10	9,970	30	9,980	20
14-Sep	7,350	2,650	7,810	2,190	7,340	2,660	9,950	50	9,970	30	9,950	50	9,950	50
15-Sep	7,350	2,650	7,820	2,180	7,360	2,640	9,950	50	9,970	30	9,950	50	9,960	40
16-Sep	7,600	2,400	8,560	1,440	7,590	2,410	10,050	50	10,050	50	10,030	30	10,040	40
17-Sep	7,650	2,350	8,430	1,570	7,670	2,330	10,000	0	10,000	0	9,990	10	9,980	20
18-Sep	7,650	2,350	8,240	1,760	7,670	2,330	9,950	50	9,990	10	9,970	30	9,980	20
19-Sep	7,650	2,350	8,210	1,790	7,670	2,330	9,950	50	9,990	10	9,970	30	9,980	20
20-Sep	7,100	2,900	8,140	1,860	7,130	2,870	9,950	50	9,960	40	9,940	60	9,960	40
21-Sep	7,000	3,000	8,030	1,970	7,120	2,880	9,950	50	9,940	60	9,930	70	9,960	40
22-Sep	7,100	2,900	7,880	2,120	7,090	2,910	9,950	50	9,940	60	9,920	80	9,930	70
23-Sep	7,050	2,950	7,730	2,270	7,080	2,920	9,900	100	9,920	80	9,900	100	9,910	90
24-Sep	7,050	2,950	7,710	2,290	7,070	2,930	9,900	100	9,930	70	9,910	90	9,910	90
25-Sep	7,100	2,900	7,710	2,290	7,130	2,870	9,900	100	9,940	60	9,920	80	9,920	80
26-Sep	7,150	2,850	7,790	2,210	7,170	2,830	10,000	0	10,010	10	9,990	10	9,980	20
27-Sep	7,150	2,850	7,890	2,110	7,160	2,840	9,950	50	9,970	30	9,950	50	9,970	30
28-Sep	7,150	2,850	7,790	2,210	7,140	2,860	9,900	100	9,940	60	9,920	80	9,940	60
29-Sep	7,150	2,850	7,750	2,250	7,150	2,850	9,900	100	9,930	70	9,910	90	9,910	90
30-Sep	7,200	2,800	7,730	2,270	7,170	2,830	9,900	100	9,930	70	9,910	90	9,910	90

Note: GL (Ground level) of Central Radioactive Waste Treatment Facility is OP+10m.