Reference February 15, 2017 Tokyo Electric Power Company Holdings, Inc.


## <u>Unit 2 Primary Containment Vessel Investigation</u> <u>at Fukushima Daiichi Nuclear Power Station</u> (By the self-propelled investigation device)

## IRID TEPCO

## Tokyo Electric Power Company Holdings, Inc.


## 1. Current conditions of Unit 2 Primary Containment Vessel (PCV)

- Nuclear fuel in the Primary Containment vessel (PCV) was exposed to the air and melted from the impact of March 2011 Great Earthquake.
- As a result of the accident analysis, it was found that a portion of melted nuclear fuel might have been fallen inside the pedestal.
- To remove fuel debris, it is necessary to investigate the PCV and clarify the conditions of debris and surrounding structures.
  X-6 penetration



### 2. Outline of Unit 2 PCV investigation


- [Purpose]: ① To obtain feedback information (deformation of platform, etc.) for the design and development of next investigation devices inside the pedestal
- 2 To inspect conditions on the platform inside pedestal, fuel debris fallen to the CRD housing, and conditions of structures inside pedestal.
- [Investigation point]: Platform and Control Rod Drive (CRD) will be investigated from the platform inside pedestal



Investigation area inside the pedestal


### 3. Work steps for Unit 2 PCV investigation





Images provided from International Research Institute for Nuclear Decommissioning (IRID)


## 4. Preparatory investigation results from X-6 penetration to CRD rai



- The deposits on the CRD rail was the mixture of black paste and thin pieces of or gravel-sized materials.
- The deposits on the upper part of the CRD rail was soft but it adhered more to the lower part of the rail.
- The deposit removal device could get on the deposits but could not run on them for some parts.


# 4. Preparatory investigation results at the entrance of pedestal area $T \equiv PCO$

#### Plan view of PCV




#### 4. Preparatory investigation results of pedestal area





Digital image of Unit 2 pedestal area obtained from preparatory investigations

## 5. Additional results expected from the self-propelled investigation device



Digital images <sup>*1</sup>	<ul> <li>Halation will not be likely to occur because cameras and lighting are far away from each other.</li> <li>The space can be recognized with two cameras of both front and back.</li> <li>Radiation levels can be estimated from noise images on the camera screens (marginal error of ±30%).</li> </ul>
Temperature	Temperatures are measured by thermocouple.
Radiation levels	<ul> <li>Radiation levels are measured with an integrating dosimeter, not the estimation from noise images (marginal error of ±20%)</li> <li>The dosimeter may be affected by the deposits because it is attached to the connection cable (or touches the floor surface). There is a possibility that the measurement data does not indicate ambient radiation.</li> </ul>

<sup>\*1</sup> If the device can reach to the end of CRD rail, it can view the inside of the pedestal from different angles and find the conditions of interior structures and deposits.

### 6. Investigation by the self-propelled investigation device to the end of CRD




Image provided from International Research Institute for Nuclear Decommissioning (IRID)

### 6. Investigation by the self-propelled investigation device to the end of CRD rail

To the center of RPV	Investigation area	Investigation items	Information expected to be obtained
Platform Lifting balance	<ul> <li>On CRD rail</li> <li>Entrance to the pedestal area</li> <li>Inside of the pedestal</li> </ul>	Visual observation	<ul> <li>Information can be obtained of the vicinity of the metal grating fallen in.</li> <li>Damage on the bottom of the reactor</li> <li>Damage on the upper part of the interior structures such as CRD housing</li> <li>Deposits adhered to the structures</li> <li>Damage on the metal grating</li> </ul>
		Temperature measurement	Temperatures can be measured up to the vicinity of the pedestal.
Area where the deposits still exist		Radiation measurement	Radiation levels can be measured up to the vicinity of the pedestal. *The dosimeter may be affected by the deposits because it is attached to the connection cable (or touches the floor surface). There is a possibility that the measurement data does not indicate ambient radiation.
CRD rail Point where the		■ Access of the device (very difficult)	
device is inserted	<ul> <li>Access of the device (very difficult)</li> <li>The device needs to go over the gap between the CRD rail and platform. It may fall in the gap or may not be able to go further.</li> </ul>		
X-6 penetration		• The device needs to access the platform only with the images from its own front and back cameras, not with visual observation from the overview camera.	
			e falls in the gap, it may not be retrieved. It may ith the connection cable being pulled back.
PAN	090 ALLT -039		may be left inside the PCV if it takes too much ieve it with priority on the investigation.

## Reference: Investigation results on the platform inside the pedestal $T \equiv PCO$

