

Measurement Results of Sub-Drain Pit Water Level at Main Building of Unit 1 ~ 6

(Unit : mm)

Unit	Number	Date of Sampling		Date of Sampling		Date of Sampling		Date of Sampling		Date of Sampling	
		June 3		June 10		June 17		June 24		June 29	
		Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +
Unit 1	No . 1	6,080	3,920	5,790	4,210	5,920	4,080	5,680	4,320	5,420	4,580
Unit 2	No . 2 7	5,850	4,150	5,950	4,050	5,970	4,030	6,170	3,830	5,790	4,210
Unit 3	No . 3 2	6,100	3,900	6,330	3,670	6,450	3,550	6,470	3,530	6,040	3,960
Unit 4	No . 5 6	6,100	3,900	6,070	3,930	6,030	3,970	5,930	4,070	5,840	4,160
Unit 5	No . 7 1	7,760	5,240	7,840	5,160	8,010	4,990	8,120	4,880	7,810	5,190
Unit 6	No . 9 5	6,990	6,010	7,090	5,910	7,330	5,670	7,500	5,500	7,410	5,590

Note 1) GL(ground level) of Unit 1 ~ 4 is OP + 10 m.

2) GL(ground level) of Unit 5 and 6 is OP + 13 m.

Measurement Results of Sub-Drain Pit Water Level at Centralized Radiation Waste Treatment Facility

Date	No112 (Northeast of Process Main Building)		No125 (West of Incineration Workshop Building)		No133 (West of On-Site Bunker Building)		No150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building)	
	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +	Depth from GL	OP +
2011/6/1	3,500	6,500	2,860	7,140	3,410	6,590	640	9,360	550	9,450	610	9,390	650	9,350
2011/6/2	3,500	6,500	2,940	7,060	3,420	6,580	680	9,320	580	9,420	640	9,360	590	9,410
2011/6/3	3,500	6,500	2,980	7,020	3,430	6,570	680	9,320	600	9,400	660	9,340	610	9,390
2011/6/4	3,500	6,500	3,020	6,980	3,510	6,490	710	9,290	640	9,360	690	9,310	650	9,350
2011/6/5	3,490	6,510	3,040	6,960	3,480	6,520	710	9,290	640	9,360	690	9,310	650	9,350
2011/6/6	3,480	6,520	3,050	6,950	3,470	6,530	710	9,290	630	9,370	690	9,310	640	9,360
2011/6/7	3,500	6,500	3,040	6,960	3,450	6,550	730	9,270	640	9,360	690	9,310	640	9,360
2011/6/8	3,500	6,500	3,030	6,970	3,420	6,580	720	9,280	630	9,370	690	9,310	640	9,360
2011/6/9	3,500	6,500	3,030	6,970	3,400	6,600	720	9,280	630	9,370	680	9,320	630	9,370
2011/6/10	3,500	6,500	3,010	6,990	3,350	6,650	700	9,300	620	9,380	670	9,330	620	9,380
2011/6/11	3,480	6,520	2,970	7,030	3,330	6,670	700	9,300	590	9,410	640	9,360	590	9,410
2011/6/12	3,480	6,520	2,990	7,010	3,360	6,640	680	9,320	600	9,400	650	9,350	600	9,400
2011/6/13	3,480	6,520	2,970	7,030	3,340	6,660	680	9,320	580	9,420	630	9,370	590	9,410
2011/6/14	3,470	6,530	2,960	7,040	3,340	6,660	680	9,320	600	9,400	650	9,350	600	9,400
2011/6/15	3,460	6,540	2,980	7,020	3,340	6,660	690	9,310	610	9,390	660	9,340	610	9,390
2011/6/16	3,460	6,540	2,980	7,020	3,330	6,670	690	9,310	610	9,390	670	9,330	610	9,390
2011/6/17	3,450	6,550	2,960	7,040	3,310	6,690	680	9,320	590	9,410	640	9,360	590	9,410
2011/6/18	3,400	6,600	2,950	7,050	3,280	6,720	660	9,340	570	9,430	630	9,370	580	9,420
2011/6/19	3,400	6,600	2,960	7,040	3,320	6,680	680	9,320	600	9,400	650	9,350	610	9,390
2011/6/20	3,410	6,590	2,950	7,050	3,300	6,700	680	9,320	590	9,410	650	9,350	600	9,400
2011/6/21	3,400	6,600	2,940	7,060	3,280	6,720	680	9,320	570	9,430	630	9,370	580	9,420
2011/6/22	3,350	6,650	2,790	7,210	3,200	6,800	540	9,460	460	9,540	520	9,480	470	9,530
2011/6/23	3,340	6,660	2,790	7,210	3,210	6,790	570	9,430	470	9,530	530	9,470	480	9,520
2011/6/24	3,340	6,660	2,800	7,200	3,210	6,790	560	9,440	480	9,520	530	9,470	480	9,520
2011/6/25	3,280	6,720	2,830	7,170	3,220	6,780	560	9,440	460	9,540	520	9,480	470	9,530
2011/6/26	3,260	6,740	2,760	7,240	3,200	6,800	540	9,460	450	9,550	510	9,490	450	9,550
2011/6/27	3,190	6,810	2,290	7,710	3,030	6,970	380	9,620	270	9,730	330	9,670	270	9,730
2011/6/28	3,140	6,860	2,310	7,690	2,980	7,020	370	9,630	250	9,750	310	9,690	250	9,750
2011/6/29	3,230	6,770	2,450	7,550	2,970	7,030	380	9,620	290	9,710	350	9,650	290	9,710
2011/6/30	3,100	6,900	2,520	7,480	2,960	7,040	420	9,580	310	9,690	370	9,630	310	9,690

Note · GL(ground level) of the Centralized Radiation Waste Treatment Facility is OP + 10 m.

Layout Drawing of Unit 1 ~ 6 of Fukushima Daiichi Nuclear Power Station and Sub-Drain of Centralized Radiation Waste Treatment Facility

