

# Fukushima Daiichi Nuclear Power Station

## Analysis Results of Spent Fuel Pool Water in Unit 1 to 4

August 25, 2011  
Tokyo Electric Power Company

Reference

### Analysis Results of Spent Fuel Pool Water (Sampling in August)

Unit	Sampling Date	pH	Cl (Chloride Ion)	Cs-137	Cs-134	I-131
		-	ppm	Bq/L	Bq/L	Bq/L
Unit 1	11:35 August 19	8.2	3.9	2.3E+07	1.8E+07	ND
Unit 2	11:10 August 19	7.5	1508	1.1E+08	1.1E+08	ND
Unit 3	14:00 August 19	9.2	1769	8.7E+07	7.4E+07	ND
Unit 4	11:40 August 20	7.7	1944	6.1E+04	4.4E+04	ND