

September 3, 2011
Tokyo Electric Power Company

Sampling Result of Water of the Spent Fuel Pool and Liner Drain Water
of the Fukushima Daiichi Nuclear Power Plant Unit 4

Sample	Sampling date/time	Cl (Chloride ion)	Hydrazine	Cesium 137	Cesium 134	Iodine 131
		ppm	ppm	Bq/L	Bq/L	Bq/L
	9/2 15:00	997	59	3.1×10^4	2.2×10^4	N D
	9/2 15:05	389	N D	1.0×10^4	8.0×10^3	N D

Sample : Water of the Spent Fuel Pool

Sample : Liner Drain Water of the Spent Fuel Pool