

November 8, 2011

Tokyo Electric Power Company

Fukushima Daiichi Nuclear Power Station Analysis Results of Spent Fuel Pool Water in Unit 1 to 4

Analysis Results of Spent Fuel Pool Water (Sampling on Nov. 5, 2011)

Unit	Sampling Data	pH	Cl (Chloride Ion)	I-131	Cs-134	Cs-137
		-	ppm	Bq/L	Bq/L	Bq/L
Unit 1	Nov.5 14:25	8.1	3	ND	1.3E+07	1.8E+07
Unit 2	Nov.5 11:50	9.2	1,600	ND	9.5E+07	1.1E+08
Unit 3	Nov.5 14:05	9.8	1,800	ND	6.0E+07	7.4E+07
Unit 4	Nov.5 10:10	10.1	150	ND	3.5E+03	5.1E+03

<Reference> Analysis Results of Spent Fuel Pool Water (Sampling on Aug. 19 and 20, 2011)

Unit	Sampling Data	pH	Cl (Chloride Ion)	I-131	Cs-134	Cs-137
		-	ppm	Bq/L	Bq/L	Bq/L
Unit 1	Aug.19 11:35	8.2	3.9	ND	1.8E+07	2.3E+07
Unit 2	Aug.19 11:10	7.5	1,508	ND	1.1E+08	1.1E+08
Unit 3	Aug.19 14:00	9.2	1,769	ND	7.4E+07	8.7E+07
Unit 4	Aug.20 11:40	7.7	1,944	ND	4.4E+04	6.1E+04