

**Results of Gas Sampling Conducted at  
the Entrance of Gas Control System, PCV, Unit 2**

February 2, 2012

【Sampling Point】 Entrance of Gas Control System, PCV, Unit 2

Tokyo Electric Power Company

【Sampling Time & Date】 10:44 am on Wed. February 1, 2012

【Results】

Nuclides		Radioactivity Concentration ( Bq/cm <sup>3</sup> )	Detection Limit ( Bq/cm <sup>3</sup> )	Half Life
Gas Vial	I-131	Below the detection limit	$1.3 \times 10^{-1}$	Approx. 8 days
	Cs-134	$3.5 \times 10^{-1}$	$3.2 \times 10^{-1}$	Approx. 2 years
	Cs-137	$7.4 \times 10^{-1}$	$3.8 \times 10^{-1}$	Approx. 30 years
	Kr-85	Below the detection limit	$2.5 \times 10^1$	Approx. 11 years
	Xe-131m	Below the detection limit	$3.0 \times 10^0$	Approx. 12 days
	Xe-133	Below the detection limit	$2.5 \times 10^{-1}$	Approx. 5 days
	Xe-135	Below the detection limit	$9.5 \times 10^{-2}$	Approx. 9 hours

The results for Xe with a short half life were all below the detection limit.  
Below the re-criticality criteria for Xe-135, 1Bq/cm<sup>3</sup>.

---

【Note】 As for the sub-critical state of Unit 1, we confirmed that the radioactive concentration of Xe-135 in the exhaust gas, measured by a detection device installed in the Gas Control System, was below the re-criticality criteria, 1Bq/cm<sup>3</sup>. (Results for Xe-133 on February 1 :  $(1.7 \sim 2.7) \times 10^{-3} \text{Bq / cm}^3$ )