

February 12, 2012

Tokyo Electric power Company

## Fukushima Daiichi NPS Unit 2

The temperature of the lower part of the reactor pressure vessel (upper part of the bottom head)  
(Reference)

mounting angle	0 °	135 °	270 °	mounting angle	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3
2/1 1:00	50.7	44.5	43.9	2/4 10:00	66.5	45.1	45.2
2/1 4:00	51.1	44.7	44.0	2/4 11:00	66.3	45.2	45.1
2/1 7:00	50.9	44.4	43.9	2/4 12:00	64.1	45.4	45.1
2/1 10:00	52.9	44.5	43.9	2/4 13:00	65.2	45.4	45.1
2/1 11:00	50.2	44.6	44.0	2/4 14:00	65.2	45.5	45.2
2/1 12:00	51.0	44.4	43.9	2/4 15:00	66.6	45.3	45.2
2/1 13:00	51.3	44.4	43.9	2/4 16:00	67.2	45.5	45.2
2/1 14:00	51.3	44.4	43.9	2/4 17:00	64.8	45.7	45.2
2/1 15:00	52.8	44.1	43.9	2/4 18:00	64.8	45.6	45.2
2/1 16:00	51.9	44.5	43.9	2/4 19:00	65.2	45.6	45.3
2/1 17:00	50.3	44.4	43.9	2/4 20:00	65.6	45.6	45.2
2/1 18:00	51.4	44.4	43.9	2/4 21:00	65.4	45.6	45.2
2/1 19:00	51.7	44.5	44.0	2/4 22:00	65.8	45.7	45.3
2/1 22:00	52.3	44.7	44.0	2/4 23:00	66.2	45.6	45.3
2/2 1:00	52.2	44.5	44.0	2/5 0:00	67.8	45.4	45.2
2/2 4:00	53.4	44.6	43.9	2/5 1:00	69.2	45.7	45.3
2/2 7:00	51.7	44.6	44.1	2/5 2:00	66.4	45.9	45.3
2/2 10:00	55.0	44.6	44.1	2/5 3:00	66.3	45.7	45.3
2/2 11:00	52.6	44.8	44.1	2/5 4:00	67.1	45.6	45.3
2/2 12:00	52.2	44.7	44.2	2/5 5:00	67.4	45.6	45.2
2/2 13:00	54.0	44.5	44.2	2/5 6:00	67.7	45.3	45.2
2/2 14:00	54.4	44.4	44.2	2/5 7:00	70.4	45.5	45.2
2/2 15:00	55.7	44.3	44.2	2/5 8:00	68.2	45.7	45.2
2/2 16:00	56.4	44.6	44.2	2/5 9:00	67.4	45.5	45.1
2/2 19:00	56.8	44.8	44.3	2/5 10:00	68.8	45.4	45.1
2/2 22:00	55.3	44.7	44.3	2/5 11:00	69.0	45.6	45.0
2/3 1:00	55.3	44.7	44.3	2/5 12:00	67.7	45.3	45.0
2/3 4:00	56.9	44.7	44.4	2/5 13:00	68.7	45.3	45.0
2/3 7:00	59.5	44.6	44.4	2/5 14:00	68.9	45.2	44.9
2/3 10:00	58.6	45.0	44.4	2/5 15:00	70.4	45.0	44.8
2/3 11:00	58.2	44.8	44.5	2/5 16:00	71.7	45.3	44.8
2/3 12:00	61.5	44.6	44.6	2/5 17:00	69.1	45.3	44.8
2/3 13:00	62.7	44.5	44.5	2/5 18:00	68.3	45.1	44.7
2/3 14:00	61.2	44.7	44.5	2/5 19:00	69.8	45.0	44.7
2/3 15:00	60.9	44.8	44.5	2/5 20:00	70.1	45.0	44.7
2/3 16:00	63.5	44.8	44.5	2/5 21:00	71.0	44.8	44.6
2/3 17:00	61.3	45.0	44.6	2/5 22:00	72.6	45.0	44.6
2/3 18:00	60.9	44.9	44.6	2/5 23:00	70.6	45.0	44.6
2/3 19:00	62.9	44.6	44.6	2/6 0:00	70.0	44.9	44.5
2/3 20:00	61.7	45.0	44.6	2/6 1:00	70.6	44.8	44.5
2/3 21:00	61.2	44.9	44.7	2/6 2:00	71.1	44.8	44.5
2/3 22:00	62.1	44.9	44.7	2/6 3:00	70.3	44.6	44.4
2/3 23:00	62.5	45.0	44.8	2/6 4:00	73.1	44.8	44.4
2/4 0:00	63.2	44.8	44.8	2/6 5:00	70.6	44.7	44.3
2/4 1:00	65.2	44.9	44.9	2/6 6:00	71.0	44.4	44.2
2/4 2:00	64.1	45.3	45.0	2/6 7:00	73.3	44.6	44.2
2/4 3:00	63.2	45.2	45.0	2/6 8:00	71.2	44.7	44.1
2/4 4:00	64.1	45.3	45.0	2/6 9:00	69.6	44.4	44.1
2/4 5:00	64.6	45.3	45.0	2/6 10:00	70.5	44.3	44.0
2/4 6:00	64.7	45.2	45.1	2/6 11:00	70.6	44.1	43.9
2/4 7:00	66.8	45.1	45.1	2/6 12:00	72.0	43.9	43.8
2/4 8:00	64.7	45.3	45.1	2/6 13:00	70.7	44.1	43.8
2/4 9:00	63.7	45.3	45.1	2/6 14:00	70.7	44.0	43.7

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

mounting angle	0 °	135 °	270 °	mounting angle	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3
2/6 15:00	70.8	43.8	43.6	2/8 22:00	67.9	38.4	38.5
2/6 16:00	71.6	43.9	43.6	2/8 23:00	70.8	39.0	38.2
2/6 17:00	69.5	44.1	43.5	2/9 0:00	67.5	38.9	38.3
2/6 18:00	68.5	43.9	43.5	2/9 1:00	68.2	38.5	38.2
2/6 19:00	69.3	43.8	43.4	2/9 2:00	68.1	38.5	38.1
2/6 20:00	70.1	43.7	43.3	2/9 3:00	68.0	38.4	38.1
2/6 21:00	70.4	43.5	43.3	2/9 4:00	69.5	38.0	38.0
2/6 22:00	71.0	43.4	43.2	2/9 5:00	70.6	38.5	37.9
2/6 23:00	70.0	43.8	43.2	2/9 6:00	67.6	38.5	37.9
2/7 0:00	68.8	43.5	43.2	2/9 7:00	66.7	38.1	37.8
2/7 1:00	70.1	43.5	43.1	2/9 8:00	66.5	38.0	37.7
2/7 2:00	70.4	43.5	43.1	2/9 9:00	66.1	37.9	37.7
2/7 3:00	70.4	43.2	43.0	2/9 10:00	64.6	37.9	37.6
2/7 4:00	72.7	43.2	42.9	2/9 11:00	69.5	38.2	37.5
2/7 5:00	70.4	43.2	42.8	2/9 12:00	67.1	38.2	37.5
2/7 6:00	70.1	43.0	42.7	2/9 13:00	67.4	37.7	37.4
2/7 7:00	71.5	42.7	42.6	2/9 14:00	67.2	37.7	37.3
2/7 8:00	71.4	42.9	42.4	2/9 15:00	66.7	37.6	37.3
2/7 9:00	68.6	42.6	42.3	2/9 16:00	66.3	37.3	37.4
2/7 10:00	69.0	42.4	42.1	2/9 17:00	67.9	37.2	37.1
2/7 11:00	70.1	42.2	42.0	2/9 18:00	66.8	37.7	37.0
2/7 12:00	70.0	41.7	41.9	2/9 19:00	65.9	37.0	37.1
2/7 13:00	71.5	41.8	41.6	2/9 20:00	67.9	36.9	37.0
2/7 14:00	69.1	42.1	41.4	2/9 21:00	67.9	37.5	36.8
2/7 15:00	67.6	41.6	41.3	2/9 22:00	64.8	37.2	36.8
2/7 16:00	68.5	41.4	41.2	2/9 23:00	65.3	37.0	36.8
2/7 17:00	67.7	41.6	41.0	2/10 0:00	66.1	37.0	36.8
2/7 18:00	67.3	41.2	40.9	2/10 1:00	66.8	36.9	36.7
2/7 19:00	67.8	41.0	40.8	2/10 2:00	68.6	36.5	36.7
2/7 20:00	67.3	40.9	40.7	2/10 3:00	68.7	37.1	36.5
2/7 21:00	67.6	40.8	40.6	2/10 4:00	66.2	36.9	36.5
2/7 22:00	69.1	40.4	40.4	2/10 5:00	66.3	36.6	36.4
2/7 23:00	69.4	40.5	40.3	2/10 6:00	67.0	36.5	36.4
2/8 0:00	65.4	40.5	40.2	2/10 7:00	67.4	36.5	36.3
2/8 1:00	66.3	40.4	40.1	2/10 8:00	66.9	36.1	36.3
2/8 2:00	65.8	40.3	40.0	2/10 9:00	68.9	36.0	36.2
2/8 3:00	66.2	39.9	39.9	2/10 10:00	67.2	36.7	36.1
2/8 4:00	67.4	39.8	39.8	2/10 11:00	68.4	35.9	36.1
2/8 5:00	67.4	40.3	39.6	2/10 12:00	69.9	36.6	36.0
2/8 6:00	65.0	40.0	39.6	2/10 13:00	65.9	36.2	36.1
2/8 7:00	66.1	39.9	39.6	2/10 14:00	67.2	36.2	36.0
2/8 8:00	66.1	39.8	39.4	2/10 15:00	67.3	36.1	36.0
2/8 9:00	66.2	39.6	39.4	2/10 16:00	67.8	35.8	36.0
2/8 10:00	68.0	39.3	39.2	2/10 17:00	70.4	35.8	35.8
2/8 11:00	66.0	39.5	39.2	2/10 18:00	68.6	36.1	35.9
2/8 12:00	66.1	39.7	39.1	2/10 19:00	69.0	36.0	35.9
2/8 13:00	66.2	39.4	39.0	2/10 20:00	69.2	35.6	35.9
2/8 14:00	66.5	39.3	38.9	2/10 21:00	71.1	36.3	35.8
2/8 15:00	66.3	38.9	38.9	2/10 22:00	68.4	36.3	35.8
2/8 16:00	68.0	38.7	38.8	2/10 23:00	67.8	35.9	35.8
2/8 17:00	66.4	39.4	38.7	2/11 0:00	69.3	35.9	35.8
2/8 18:00	64.1	39.0	38.6	2/11 1:00	69.8	35.8	35.8
2/8 19:00	64.7	39.0	38.6	2/11 2:00	69.2	35.5	35.8
2/8 20:00	65.4	38.9	38.5	2/11 3:00	71.3	35.8	35.6
2/8 21:00	66.3	38.6	38.5	2/11 4:00	68.5	36.1	35.6

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

mounting angle	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3
2/11 5:00	67.4	35.7	35.6
2/11 6:00	68.3	35.6	35.6
2/11 7:00	68.8	35.6	35.6
2/11 8:00	69.2	35.2	35.6
2/11 9:00	71.3	35.3	35.4
2/11 10:00	70.8	35.9	35.4
2/11 11:00	71.2	35.1	35.4
2/11 12:00	71.2	35.9	35.4
2/11 13:00	68.7	35.5	35.4
2/11 14:00	69.4	35.4	35.4
2/11 15:00	69.6	35.4	35.3
2/11 16:00	68.6	35.5	35.4
2/11 17:00	69.5	35.0	35.4
2/11 18:00	71.2	35.3	35.3
2/11 19:00	71.1	35.3	35.3
2/11 20:00	70.9	34.9	35.3
2/11 21:00	73.3	34.9	35.2
2/11 22:00	72.5	35.6	35.2
2/11 23:00	71.2	35.2	35.2
2/12 0:00	71.1	35.2	35.2
2/12 1:00	69.5	35.3	35.2
2/12 2:00	71.9	35.2	35.2
2/12 3:00	74.1	34.8	35.1
2/12 4:00	75.7	35.4	35.0
2/12 5:00	74.0	35.4	35.0
2/12 6:00	74.4	34.9	35.0
2/12 7:00	76.3	34.8	34.9
2/12 8:00	74.5	34.8	34.9
2/12 9:00	77.1	34.4	34.9
2/12 10:00	78.3	35.0	34.7
2/12 11:00	74.9	35.1	34.7
2/12 12:00	79.1	34.9	34.6
2/12 13:00	77.6	34.9	34.6
2/12 14:00	78.5	34.5	34.6
2/12 15:00	79.2	34.4	34.6
2/12 16:00	80.1	34.3	34.5

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.