

Plant Status of Fukushima Daiichi Nuclear Power Station

February 23, 2012

Tokyo Electric Power Company

<1. Status of the Nuclear Reactor and the Primary Containment Vessel> (As of February 23 at 11:00 am)

Unit	Status of Water injection		Bottom temperature of Reactor pressure vessel	Pressure of primary containment vessel	Hydrogen density Of Primary containment vessel
Unit 1	Injecting Fresh water	Core Spray System: Approx. 1.7 m ³ /h	24.4 °C	106.6k Paabs	0.00 vol%
		Feed Water System: Approx. 4.5 m ³ /h			
Unit 2	Injecting Fresh water	Core Spray System: Approx. 6.0 m ³ /h	47.8 °C	119k Paabs	0.06 vol%
		Feed Water System: Approx. 3.0 m ³ /h			
Unit 3	Injecting Fresh water	Core Spray System: Approx. 5.2 m ³ /h	51.3 °C	101.6k Paabs	/
		Feed Water System: Approx. 1.7 m ³ /h			

[Unit 2]

- With regard to the water injection volume for Unit 2 reactor, which was increased with temperature figure raising, we have gradually adjusted it to the original volume before temperature increasing (Feed water system: approx. 3.0m³/h, core spray system: approx. 6.0m³/h) As no abnormality has been observed in the variation of the plant parameter after the change in the flow rate on February 21, at 8:17 pm on February 22, we changed the water injection volume from feed water system from approx. 4.0m³/h to approx. 3.0m³/h (The water injection level from core spray system is continuing at approx. 6.0m³/h)
- On February 22, 2012, we conducted gas sampling survey of the PCV gas control system and confirmed that Xenon 135 was below the detection limit (1.1 x 10⁻¹Bq/cm³) at the inlet of the system and also below 1 Bq/cm³ that is a threshold of recriticality.

[Unit 3]

- As installation works of the PCV gas control system was completed, at 11:38 on February 23 we started the test operation, at 2:10 pm we confirmed that an exhaust flow amount was stable at 33m³/h and started adjustment operation.

[Unit 4] [Unit 5] [Unit 6]

- No significant incidents have happened.

<2. Status of the Spent Fuel Pool> (As of February 23 at 11:00 am)

Unit	Cooling type	Status of cooling	Temperature of water in Spent Fuel Pool
Unit 1	Circulating Cooling System	Under operation *	26.5 °C
Unit 2	Circulating Cooling System	Under operation	13.3 °C
Unit 3	Circulating Cooling System	Under operation	13.5 °C
Unit 4	Circulating Cooling System	Under operation	25 °C

* System secondary air fin cooler: out of service

[Unit 2]

- Desalination equipment has been activated in order to reduce density of salt from the spent fuel pool since 11:50 am on January 19.

[Unit 3]

- Radioactive material removal equipment has been activated in order to remove radioactive materials from the spent fuel pool since 3:18 pm on January 14.

[Unit4]

- From 1:23 pm to 3:00 pm on February 23, we injected hydrazine [corrosion inhibitor] into the spent fuel pool (approx. 2 m³)

<3. Status of water transfer from the Vertical Shaft of the Trench and the basement floor of the Turbine Building>

Unit	Draining water source	Place transferred	Status
Unit 2	Unit 2 T/B	Central Radioactive Waste Treatment Facility [Miscellaneous Solid Waste Volume Reduction Treatment Building(High Temperature Incinerator Building)]	9:39 am on February 20 – 8:28 am on February 23, Transferred
	Unit 2 T/B	Central Radioactive Waste Treatment Facility [Process Main Building]	2:04 pm on February 23 – Transferring
Unit 3	Unit 3 T/B	Central Radioactive Waste Treatment Facility [Miscellaneous Solid Waste Volume Reduction Treatment Building(High Temperature Incinerator Building)]	9:30 am on February 20 – 9:52 am on February 22, Transferred

<4. Status of the Treatment Facility and the Storage Facility> (As of February 23 at 7:00 am)

Facility	Cesium adsorption apparatus	Secondary Cesium adsorption apparatus (sarry)	Decontamination instruments	water desalinations (reverse osmosis membrane)	water desalinations (evaporative concentration)
Operating status	Under operation	Under operation*	Out of service	Operating intermittently according to the water balance	Operating intermittently according to the water balance

*Cleaning of filter is implemented accordingly.

- June 8, 2011 ~ Large tanks to store contaminated and decontaminated water are transported and installed.

<5. Others>

- October 7, 2011 ~ : Continuously implementing water spray using water after purifying accumulated water of Unit 5 and Unit 6 to prevent spontaneous fire of trimmed trees and diffusion of dust.
- February 20, 2012 : At around 3:43pm, we observed that an error message was displayed in the screen of the noble gas monitoring system B of the gas management system of the primary containment vessel of Unit 2. Accordingly, the density of the noble gas in the system B was no longer observable at the Central Monitoring Station in the Main Anti-Earthquake Building. Observation was continued using the system A, one of the two systems A and B, which did not display any error message.
- February 21, 2012 : at around 5:20pm, the same error message was displayed in the screen of system A. As a result, the density of the noble gas was no longer observable at Central Monitoring Station in the Main Anti-Earthquake Building. After investigating the situation at the site, we detected a failure of the transmission system which connects the site and the Central Monitoring Station in the Main Anti-Earthquake

Building. However, there is no difficulty in confirming the subcriticality, as both the system A and B can be observed from the monitor at the site and, at the moment, the monitor screen can be remotely watched from the Central Monitoring Station in the Main Anti-Earthquake Building. The cause of the failure is now being investigated for restoration. The gas management system of the primary containment vessel of Unit 2 itself is in normal operation.

- February 22, 2012 : 10:05 As the component cooling sea water system pump (C) of Unit 6 had been restored, we started test operation.

10:07 Accordingly, the component cooling sea water system pump (A) stopped its operation.

11:25 We confirmed no problem in operation.

End