

Nuclide Analysis Results of Sub-drain Water in the Surroundings of "Centralized Radiation Waste Treatment Facility"

I-131(Bq/cm³)

Sampling point	After transfer															
	Oct 09	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19	Oct 20	Oct 21	Oct 22	Oct 23	Oct 24
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-134(Bq/cm³)

Sampling point	After transfer															
	Oct 09	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19	Oct 20	Oct 21	Oct 22	Oct 23	Oct 24
	ND	ND	ND	0.14	0.025	ND	ND	ND	ND	ND	ND	0.075	ND	0.093	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	0.028	0.026	ND	0.038	ND	0.021	ND	0.024	0.034	ND	0.047	ND	ND
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND
	0.44	0.23	0.37	0.7	0.36	0.29	0.36	0.22	0.36	0.44	0.19	0.21	0.23	0.19	0.37	0.19
	0.028	ND	0.033	ND	0.026	ND	0.025	ND	0.032	ND	0.073	0.042	ND	0.026	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-137(Bq/cm³)

Sampling point	After transfer															
	Oct 09	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19	Oct 20	Oct 21	Oct 22	Oct 23	Oct 24
	0.071	ND	0.033	0.12	ND	ND	ND	ND	0.036	0.028	ND	0.082	ND	0.12	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	0.033	ND	0.026	ND	0.032	0.038	ND	0.029	0.035	0.039	ND	0.035	0.041	ND	0.028
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND
	0.5	0.3	0.41	0.81	0.45	0.3	0.43	0.3	0.44	0.55	0.21	0.25	0.27	0.24	0.46	0.25
	0.037	ND	ND	0.03	ND	ND	ND	ND	0.024	ND	0.094	0.035	0.035	0.037	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

<Place of sampling>
 Southeast part of Unit 4 Turbine Building
 Northeast part of Process Main Building
 Southeast part of Process Main Building
 Southwest part of Process Main Building
 South part of Miscellaneous Solid Waste
 Volume Reduction Treatment Building
 Southwest part of On-site Bunker Building
 West part of Incineration Workshop Building
 North part of Miscellaneous Solid Waste
 Volume Reduction Treatment Building
 Southeast part of On-site Bunker Building

* Hyphen "-" indicates that neither sampling nor measurements were implemented.

* was conducted as upstream of the groundwater once a week from April 29 since it was unable to sample at .

* We have been sampling at since May 26, for it is located downstream of the groundwater.

* We have been sampling at since May 30.

* We have been sampling at since August 2.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.02Bq/cm³, Cs-134: approx. 0.03Bq/cm³, Cs-137: approx. 0.03Bq/cm³ (10/24)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.