

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/11 19:30											
3/11 19:37											
3/11 20:00											
3/11 20:07			6.900								
3/11 20:30											
3/11 21:00											
3/11 21:30	450										
3/11 22:00	550										
3/11 22:10	550										
3/11 22:20	590										
3/11 22:30											
3/11 22:35	590										
3/11 22:47	590										
3/11 23:05	590										
3/11 23:24	590										
3/11 23:30											
3/12 0:30	1300										
3/12 0:45	1300										
3/12 1:00	1300										
3/12 1:05					0.600						
3/12 1:25	1300										
3/12 1:40	1300										
3/12 1:55	1300	530									
3/12 2:10	1300	500									
3/12 2:30	1300	500			0.840						
3/12 2:45			0.800		0.840						
3/12 2:50		500									
3/12 3:05	1300	500									
3/12 3:30	1300										
3/12 3:55	1300	500									
3/12 4:19	1300	500			0.780	0.790					
3/12 4:35	1300	500			0.770	0.770					
3/12 4:55	1300	500									
3/12 5:20	1300	500									

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/12 5:30	1300	500									
3/12 5:55	1300	500									
3/12 6:00	1300	500			0.740						
3/12 6:05					0.740						
3/12 6:30	1300	550			0.790	0.780					
3/12 6:47	1200	400			0.770	0.770					
3/12 7:00	900	300									
3/12 7:01					0.760	0.760					
3/12 7:15	700	250									
3/12 7:17					0.760	0.760					
3/12 7:30	100	200			0.760	0.760					
3/12 7:40					0.755						
3/12 7:55	50	-100			0.755	0.755					
3/12 8:03	50	-100			0.755	0.755					
3/12 8:10	0	-200									
3/12 8:15					0.750	0.750					
3/12 8:20	-50	-300									
3/12 8:22	0	-300									
3/12 8:23					0.750	0.750					
3/12 8:30	0	-400									
3/12 8:36					0.750						
3/12 8:39	-50	-500									
3/12 8:49	-300	-550			0.740	0.740					
3/12 8:56	-375	-600									
3/12 9:00	-500	-650									
3/12 9:02					0.740	0.740					
3/12 9:10	-425	-650									
3/12 9:20	-425	-700			0.740	0.740					
3/12 9:25	-450	-700			0.740	0.740					
3/12 9:45	-450	-700			0.740	0.740					
3/12 9:52	-500	-700			0.740	0.740					
3/12 10:04	-500	-700									
3/12 10:19					0.750						
3/12 10:20					0.750						

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/12 10:27					0.750						
3/12 10:33	-500	-700									
3/12 10:38	-550	-700			0.740	0.740					
3/12 10:47	-550	-700			0.740	0.740					
3/12 10:52	-600	-750			0.750	0.750					
3/12 11:00	-700	-800			0.750	0.750					
3/12 11:10	-800	-800									
3/12 11:20	-900	-800			0.750	0.750					
3/12 11:30	-1100	-900			0.750	0.750					
3/12 11:41	-1250	-1000			0.750	0.750					
3/12 11:52	-1350	-1100			0.750	0.740					
3/12 12:05	-1500	-1400			0.750	0.740					
3/12 12:12	-1550	-1450			0.750	0.740					
3/12 12:35	-1700	-1450			0.750	0.750					
3/12 12:45	-1700	-1450			0.750	0.745					
3/12 12:55	-1700	-1500			0.750	0.745					
3/12 13:05	-1700	-1500			0.750	0.745					
3/12 13:14	-1700	-1550			0.750	0.745					
3/12 13:26	-1700	-1550			0.755	0.745					
3/12 13:38	-1700	-1550			0.755	0.745					
3/12 13:48	-1700	-1650			0.755	0.745					
3/12 13:52	-1700	-1650			0.755	0.744					
3/12 13:58	-1700	-1650			0.755	0.744					
3/12 14:05	-1700	-1650			0.735	0.735					
3/12 14:10	-1700	-1650			0.730	0.730					
3/12 14:18	-1700	-1600			0.725	0.725					
3/12 14:20	-1700	-1600			0.710	0.710					
3/12 14:25	-1700	-1600			0.690	0.690					
3/12 14:30	-1700	-1600			0.670						
3/12 14:35	-1700	-1600			0.640	0.640					
3/12 14:40	-1700	-1650			0.620	0.620					
3/12 14:41	-1700	-1650			0.610	0.610					
3/12 14:50	-1700	-1600			0.580	0.580					
3/12 14:52	-1700	-1650			0.570	0.570					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/12 14:54	-1700	-1650			0.565	0.565					
3/12 14:56	-1700	-1650			0.555	0.555					
3/12 14:58	-1700	-1650			0.550	0.550					
3/12 15:00					0.540	0.540					
3/12 15:02					0.535	0.535					
3/12 15:04	-1700	-1650			0.530	0.530					
3/12 15:06	-1700	-1650			0.525	0.525					
3/12 15:08	-1700	-1650			0.525	0.525					
3/12 15:10	-1700	-1650			0.520	0.515					
3/12 15:12	-1700	-1650			0.520	0.515					
3/12 15:14	-1700	-1650			0.525	0.520					
3/12 15:18	-1700	-1650			0.525	0.520					
3/12 15:20	-1700	-1650			0.530	0.520					
3/12 15:22	-1700	-1650			0.535	0.520					
3/12 15:26	-1700	-1650			0.535	0.520					
3/12 15:28	-1700	-1650			0.540	0.525					
3/12 15:30	-1700	-1650			0.540	0.525					
3/12 15:35	-1700	-1650			0.540	0.525					
3/12 15:37	-1700	-1650									
3/12 16:10	-1700	-1650									
3/12 16:31	-1700	-1650									
3/12 16:45	-1700	-1700									
3/12 17:00	-1700	-1700									
3/12 17:30	-1700	-1700									
3/12 18:00	-1700	-1700									
3/12 20:08		-1700		0.370							
3/12 20:20				0.367							
3/12 20:30		-1600		0.367							
3/12 21:00		-1750		0.360							
3/12 21:30		-1700		0.355							
3/12 22:00		-1700		0.355							
3/12 22:20		-1700		0.353							
3/12 23:00		-1750		0.358							
3/12 23:30		-1750		0.368							

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/13 0:00		-1750		0.368							
3/13 0:30		-1750		0.378							
3/13 1:00		-1700		0.375							
3/13 2:00		-1700		0.375							
3/13 3:00		-1700		0.373							
3/13 4:00		-1700		0.248							
3/13 5:00		-1700	0.389								
3/13 5:30		-1700	0.389								
3/13 6:00		-1700	0.389								
3/13 6:30		-1700	0.389								
3/13 7:00		-1700	0.394								
3/13 7:30		-1700	0.392								
3/13 8:00		-1700	0.392								
3/13 8:20		-1700	0.396								
3/13 8:55		-1700	0.398								
3/13 9:25		-1700	0.392								
3/13 9:55		-1700	0.392								
3/13 10:35		-1750	0.402								
3/13 10:55		-1700	0.398								
3/13 11:25		-1700	0.404								
3/13 11:55		-1700	0.405								
3/13 12:20		-1700	0.405								
3/13 12:40		-1700	0.405								
3/13 13:00		-1700	0.408								
3/13 13:37					0.595	0.590					
3/13 14:00					0.595	0.590					
3/13 14:10		-1700	0.413								
3/13 14:30		-1700		0.415	0.600	0.600					
3/13 14:45		-1700		0.415	0.600	0.600					
3/13 15:00		-1700	0.415		0.600	0.600					
3/13 15:15		-1700		0.418	0.605	0.600					
3/13 15:30		-1700		0.418	0.605	0.600					
3/13 15:45		-1700		0.420	0.605	0.600					
3/13 16:00		-1700	0.420		0.605	0.600					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/13 16:15		-1700	0.420		0.605	0.600					
3/13 16:30		-1700	0.420		0.605	0.600					
3/13 16:45		-1700	0.422		0.605	0.600					
3/13 17:00		-1700	0.423		0.605	0.600					
3/13 17:15		-1700	0.418		0.605	0.600					
3/13 17:30		-1700	0.415		0.600	0.600					
3/13 18:00		-1700	0.415		0.600	0.600					
3/13 18:20		-1700	0.408		0.590	0.590					
3/13 18:40		-1700	0.403		0.590	0.585					
3/13 19:00		-1750	0.398		0.580	0.580					
3/13 19:30		-1750	0.393		0.575	0.570					
3/13 19:45		-1750	0.388		0.570	0.570					
3/13 20:00		-1750	0.388		0.570	0.565					
3/13 20:15		-1750	0.382		0.560	0.560					
3/13 20:30		-1750	0.383		0.560	0.560					
3/13 20:45		-1750	0.378		0.550	0.550					
3/13 21:00		-1750	0.382		0.550	0.550					
3/13 21:15		-1750	0.380		0.550	0.550					
3/13 21:30		-1750	0.380		0.550	0.550					
3/13 21:45		-1700			0.550	0.550					
3/13 22:00		-1700			0.540	0.540					
3/13 22:15		-1750	0.370		0.540	0.540					
3/13 22:30		-1750	0.030	0.368	0.540	0.540					
3/13 22:45		-1750	0.028	0.365	0.540	0.530					
3/13 23:00		-1750	0.062	0.366	0.540	0.530					
3/13 23:15		-1750	0.068	0.360	0.530	0.530					
3/13 23:30		-1750	0.056	0.360	0.530	0.530					
3/14 0:00		-1700	0.156	0.356	0.520	0.520					
3/14 0:15		-1700	0.072	0.356	0.520	0.520					
3/14 0:30		-1700	0.070	0.356	0.520	0.520					
3/14 0:45		-1700	0.106	0.356	0.520	0.520					
3/14 1:00		-1700	0.056	0.350	0.515	0.510					
3/14 1:15		-1700	0.150	0.350							
3/14 1:30		-1750	0.050	0.350	0.515	0.510					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/14 1:45		-1750	0.040	0.350	0.515	0.505					
3/14 2:00		-1700	0.040	0.350	0.510	0.505					
3/14 2:15		-1700	0.040	0.346	0.510	0.505					
3/14 2:30		-1700	0.036	0.342	0.505	0.500					
3/14 2:45		-1700	0.032	0.340	0.505	0.500					
3/14 3:00		-1700	0.032	0.340	0.505	0.500					
3/14 3:15		-1700	0.032	0.340	0.500	0.500					
3/14 3:30		-1700	0.032	0.340	0.500	0.495					
3/14 3:45		-1700	0.032	0.338	0.500	0.495					
3/14 4:00		-1700	0.032	0.338	0.495	0.490					
3/14 4:15		-1700	0.030	0.328	0.495	0.490					
3/14 4:30		-1700	0.030	0.328	0.495	0.490					
3/14 4:45		-1700	0.038	0.332	0.490	0.485					
3/14 5:00	-1700	-1700	0.030	0.326	0.485	0.480					
3/14 5:15	-1700	-1700	0.030	0.326	0.485	0.480					
3/14 5:30	-1750	-1750	0.030	0.326	0.480	0.480					
3/14 5:45	-1750	-1750	0.030	0.323	0.480	0.475					
3/14 6:00	-1750	-1750	0.030	0.326	0.480	0.475	1.64E+02		2.66E+01		
3/14 6:15	-1750	-1750	0.030	0.318	0.480	0.475					
3/14 6:30	-1750	-1750	0.036	0.320	0.475	0.470	1.62E+02		2.66E+01		
3/14 6:45	-1750	-1750	0.030	0.316	0.475	0.470					
3/14 7:00	-1750	-1750	0.036	0.318	0.470	0.467	1.61E+02		2.65E+01		
3/14 7:15	-1750	-1750	0.038	0.318	0.465	0.460					
3/14 7:30	-1750	-1750	0.038	0.316	0.465	0.460	1.60E+02		2.65E+01		
3/14 7:45							1.60E+02		2.65E+01		
3/14 8:00	-1750	-1750	0.038	0.316	0.460	0.455	1.60E+02		2.65E+01		
3/14 8:15							1.57E+02		2.65E+01		
3/14 8:30	-1800	-1750	0.038	0.312	0.460	0.455	1.52E+02		2.65E+01		
3/14 8:45	-1800	-1750					1.49E+02		2.65E+01		
3/14 9:00	-1800	-1750	0.036	0.306	0.450	0.445	1.45E+02		2.65E+01		
3/14 9:35	-1800	-1750	0.040	0.306	0.450	0.445	1.41E+02		2.65E+01		
3/14 9:45	-1800	-1750	0.040	0.306	0.450	0.445	1.40E+02		2.65E+01		
3/14 10:00	-1800	-1750	0.042	0.310	0.445	0.440	1.39E+02		2.65E+01		
3/14 10:15	-1800	-1750					1.37E+02		2.65E+01		

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/14 10:30	-1800	-1750	0.038	0.306	0.440	0.435	1.35E+02		2.65E+01		
3/14 10:45	-1800	-1750					1.33E+02		2.65E+01		
3/14 11:00			0.038	0.306							
3/14 12:00	-1800	-1750	0.040	0.306			1.23E+02		2.64E+01		
3/14 12:30	-1800	-1750	0.040	0.306			1.18E+02		2.64E+01		
3/14 14:45	-1800	-1750	0.046	0.300			9.80E+01		2.62E+01		
3/14 15:00	-1800	-1750	0.046	0.298			9.48E+01		2.62E+01		
3/14 15:30	-1750	-1750	0.048	0.300			9.17E+01		2.62E+01		
3/14 16:00	-1750	-1750	0.052	0.300			8.97E+01		2.62E+01		
3/14 19:15	-1750	-1750	0.062	0.272			7.88E+01		2.59E+01		
3/14 21:00	-1750	-1750	0.060	0.270			6.56E+01		2.57E+01		
3/14 22:00	-1700	-1700	0.057	0.260			6.10E+01		2.56E+01		
3/15 2:30	-1700	-1700									
3/15 3:00	-1700	-1700	0.068	0.248			5.73E+01		2.46E+01		
3/15 4:00	-1750	-1750	0.068	0.240			6.27E+01		2.47E+01		
3/15 5:00	-1750		0.066	0.240			7.74E+01		2.47E+01		
3/15 11:25	-1700	-1700	0.078	0.206			8.70E+01		2.42E+01		
3/15 11:42	-1700	-1700	0.080	0.206			8.58E+01		2.41E+01		
3/15 11:58	-1700	-1700	0.079	0.202			8.44E+01		2.41E+01		
3/15 13:00	-1700	-1700	0.076	0.206			8.19E+01		2.41E+01		
3/15 15:25	-1800	-1750	0.082	0.195			1.04E+02		2.37E+01		
3/15 16:10	-1800	-1750	0.090	0.200			9.75E+01		2.36E+01		
3/15 18:43	-1800	-1800	0.188				6.89E+01		2.33E+01		
3/16 1:24	-1750	-1750	0.180	0.096			3.84E+01		2.31E+01		
3/16 1:44	-1750		0.092	0.176			3.50E+01		2.36E+01		
3/16 1:54	-1750	-1750	0.092	0.176			3.44E+01		2.33E+01		
3/16 5:00	-1800	-1750	0.096	0.178			7.92E+00		2.42E+01		
3/16 5:15	-1800	-1750	0.098	0.180			4.15E+00		2.42E+01		
3/16 5:35	-1800	-1750	0.100	0.180			9.81E+01		3.64E+01		
3/16 6:55	-1800	-1750	0.186	0.186							
3/16 12:35	-1750	-1750	0.230	0.190							
3/16 15:30	-1750	-1750	0.232	0.188				1.85E+01		2.20E+01	
3/16 20:00	-1800	-1800	0.228	0.188				3.70E-03		2.27E+01	
3/16 20:20	-1800	-1800	0.228	0.188				3.70E-03		2.27E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/16 23:50	-1800	-1750	0.238	0.188				3.05E-03		2.29E+01	
3/17 3:10	-1750	-1750	0.220	0.172				3.09E-03		2.40E+01	
3/17 6:00	-1750	-1750	0.206	0.168				3.15E-03		1.38E+01	
3/17 11:00	-1800	-1800	0.192	0.160				3.60E-03		2.38E+01	
3/17 11:15	-1800	-1800	0.192	0.160				2.70E-03		3.08E+01	
3/17 11:30	-1800	-1800	0.192	0.160				4.10E-03		3.15E+01	
3/17 12:50	-1700	-1750	0.206	0.160				4.10E-03		3.16E+01	
3/17 21:40	-1700		0.192	0.168				3.23E-03		4.82E+01	
3/17 21:50	-1700		0.192	0.168				4.15E-03		4.81E+01	
3/18 2:20	-1700		0.186	0.158				2.65E-03		4.78E+01	
3/18 2:50	-1700		0.182	0.158				3.80E-03		4.77E+01	
3/18 7:40	-1700		0.190	0.162				3.50E-03		4.70E+01	
3/18 7:55	-1700		0.188	0.162				3.75E-03		4.69E+01	
3/18 9:40	-1750	-1700	0.192	0.160				2.75E-03		4.67E+01	
3/18 16:00	-1700	-1800	0.212	0.170	0.180	0.160		3.56E-03		4.60E+01	
3/18 20:55	-1750	-1800	0.212	0.162	0.180	0.160		2.97E-03		4.54E+01	
3/18 21:10	-1750	-1800	0.216	0.168	0.180	0.160		4.00E-03		4.53E+01	
3/19 2:40	-1700	-1700	0.228	0.172	0.180	0.165		3.55E-03		4.46E+01	
3/19 3:30	-1750	-1750	0.228	0.172	0.180	0.165		2.63E-03		1.45E+01	
3/19 7:10	-1700	-1700	0.222	0.170	0.180	0.170		2.33E-03		4.40E+01	
3/19 11:00	-1800	-1700	0.218	0.168	0.180	0.170		2.32E-03		4.35E+01	
3/19 16:30	-1750	-1750	0.228	0.178	0.180	0.170		3.67E+01		4.29E+01	
3/19 16:45	-1750	-1750	0.228	0.178	0.180	0.170		3.60E+01		4.28E+01	
3/19 16:50	-1750	-1750	0.228	0.178	0.180	0.170		3.60E+01		4.28E+01	
3/19 19:00	-1750	-1700	0.232	0.180	0.170	0.165		3.35E+01		4.26E+01	
3/19 22:30	-1750	-1750	0.228	0.182	0.180	0.170		2.49E+01		4.21E+01	
3/20 0:00	-1750	-1750	0.228	0.186	0.180	0.170		1.89E+01		4.19E+01	
3/20 4:50	-1750	-1750	0.226	0.180	0.180	0.170		1.20E+01		4.13E+01	
3/20 5:00	-1750	-1750	0.226	0.180	0.180	0.170		1.11E+01		4.12E+01	
3/20 10:00	-1750	-1750	0.226	0.182	0.170	0.160	3.83E+00			4.07E+01	
3/20 11:00	-1750	-1750	0.216	0.178	0.170	0.160		2.76E+01		4.05E+01	
3/20 15:00	-1700	-1750	0.208	0.176	0.170	0.160		1.20E+01		4.00E+01	
3/20 22:00	-1750	-1800	0.216	0.178	0.160	0.160		4.80E+01		3.91E+01	
3/21 3:00	-1750	-1800	0.216	0.176	0.160	0.160		4.66E+01		3.85E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/21 8:00	-1750	-1750	0.218	0.182	0.160	0.160		4.71E+01		3.79E+01	
3/21 13:30	-1750	-1750	0.218	0.188	0.160	0.155		4.75E+01		3.74E+01	
3/21 14:00	-1750	-1750	0.220	0.190	0.160	0.155		4.76E+01		3.73E+01	
3/21 14:25	-1750	-1750	0.220	0.190	0.160	0.155		4.76E+01		3.73E+01	
3/22 0:15	-1750	-1700	0.218	0.190	0.160	0.155		4.77E+01		3.62E+01	
3/22 5:00	-1750	-1700	0.232	0.200	0.160	0.155		4.80E+01		3.56E+01	
3/22 6:00	-1750	-1700	0.218	0.186	0.160	0.155		4.80E+01		3.55E+01	
3/22 10:30	-1800	-1750	0.250	0.228	0.175	0.155		4.79E+01		3.49E+01	
3/22 11:20	-1800	-1750	0.252	0.228	0.175	0.155		4.78E+01		3.49E+01	
3/22 15:30	-1800	-1750	0.240	0.188	0.180	0.160		4.65E+01		3.40E+01	
3/22 17:00	-1800	-1750	0.242	0.212	0.180	0.160		4.68E+01		3.40E+01	
3/22 18:00	-1750	-1750	0.242	0.212	0.180	0.160		4.64E+01		3.40E+01	
3/22 23:00	-1750	-1750	0.246	0.218	0.185	0.160		4.71E+01		3.36E+01	
3/23 4:00	-1750	-1750	0.336	0.300	0.260	0.240		4.60E+01		3.16E+01	
3/23 9:00	-1750	-1750	0.376	0.342	0.305	0.285		4.88E+01		3.06E+01	
3/23 9:30	-1750	-1750	0.412	0.368	0.310	0.290					
3/23 10:00	-1750	-1750	0.388	0.358	0.320	0.295					
3/23 10:30	-1750	-1750	0.390	0.358	0.320	0.295					
3/23 11:00	-1750	-1750	0.396	0.360	0.325	0.300					
3/23 11:30	-1750	-1750	0.400	0.366	0.320	0.300					
3/23 12:00	-1750	-1750	0.396	0.356	0.320	0.300					
3/23 12:30	-1750	-1750	0.392	0.362	0.325	0.305					
3/23 13:00	-1750	-1750	0.400	0.366	0.330	0.305					
3/23 13:30	-1750	-1700	0.400	0.370	0.330	0.310					
3/23 14:00	-1700	-1700	0.418	0.398	0.345	0.320		4.80E+01		2.98E+01	
3/23 14:20	-1700	-1700	0.390	0.430	0.340	0.320		4.80E+01		2.99E+01	
3/23 14:30	-1700	-1700	0.428	0.390	0.340	0.320					
3/23 15:00	-1700	-1700	0.416	0.380	0.345	0.325					
3/23 15:30	-1700	-1700	0.416	0.378	0.345	0.330					
3/23 16:00	-1750	-1700	0.422	0.398	0.360	0.330					
3/23 18:09	-1740	-1670	0.483		0.347	0.339					
3/23 19:32	-1740	-1680	0.490		0.360	0.346					
3/23 20:21	-1740	-1660	0.492		0.354	0.347					
3/23 21:00	-1700	-1650	0.440	0.416	0.375	0.355		3.12E+01		2.88E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/23 23:00	-1750	-1750	0.466	0.440	0.380	0.365					
3/24 1:00	-1700	-1700	0.456	0.430	0.385	0.370		4.39E+01		2.79E+01	
3/24 5:00	-1700	-1700	0.472	0.446	0.400	0.390		4.37E+01		2.71E+01	
3/24 7:00	-1700	-1700	0.480	0.450	0.400	0.390		4.37E+01		2.71E+01	
3/24 9:00	-1700	-1700	0.496	0.466	0.400	0.400		4.41E+01		2.67E+01	
3/24 11:00	-1700	-1700	0.480	0.446	0.400	0.395		4.35E+01		2.63E+01	
3/24 13:00	-1700	-1650	0.470	0.430	0.390	0.382		4.24E+01		2.61E+01	
3/24 17:00	-1650	-1650	0.488	0.408	0.355	0.355		4.09E+01		2.58E+01	
3/24 20:00	-1700	-1650	0.430	0.402	0.345	0.340		4.05E+01		2.56E+01	
3/24 21:45	-1700	-1650	0.420	0.388	0.330	0.325		4.13E+01		2.55E+01	
3/24 22:00	-1700	-1650	0.422	0.388	0.325	0.325		4.16E+01		2.55E+01	
3/25 0:00	-1700	-1650	0.416	0.388	0.325	0.320		4.16E+01		2.54E+01	
3/25 2:00	-1700	-1650	0.418	0.398	0.325	0.315		4.11E+01		2.54E+01	
3/25 6:00	-1700	-1650	0.406	0.390	0.310	0.305		4.00E+01		2.51E+01	
3/25 10:00	-1650	-1650	0.388	0.388	0.295	0.290		3.89E+01		2.49E+01	
3/25 14:00	-1650	-1600	0.380	0.388	0.280	0.280		3.78E+01		2.47E+01	
3/25 15:45	-1650	-1600	0.376	0.382	0.275	0.275		3.78E+01		2.47E+01	
3/25 16:00	-1650	-1600	0.378	0.382	0.275	0.275		3.72E+01		2.46E+01	
3/25 16:30	-1650	-1600	0.380	0.380	0.275	0.275		3.71E+01		2.45E+01	
3/25 18:30	-1650	-1600	0.376	0.376	0.275	0.275		3.67E+01		2.44E+01	
3/25 23:00	-1650	-1600	0.388	0.392	0.275	0.275		3.60E+01		2.42E+01	
3/26 5:00	-1650	-1600	0.392	0.400	0.270	0.270		3.53E+01		2.38E+01	
3/26 9:30	-1650	-1600	0.418	0.400	0.270	0.270		3.51E+01		2.36E+01	
3/26 11:30	-1650	-1600	0.418	0.392	0.275	0.275		3.57E+01		2.35E+01	
3/26 12:00	-1650	-1600	0.396	0.420	0.275	0.275		3.57E+01		2.35E+01	
3/26 13:00	-1650	-1600	0.390	0.422	0.275	0.275		3.54E+01		2.34E+01	
3/26 17:30	-1650	-1650	0.388	0.416	0.275	0.275		3.63E+01		2.31E+01	
3/26 21:00	-1650	-1650	0.406	0.432	0.270	0.270		3.47E+01		2.29E+01	
3/27 1:00	-1650	-1650	0.406	0.440	0.265	0.265		3.41E+01		2.27E+01	
3/27 5:00	-1650	-1600	0.412	0.452	0.270	0.270		3.40E+01		2.25E+01	
3/27 9:00	-1650	-1600	0.416	0.462	0.270	0.270		3.46E+01		2.22E+01	
3/27 15:30	-1650	-1650	0.412	0.476	0.270	0.270		3.36E+01		2.19E+01	
3/27 16:20	-1650	-1650	0.410	0.482	0.265	0.270		3.36E+01		2.18E+01	
3/27 22:00	-1650	-1650	0.412	0.492	0.265	0.270		3.36E+01		2.16E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/28 0:00	-1650	-1600	0.416	0.490	0.270	0.270		3.36E+01		2.15E+01	
3/28 3:00	-1700	-1650	0.418	0.492	0.270	0.270		3.38E+01		2.13E+01	
3/28 7:00	-1700	-1650	0.420	0.506	0.270	0.270		3.37E+01		2.11E+01	
3/28 12:30	-1700	-1650	0.418	0.502	0.270	0.270		3.39E+01		2.08E+01	
3/28 17:30	-1650	-1650	0.422	0.528	0.280	0.280		3.39E+01		2.06E+01	
3/28 21:00	-1700	-1700	0.430	0.530	0.290	0.290		3.40E+01		2.04E+01	
3/28 21:20	-1700	-1700	0.428	0.536	0.290	0.290		3.39E+01		2.04E+01	
3/28 21:40	-1700	-1700	0.424	0.536	0.290	0.290					
3/28 22:00	-1700	-1700	0.432	0.539	0.290	0.290		3.40E+01		2.03E+01	
3/28 22:20	-1700	-1700	0.432	0.536	0.290	0.290					
3/29 1:00	-1500	-1650	0.438	0.556	0.290	0.290		3.38E+01		2.02E+01	
3/29 4:00	-1600	-1600	0.436	0.558	0.285	0.285		3.60E+01		2.00E+01	
3/29 7:00	-1650	-1700	0.430	0.552	0.275	0.275		3.77E+01		1.99E+01	
3/29 8:30	-1650	-1650	0.430	0.552	0.275						
3/29 8:35	-1650	-1650	0.430	0.552	0.275						
3/29 8:45	-1650	-1650	0.426	0.550	0.275	0.275		4.01E+01		1.98E+01	
3/29 9:10	-1650	-1650	0.428	0.550	0.275	0.275		3.37E+01		1.98E+01	
3/29 9:40	-1650	-1650	0.426	0.546	0.275	0.275		3.94E+01		1.98E+01	
3/29 13:00	-1650	-1600	0.412	0.546	0.265	0.265		3.38E+01		1.97E+01	
3/29 16:00	-1650	-1600	0.408	0.546	0.265	0.265		3.36E+01		1.96E+01	
3/29 19:00	-1650	-1650	0.398	0.536	0.250	0.250		3.48E+01		1.94E+01	
3/29 22:00	-1650	-1650	0.392	0.536	0.245	0.250		3.94E+01		1.93E+01	
3/30 1:00	-1600	-1600	0.400	0.546	0.240	0.240		3.97E+01		1.92E+01	
3/30 4:00	-1600	-1600	0.392	0.542	0.235	0.235		3.32E+01		1.91E+01	
3/30 7:00	-1600	-1600	0.380	0.538	0.235	0.235		3.71E+01		1.90E+01	
3/30 10:00	-1600	-1600	0.376	0.536	0.230	0.230		4.06E+01		1.89E+01	
3/30 13:00	-1600	-1600	0.378	0.546	0.230	0.230		3.77E+01		1.82E+01	
3/30 16:00	-1600	-1600	0.366	0.538	0.230	0.230		4.00E+01		1.85E+01	
3/30 18:00	-1600	-1600	0.366	0.538	0.225	0.225		4.07E+01		1.85E+01	
3/30 20:00	-1600	-1600	0.362	0.548	0.220	0.220		4.01E+01		1.85E+01	
3/30 22:00	-1650	-1650	0.372	0.562	0.220	0.220		4.00E+01		1.84E+01	
3/31 0:00	-1600	-1600	0.362	0.552	0.220	0.220		4.12E+01		1.83E+01	
3/31 2:00	-1600	-1600	0.362	0.552	0.210	0.210		4.23E+01		1.83E+01	
3/31 4:00	-1650	-1650	0.370	0.568	0.210	0.210		4.17E+01		1.82E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
3/31 6:00	-1650	-1650	0.368	0.568	0.210	0.210		3.82E+01		1.81E+01	
3/31 8:00	-1650	-1650	0.366	0.550	0.210	0.210		3.42E+01		1.80E+01	
3/31 10:00	-1600	-1600	0.358	0.566	0.210	0.210		4.23E+01		1.80E+01	
3/31 12:00	-1600	-1650	0.366	0.562	0.210	0.205		4.12E+01		1.72E+01	
3/31 13:00	-1600	-1550	0.356	0.552	0.205	0.205		4.12E+01		1.72E+01	
3/31 14:00	-1600	-1550	0.352	0.552	0.205	0.205		3.44E+01		1.76E+01	
3/31 16:00	-1600	-1550	0.350	0.552	0.190	0.190		4.35E+01		1.77E+01	
3/31 18:00	-1600	-1600	0.340	0.548	0.180	0.180		4.10E+01		1.77E+01	
3/31 20:00	-1650	-1650	0.336	0.538	0.180	0.180		4.25E+01		1.76E+01	
3/31 22:00	-1650	-1650	0.340	0.546	0.180	0.180		4.29E+01		1.76E+01	
4/1 0:00	-1650	-1650	0.326	0.536	0.175	0.175		4.39E+01		1.75E+01	
4/1 2:00	-1600	-1600	0.328	0.546	0.175	0.175		3.87E+01		1.75E+01	
4/1 4:00	-1650	-1600	0.336	0.558	0.170	0.175		4.24E+01		1.74E+01	
4/1 6:00	-1600	-1600	0.326	0.550	0.170	0.170		4.43E+01		1.74E+01	
4/1 8:00	-1650	-1650	0.322	0.552	0.165	0.170		4.25E+01		1.73E+01	
4/1 10:00	-1650	-1650	0.328	0.552	0.165	0.165		4.30E+01		1.72E+01	
4/1 12:00	-1650	-1600	0.320	0.550	0.165	0.165		4.09E+01		1.72E+01	
4/1 16:00	-1600	-1600	0.326	0.550	0.160	0.160		4.42E+01		1.69E+01	
4/1 16:30	-1600	-1600	0.326	0.564	0.160	0.160		4.30E+01		1.70E+01	
4/1 17:00	-1600	-1600	0.326	0.560	0.160	0.160		4.38E+01		1.70E+01	
4/1 20:00	-1600	-1600	0.316	0.556	0.160	0.160		4.29E+01		1.69E+01	
4/2 0:30	-1600	-1600	0.310	0.566	0.160	0.160		4.10E+01		1.67E+01	
4/2 4:00	-1600	-1600	0.320	0.578	0.160	0.160		4.55E+01		1.65E+01	
4/2 8:00	-1650	-1600	0.326	0.582	0.160	0.160		4.42E+01		1.62E+01	
4/2 12:00	-1650	-1650	0.322	0.590	0.155	0.155		4.51E+01		1.60E+01	
4/2 16:30	-1650	-1650	0.316	0.598	0.155	0.155		3.63E+01		1.57E+01	
4/2 20:00	-1650	-1650	0.326	0.598	0.155	0.155		3.38E+01		1.55E+01	
4/2 20:37	-1650	-1650	0.328	0.598	0.155	0.155					
4/2 20:47	-1650	-1650	0.328	0.600	0.155	0.160					
4/2 21:07	-1650	-1650	0.326	0.598	0.155	0.160		3.19E+01		1.56E+01	
4/2 23:00	-1650	-1650	0.322	0.590	0.155	0.160		3.75E+01		1.55E+01	
4/3 3:00	-1650	-1650	0.322	0.602	0.155	0.160		3.18E+01		1.53E+01	
4/3 7:00	-1650	-1600	0.328	0.608	0.155	0.160		4.74E+01		1.50E+01	
4/3 9:00	-1650	-1650	0.326	0.608	0.155	0.155		4.46E+01		1.49E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/3 10:52	-1650	-1650	0.330	0.612	0.155	0.155					
4/3 11:02			0.330	0.618	0.155	0.155					
4/3 11:07	-1650	-1650	0.328	0.616	0.155	0.155					
4/3 11:12	-1650	-1650	0.328	0.612	0.155	0.155					
4/3 11:17	-1650	-1650	0.328	0.612	0.155	0.155					
4/3 11:37	-1650	-1650		0.616	0.155	0.155					
4/3 12:17	-1650	-1650	0.330	0.626	0.155	0.155					
4/3 12:35	-1650	-1650	0.336	0.628	0.155	0.155		3.11E+01		1.41E+01	
4/3 14:00	-1650	-1650	0.328	0.618	0.155	0.155		3.86E+01		1.42E+01	
4/3 17:20	-1650	-1650	0.336	0.628	0.155	0.155		3.89E+01		1.38E+01	
4/3 17:35	-1650	-1650	0.336	0.632	0.155	0.155					
4/3 17:45	-1650	-1650	0.336	0.632	0.155	0.155					
4/3 18:00	-1650	-1650	0.332	0.636	0.155	0.155		3.84E+01		1.38E+01	
4/4 0:00	-1650	-1650	0.338	0.658	0.155	0.155		3.83E+01		1.34E+01	
4/4 6:00	-1700	-1650	0.338	0.670	0.150	0.150		3.77E+01		1.28E+01	
4/4 11:00	-1650	-1650	0.332	0.670	0.150	0.150		3.87E+01		1.22E+01	
4/4 18:00	-1650	-1650	0.332	0.672	0.150	0.150		3.19E+01		1.16E+01	
4/5 0:00	-1700	-1650	0.338	0.672	0.150	0.150		3.21E+01		1.08E+01	
4/5 6:00	-1700	-1650	0.342	0.688	0.150	0.150		3.15E+01		1.02E+01	
4/5 12:00	-1650	-1650	0.346	0.696	0.150	0.150		3.23E+01		9.64E+00	
4/5 18:00	-1650	-1650	0.338	0.718	0.150	0.150		3.15E+01		9.19E+00	
4/6 0:00	-1650	-1650	0.338	0.703	0.150	0.150		3.11E+01		8.79E+00	
4/6 6:00	-1650	-1700	0.350	0.723	0.150	0.150		3.11E+01		8.40E+00	
4/6 12:00	-1650	-1650	0.348	0.725	0.150	0.150		3.10E+01		8.01E+00	
4/6 18:00	-1650	-1650	0.350	0.720	0.150	0.150		3.05E+01		7.57E+00	
4/6 22:00	-1650	-1650	0.353	0.733	0.150	0.150		4.06E+01		7.32E+00	
4/7 0:00	-1650	-1650	0.355	0.735	0.150	0.150		3.37E+01		7.17E+00	
4/7 5:20					0.155	0.155					
4/7 5:30					0.155	0.155					
4/7 5:40					0.155	0.155					
4/7 5:50					0.155	0.155					
4/7 6:00	-1650	-1650	0.363	0.758	0.155	0.155		3.08E+01		1.29E+01	
4/7 7:00					0.160	0.155					
4/7 7:10					0.160	0.155					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/7 7:20					0.160	0.155					
4/7 7:30					0.160	0.155					
4/7 7:40					0.160	0.155					
4/7 7:50					0.160	0.155					
4/7 8:00					0.160	0.155					
4/7 8:10					0.160	0.155					
4/7 8:20					0.160	0.155					
4/7 8:30					0.160	0.155					
4/7 8:40					0.160	0.155					
4/7 8:50					0.160	0.155					
4/7 9:00					0.160	0.155					
4/7 9:10					0.165	0.155					
4/7 9:20					0.165	0.155					
4/7 9:30					0.165	0.155					
4/7 9:40					0.165	0.155					
4/7 9:50					0.165	0.155					
4/7 10:00					0.165	0.155					
4/7 10:10					0.165	0.155					
4/7 10:20					0.165	0.155					
4/7 10:30					0.165	0.155					
4/7 11:00					0.165	0.150					
4/7 12:00	-1650	-1650	0.375	0.758	0.165	0.150		3.17E+01		1.29E+01	
4/7 13:00					0.165	0.150					
4/7 14:00					0.165	0.150					
4/7 15:00					0.165	0.150					
4/7 16:00					0.170	0.150					
4/7 17:00					0.170	0.150					
4/7 18:00	-1650	-1650	0.380	0.773	0.170	0.150		3.11E+01		1.28E+01	
4/7 19:00					0.175	0.150					
4/7 20:00					0.175	0.150					
4/7 21:00					0.175	0.150					
4/7 22:00					0.175	0.150					
4/7 23:00					0.175	0.150					
4/8 0:00	-1650	-1650	0.390	0.788	0.175	0.150		1.00E+02		1.27E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/8 1:00					0.180	0.150					
4/8 2:00					0.180	0.150					
4/8 3:00					0.180	0.150					
4/8 4:00					0.180	0.150					
4/8 5:00					0.180	0.150					
4/8 6:00	-1650	-1650	0.395	0.785	0.180	0.150		1.87E+02		1.26E+01	
4/8 8:00					0.180	0.150		7.62E+01		1.25E+01	
4/8 9:00					0.180	0.150		1.79E+02		1.25E+01	
4/8 10:00					0.180	0.150		1.76E+02		1.25E+01	
4/8 11:00					0.180	0.150		6.20E+01		1.25E+01	
4/8 12:00	-1650	-1650	0.395	0.793	0.180	0.150		6.29E+01		1.18E+01	
4/8 13:00					0.185	0.155		6.83E+01		1.22E+01	
4/8 14:00					0.190	0.155	2.25E+00	7.10E+01		1.22E+01	
4/8 15:00					0.190	0.155	2.03E+00	1.95E+02		1.23E+01	Confirmed instrument failure – CAMSD/W(A) and (B)
4/8 16:00					0.185	0.155	2.05E+00	1.89E+02		1.23E+01	
4/8 17:00					0.185	0.155	4.10E-03	6.10E+01		1.22E+01	
4/8 18:00	-1650	-1650	0.385	0.795	0.185	0.155	3.95E-03	1.85E+02		1.22E+01	
4/8 19:00					0.185	0.155	2.90E-03	8.15E+01		1.22E+01	
4/8 20:00					0.185	0.155	3.45E-03	5.85E+01		1.22E+01	
4/8 21:00					0.185	0.155	3.37E-03	2.00E+02		1.22E+01	
4/8 22:00					0.185	0.155	3.48E-03	1.51E+02		1.22E+01	
4/8 23:00					0.185	0.155	3.70E-03	9.00E+01		1.22E+01	
4/9 0:00	-1650	-1650	0.395	0.803	0.190	0.155	3.88E-03	8.16E+01		1.22E+01	
4/9 1:00					0.190	0.155	3.12E-03	3.14E+01		1.22E+01	
4/9 2:00					0.190	0.160	2.86E-03	8.12E+01		1.21E+01	
4/9 3:00					0.190	0.160	3.54E-03	1.58E+02		1.21E+01	
4/9 4:00					0.190	0.160	3.75E-03	2.03E+02		1.21E+01	
4/9 4:10					0.190						
4/9 4:20					0.190						
4/9 4:30					0.190	0.160					
4/9 4:40					0.190	0.160					
4/9 4:50					0.190	0.160					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/9 5:00					0.190	0.160	3.85E-03	1.85E+02		1.21E+01	
4/9 6:00	-1650	-1650	0.403	0.820	0.190	0.160	3.29E-03	1.78E+02		1.21E+01	
4/9 7:00					0.190	0.160	3.07E-03	1.60E+02		1.20E+01	
4/9 8:00					0.190	0.160	2.66E-03	1.98E+02		1.20E+01	
4/9 9:00					0.190	0.160	3.01E-03	1.13E+02		1.20E+01	
4/9 10:00					0.190	0.160	2.50E-03	8.00E+01		1.20E+01	
4/9 11:00					0.190	0.160	3.40E-03	9.50E-01		1.20E+01	
4/9 12:00	-1650	-1650	0.410	0.825	0.190	0.160	3.55E-03	1.78E+02		1.19E+01	
4/9 16:00	-1650	-1650	0.410	0.825	0.190	0.160	3.90E-03	1.61E+02		1.19E+01	
4/9 18:00	-1650	-1650	0.413	0.830	0.190	0.160	2.54E-03	1.58E+02		1.18E+01	
4/9 20:00	-1600	-1650	0.413	0.838	0.195	0.165	2.94E-03	1.52E+02		1.18E+01	
4/9 22:00	-1600	-1650	0.413	0.843	0.195	0.165	2.67E-03	1.49E+02		1.17E+01	
4/10 0:00	-1600	-1650	0.415	0.850	0.195	0.160	3.27E-03	1.04E+02		1.17E+01	
4/10 2:00					0.195	0.160	3.71E-03	1.32E+02		1.17E+01	
4/10 4:00					0.195	0.165	4.00E-03	1.40E+02		1.16E+01	
4/10 6:00	-1550	-1600	0.410	0.848	0.195	0.165	3.77E-03	1.51E+02		1.16E+01	
4/10 10:00	-1600	-1700	0.413	0.858	0.195	0.160	3.38E-03	1.16E+02		1.15E+01	
4/10 12:00	-1600	-1650	0.415	0.858	0.195	0.165	4.01E-03	8.45E+01		1.07E+01	
4/10 14:00					0.195	0.165	4.08E-03	1.63E+02		1.11E+01	
4/10 16:00					0.195	0.165	3.36E-03	1.56E+02		1.12E+01	
4/10 18:00	-1550	-1650	0.415	0.863	0.195	0.165	4.05E-03	1.23E+02		1.12E+01	
4/10 20:00					0.195	0.160	2.83E-03	1.36E+02		1.12E+01	
4/10 22:00					0.195	0.165	3.04E-03	1.27E+02		1.12E+01	
4/11 0:00	-1650	-1650	0.413	0.873	0.195	0.165	3.75E-03	1.32E+02		1.12E+01	
4/11 2:00					0.195	0.165	4.05E-03	1.28E+02		1.12E+01	
4/11 4:00					0.195	0.165	3.71E-03	1.35E+02		1.12E+01	
4/11 6:00	-1650	-1650	0.410	0.873	0.195	0.165	3.40E-03	1.27E+02		1.11E+01	
4/11 8:00					0.195	0.165	4.10E-03	1.22E+02		1.11E+01	
4/11 10:00					0.195	0.165	3.97E-03	1.28E+02		1.11E+01	
4/11 10:45					0.195	0.165	3.81E-03	1.28E+02		1.11E+01	
4/11 11:30					0.195	0.165	3.72E-03	1.26E+02		1.11E+01	
4/11 12:00	-1600	-1650	0.416	0.873	0.195	0.165	3.75E-03	1.23E+02		1.11E+01	
4/11 14:30					0.195	0.165	3.55E-03	1.25E+02		1.10E+01	
4/11 16:00					0.195	0.165	2.17E-03	1.35E+02		1.10E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/11 18:30	-1600	-1600	0.416	0.895	0.195	0.165	2.75E-03	1.22E+02		1.04E+01	
4/11 20:00					0.195	0.165	2.08E-03	1.28E+02		1.06E+01	
4/11 22:00					0.195	0.160	2.80E-03	1.46E+02		1.08E+01	
4/11 23:40					0.195	0.165					
4/12 0:00	-1600	-1500	0.416	0.898	0.195	0.165	2.55E-03	1.27E+02		1.08E+01	
4/12 4:00					0.190	0.165	3.03E-03	1.05E+02		1.08E+01	
4/12 6:00	-1650	-1650	0.416	0.908	0.190	0.165	3.35E-03	1.29E+02		1.08E+01	
4/12 8:00					0.190	0.165	2.41E-03	1.31E+02		1.07E+01	
4/12 10:00					0.190	0.165	2.72E-03	1.43E+02		1.07E+01	
4/12 13:00	-1600	-1600	0.400	0.900	0.190	0.165	2.56E-03	9.01E+01		9.50E+00	
4/12 14:00					0.190	0.165	4.15E-03	1.24E+02		1.00E+01	
4/12 15:00	-1600	-1600	0.418	0.918	0.190	0.165	4.13E-03	1.45E+02		1.02E+01	
4/12 17:00					0.190	0.165	2.00E-03	1.69E+02		1.03E+01	
4/12 18:00	-1600	-1600	0.420	0.920	0.190	0.165	3.60E-03	1.36E+02		1.04E+01	
4/12 21:00					0.190	0.165	3.41E-03	1.38E+02		1.04E+01	
4/12 23:00	-1650	-1650	0.423	0.925	0.190	0.165	2.75E-03	1.48E+02		1.04E+01	
4/13 3:30					0.190	0.165	2.19E-03	1.41E+02		1.04E+01	
4/13 6:00	-1650	-1650	0.423	0.928	0.190	0.165	3.16E-03	1.38E+02		1.04E+01	
4/13 9:00					0.190	0.165	3.61E-03	1.33E+02		1.04E+01	
4/13 12:00	-1600	-1650	0.420	0.933	0.190	0.165	3.20E-03	1.33E+02		1.03E+01	
4/13 15:00					0.190	0.165	2.20E-03	1.34E+02		1.03E+01	
4/13 18:00	-1600	-1650	0.425	0.938	0.190	0.165	2.85E-03	1.30E+02		1.02E+01	
4/13 21:00					0.190	0.165	2.60E-03	1.07E+02		1.02E+01	
4/14 0:00	-1600	-1600	0.423	0.940	0.190	0.165	2.64E-03	1.30E+02		1.01E+01	
4/14 3:00					0.190	0.165	3.36E-03	1.45E+02		1.01E+01	
4/14 6:00	-1600	-1600	0.420	0.940	0.190	0.165	3.44E-03	1.50E+02		1.00E+01	
4/14 9:00					0.190	0.165	2.69E-03	1.42E+02		1.00E+01	
4/14 12:00	-1600	-1600	0.423	0.948	0.190	0.165	3.21E-03	1.57E+02		9.96E+00	
4/14 15:00					0.190	0.165	3.07E-03	1.41E+02		9.92E+00	
4/14 18:00	-1600	-1600	0.425	0.940	0.190	0.170	2.53E-03	1.38E+02		9.87E+00	
4/14 21:00					0.190	0.170	3.00E-03	1.16E+02		9.82E+00	
4/15 0:00	-1550	-1550	0.428	0.953	0.190	0.170	2.73E-03	1.16E+02		9.77E+00	
4/15 3:00			0.428	0.953	0.185	0.165	1.84E-03	8.13E+01		9.72E+00	
4/15 6:00	-1550	-1600	0.430	0.965	0.190	0.170	2.94E-03	9.58E+01		9.68E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/15 12:00	-1650	-1650	0.430	0.965	0.190	0.170	3.01E-03	1.58E+02		9.58E+00	
4/15 18:00	-1650	-1650	0.428	0.963	0.190	0.170	2.89E-03	1.49E+02	1.21E+00	9.49E+00	
4/15 21:00					0.190	0.170	2.36E-03	1.48E+02	1.21E+00	9.44E+00	
4/16 0:00	-1650	-1700	0.423	0.978	0.185	0.170	3.50E-03	1.58E+02	1.20E+00	9.39E+00	
4/16 3:00					0.190	0.170	1.93E-03	6.70E+01	1.20E+00	9.35E+00	
4/16 6:00	-1650	-1650	0.423	0.978	0.190	0.170	3.55E-03	1.60E+02	1.20E+00	9.30E+00	
4/16 9:00					0.185	0.170	2.63E-03	1.37E+02	1.20E+00	9.26E+00	
4/16 12:00	-1650	-1650	0.423	0.975	0.185	0.175	2.22E-03	1.80E+02	1.19E+00	9.22E+00	
4/16 15:00					0.185	0.170	3.13E-03	1.03E+02	1.19E+00	9.17E+00	
4/16 18:00	-1650	-1650	0.423	0.985	0.185	0.175	2.14E-03	1.17E+02	1.19E+00	9.11E+00	
4/16 21:00					0.180	0.175	4.00E-03	1.76E+02	1.18E+00	9.08E+00	
4/17 0:00	-1650	-1650	0.425	0.993	0.180	0.175	2.85E-03	1.64E+02	1.18E+00	9.03E+00	
4/17 3:00					0.180	0.175	3.28E-03	1.51E+02	1.16E+00	8.91E+00	
4/17 6:00	-1650	-1650	0.425	1.003	0.180	0.175	3.30E-03	1.41E+02	1.12E+00	8.38E+00	
4/17 9:00					0.180	0.175	3.80E-03	1.84E+02	1.09E+00	7.55E+00	
4/17 12:00	-1650	-1650	0.420	0.973	0.175	0.170	2.72E-03	2.24E+02	1.07E+00	6.67E+00	
4/17 15:00					0.180	0.175	2.90E-03	1.73E+02	1.06E+00	5.93E+00	
4/17 18:00	-1650	-1650	0.423	1.008	0.175	0.175	3.06E-03	1.93E+02	1.04E+00	5.32E+00	
4/17 21:00					0.175	0.170	2.32E-03	1.65E+02	1.03E+00	4.77E+00	
4/18 0:00	-1650	-1650	0.420	1.015	0.175	0.170	2.79E-03	1.76E+02	1.02E+00	4.26E+00	
4/18 6:00	-1650	-1650	0.423	1.030	0.170	0.170	1.71E-03	1.75E+02	1.00E+00	3.30E+00	
4/18 9:00					0.170	0.170	2.99E-03	1.74E+02	9.96E-01	2.90E+00	
4/18 12:00	-1650	-1650	0.428	1.035	0.170	0.170	2.46E-03	1.73E+02	9.92E-01	2.56E+00	
4/18 13:00					0.170	0.170	3.85E-03	1.64E+02	9.92E-01	2.55E+00	
4/18 18:00	-1600	-1550	0.423	1.023	0.170	0.170	3.70E-03	1.46E+02	9.89E-01	2.33E+00	
4/18 21:00					0.170	0.170	3.50E-03	1.34E+02	9.90E-01	2.31E+00	
4/19 0:00	-1600	-1550	0.425	1.035	0.170	0.170	2.70E-03	1.30E+02	9.90E-01	2.30E+00	
4/19 3:00					0.170	0.170	1.81E-03	1.67E+02	9.89E-01	2.28E+00	
4/19 6:00	-1600	-1550	0.423	1.040	0.170	0.170	2.84E-03	1.02E+02	9.89E-01	2.26E+00	
4/19 9:00					0.165	0.170	1.18E+00	1.70E+02	9.88E-01	2.24E+00	
4/19 12:00	-1600	-1550	0.430	1.048	0.165	0.170	1.10E+00	1.67E+02	9.88E-01	2.21E+00	
4/19 15:00					0.170	0.170	1.39E+00	1.53E+02	9.88E-01	2.19E+00	
4/19 18:00	-1600	-1600	0.428	1.065	0.170	0.170	2.02E-03	1.24E+02	9.87E-01	2.14E+00	
4/19 21:00					0.165	0.170	1.50E-03	1.38E+02	9.87E-01	2.11E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/20 0:00	-1650	-1650	0.423	1.070	0.165	0.165	1.72E+00	1.40E+02	9.89E-01	2.10E+00	
4/20 3:00					0.165	0.165	1.65E+00	1.44E+02	9.90E-01	2.09E+00	
4/20 6:00	-1650	-1650	0.425	1.075	0.165	0.165	1.01E+00	1.63E+02	9.91E-01	2.08E+00	
4/20 9:00	-1650	-1700			0.165	0.165	9.92E-01	1.41E+02	9.91E-01	2.07E+00	
4/20 12:00	-1700	-1700	0.420	1.078	0.160	0.160	1.00E+00	1.43E+02	9.91E-01	2.05E+00	
4/20 15:00					0.160	0.160	1.07E+00	1.50E+02	9.92E-01	1.04E+00	
4/20 18:00	-1700	-1650	0.428	1.088	0.160	0.160	1.06E+00	1.51E+02	9.92E-01	2.03E+00	
4/20 21:00					0.160	0.160	1.57E+00	1.40E+02	9.92E-01	2.03E+00	
4/21 0:00	-1700	-1650	0.420	1.093	0.160	0.160	1.57E+00	1.42E+02	9.92E-01	2.02E+00	
4/21 3:00					0.160	0.165	3.85E-03	1.42E+02	9.92E-01	2.00E+00	
4/21 6:00	-1700	-1650	0.425	1.103	0.160	0.160	2.42E-03	1.40E+02	9.94E-01	1.99E+00	
4/21 9:00					0.160	0.160	3.77E-03	1.40E+02	9.95E-01	1.98E+00	
4/21 12:00	-1650	-1650	0.433	1.110	0.160	0.160	1.45E+00	1.51E+02	9.96E-01	1.96E+00	
4/21 15:00					0.160	0.160	1.48E+00	1.45E+02	9.95E-01	1.93E+00	
4/21 18:00	-1650	-1700	0.433	1.103	0.160	0.160	1.53E+00	1.51E+02	9.94E-01	1.91E+00	
4/21 21:00					0.160	0.160	1.57E+00	1.60E+02	9.94E-01	1.89E+00	
4/22 0:00	-1650	-1650	0.433	1.105	0.160	0.160	1.53E+00	1.54E+02	9.94E-01	1.88E+00	
4/22 3:00					0.160	0.160	1.36E-03	1.25E+02	9.93E-01	1.87E+00	
4/22 6:00	-1650	-1650	0.435	1.113	0.160	0.160	1.66E-03	1.53E+02	9.94E-01	1.85E+00	
4/22 9:00					0.160	0.160	1.74E-03	1.16E+02	9.94E-01	1.84E+00	
4/22 12:00	-1650	-1650	0.440	1.120	0.160	0.160	1.42E-03	1.82E+02	9.94E-01	1.83E+00	
4/22 15:00					0.160	0.160	1.56E-03	1.84E+02	9.95E-01	1.83E+00	
4/22 18:00	-1650	-1650	0.430	1.113	0.160	0.160	1.31E-03	2.43E+02	9.96E-01	1.82E+00	
4/22 21:00					0.160	0.160	1.71E-03	9.92E+01	9.96E-01	1.81E+00	
4/23 0:00	-1650	-1650	0.440	1.128	0.160	0.160	1.84E-03	1.22E+02	9.97E-01	1.80E+00	
4/23 3:00					0.160	0.160	1.39E-03	1.59E+02	9.97E-01	1.79E+00	
4/23 6:00	-1700	-1700	0.443	1.138	0.160	0.160	1.66E-03	1.58E+02	9.98E-01	1.78E+00	
4/23 9:00					0.160	0.160	1.43E-03	1.43E+02	9.99E-01	1.77E+00	
4/23 12:00	-1700	-1700	0.440	1.130	0.160	0.160	1.80E-03	1.52E+02	1.00E+00	1.77E+00	
4/23 15:00					0.160	0.160	1.78E-03	1.42E+02	1.00E+00	1.76E+00	
4/23 18:00	-1650	-1700	0.440	1.130	0.155	0.155	1.45E-03	1.65E+02	1.00E+00	1.75E+00	
4/23 21:00					0.155	0.155	1.34E-03	1.55E+02	1.00E+00	1.75E+00	
4/24 0:00	-1650	-1650	0.438	1.130	0.155	0.155	1.28E-03	1.53E+02	1.01E+00	1.74E+00	
4/24 3:00					0.155	0.155	1.38E-03	9.50E+01	1.01E+00	1.74E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/24 6:00	-1700	-1700	0.435	1.143	0.155	0.155	1.66E-03	1.08E+02	1.01E+00	1.74E+00	
4/24 12:00	-1700	-1700	0.433	1.143	0.155	0.155	2.12E-03	1.21E+02	1.02E+00	1.74E+00	
4/24 15:00					0.155	0.155	1.57E-03	3.02E+02	1.03E+00	1.74E+00	
4/24 18:00	-1700	-1700	0.438	1.148	0.150	0.155	1.45E-03	1.97E+02	1.03E+00	1.74E+00	
4/24 21:00					0.155	0.155	1.05E-03	1.96E+02	1.04E+00	1.74E+00	
4/25 0:00	-1700	-1700	0.440	1.160	0.155	0.155	1.49E-03	2.05E+02	1.04E+00	1.74E+00	
4/25 3:00					0.155	0.155	1.43E-03	1.02E+02	1.05E+00	1.75E+00	
4/25 6:00	-1700	-1650	0.450	1.173	0.155	0.155	1.27E-03	1.54E+02	1.06E+00	1.76E+00	
4/25 9:00					0.155	0.155	2.14E-03	1.40E+02	1.07E+00	1.76E+00	
4/25 11:00	-1700	-1650	0.448	1.168	0.155	0.155	1.36E-03	1.47E+02	1.08E+00	1.76E+00	
4/25 15:00	-1650	-1650	0.453	1.173	0.150	0.155	1.30E-03	1.45E+02	1.08E+00	1.74E+00	
4/25 17:00	-1650	-1550	0.448	1.165	0.150	0.150	1.34E-03	1.58E+02	1.09E+00	1.74E+00	
4/25 20:00					0.150	0.150	1.78E-03	2.09E+02	1.10E+00	1.75E+00	
4/25 23:00	-1650	-1650	0.450	1.173	0.150	0.150	1.47E-03	2.00E+02	1.10E+00	1.75E+00	
4/26 2:00					0.150	0.150	1.58E-03	2.47E+02	1.11E+00	1.75E+00	
4/26 5:00	-1650	-1650	0.445	1.185	0.150	0.150	1.39E-03	1.37E+02	1.11E+00	1.74E+00	
4/26 8:00					0.150	0.150	1.70E-03	1.76E+02	1.12E+00	1.74E+00	
4/26 11:00	-1650	-1650	0.445	1.180	0.150	0.150	1.71E-03	1.96E+02	1.12E+00	1.74E+00	
4/26 14:00					0.155	0.155	1.22E-03	2.40E+02	1.12E+00	1.74E+00	
4/26 17:00	-1600	-1650	0.443	1.183	0.155	0.150	1.66E-03	1.36E+02	1.13E+00	1.74E+00	
4/26 20:00	-1600	-1650	0.445	1.190	0.155	0.155	1.10E-03	2.08E+02	1.13E+00	1.74E+00	
4/26 23:00	-1600	-1650	0.443	1.203	0.155	0.155	1.46E-03	2.22E+02	1.13E+00	1.73E+00	
4/27 2:00					0.155	0.155	1.70E-03	1.85E+02	1.13E+00	1.73E+00	
4/27 5:00	-1650	-1600	0.450	1.205	0.155	0.155	1.48E-03	8.00E+01	1.14E+00	1.73E+00	
4/27 8:00	-1650	-1650	0.450	1.205	0.155	0.155	1.84E-03	2.30E+02	1.14E+00	1.72E+00	
4/27 11:00	-1650	-1650	0.445	1.203	0.155	0.155	1.80E-03	6.78E+01	1.14E+00	1.72E+00	
4/27 14:00	-1650	-1650	0.440	1.198	0.145	0.145	2.08E-03	6.75E+01	1.15E+00	1.71E+00	
4/27 17:00	-1650	-1650	0.435	1.188	0.140	0.140	3.45E-01	6.59E+01	1.15E+00	1.71E+00	
4/27 20:00	-1650	-1650	0.423	1.175	0.135	0.135	1.85E-03	6.53E+01	1.16E+00	1.70E+00	
4/27 23:00	-1650	-1550	0.420	1.173	0.130	0.130	5.90E-01	8.10E+01	1.16E+00	1.69E+00	
4/28 2:00	-1650	-1600	0.415	1.170	0.125	0.125	1.17E+00	4.75E+01	1.16E+00	1.68E+00	
4/28 5:00	-1650	-1600	0.415	1.168	0.125	0.125	1.92E+00	2.48E+01	1.16E+00	1.67E+00	
4/28 8:00	-1600	-1600	0.415	1.170	0.120	0.120	2.59E+00	2.46E+01	1.16E+00	1.65E+00	
4/28 11:00	-1600	-1600	0.418	1.170	0.120	0.110	2.22E+00	2.46E+01	1.16E+00	1.64E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
4/28 14:00	-1600	-1600	0.413	1.163	0.120	0.110	2.27E+00	2.46E+01	1.17E+00	1.62E+00	
4/28 17:00	-1600	-1600	0.410	1.168	0.115	0.110	2.05E+00	2.49E+01	1.17E+00	1.60E+00	
4/28 20:00	-1600	-1600	0.410	1.165	0.115	0.110	9.88E-01	3.16E+01	1.17E+00	1.58E+00	
4/28 23:00	-1600	-1600	0.410	1.168	0.110	0.110	1.30E+00	2.94E+01	1.17E+00	1.56E+00	
4/29 2:00	-1600	-1650	0.413	1.170	0.110	0.110	1.57E+00	3.01E+01	1.17E+00	1.53E+00	
4/29 5:00	-1650	-1650	0.413	1.175	0.110	0.110	2.55E+00	4.99E+01	1.17E+00	1.50E+00	
4/29 8:00	-1650	-1650	0.408	1.180	0.105	0.105	2.63E+00	5.65E+01	1.17E+00	1.48E+00	
4/29 10:00	-1700	-1700	0.408	1.173	0.105	0.105	2.75E+00	5.70E+01	1.16E+00	1.46E+00	
4/29 11:00	-1700	-1700	0.410	1.175	0.105	0.105	2.78E+00	6.66E+01	1.17E+00	1.49E+00	
4/29 14:00	-1700	-1700	0.420	1.185	0.115	0.110	2.80E+00	7.67E+01	1.16E+00	1.57E+00	
4/29 17:00	-1650	-1650	0.423	1.188	0.120	0.110	2.23E+00	6.14E+01	1.16E+00	1.59E+00	
4/29 20:00	-1650	-1700	0.425	1.190	0.120	0.110	1.91E+00	3.53E+01	1.16E+00	1.60E+00	
4/29 23:00	-1700	-1700	0.430	1.200	0.120	0.110	1.51E+00	1.07E+02	1.16E+00	1.60E+00	
4/30 2:00	-1650	-1700	0.430	1.198	0.120	0.115	1.51E+00	1.12E+02	1.16E+00	1.59E+00	
4/30 5:00	-1650	-1700	0.435	1.205	0.120	0.115	1.35E+00	1.15E+02	1.16E+00	1.57E+00	
4/30 8:00	-1650	-1700	0.438	1.210	0.125	0.120	1.06E+00	3.36E+01	1.16E+00	1.55E+00	
4/30 11:00	-1650	-1700	0.440	1.215	0.125	0.120	1.33E+00	6.39E+01	1.16E+00	1.53E+00	
4/30 14:00	-1650	-1700	0.438	1.213	0.125	0.120	1.08E+00	6.75E+01	1.16E+00	1.50E+00	
4/30 17:00	-1650	-1700	0.440	1.210	0.125	0.120	7.33E-01	7.72E+01	1.16E+00	1.46E+00	
4/30 20:00	-1650	-1700	0.445	1.215	0.130	0.125	1.05E+00	8.85E+01	1.15E+00	1.41E+00	
4/30 23:00	-1650	-1700	0.443	1.218	0.130	0.125	7.44E-01	8.85E+01	1.15E+00	1.37E+00	
5/1 2:00	-1650	-1700	0.443	1.220	0.135	0.130	7.84E-01	3.66E+01	1.15E+00	1.32E+00	
5/1 5:00	-1650	-1650	0.445	1.230	0.130	0.130	5.90E-01	3.34E+01	1.15E+00	1.29E+00	
5/1 8:00	-1650	-1700	0.443	1.225	0.130	0.130	8.64E-01	3.42E+01	1.15E+00	1.27E+00	
5/1 11:00	-1650	-1700	0.440	1.225	0.130	0.130	9.18E-01	4.10E+01	1.15E+00	1.27E+00	
5/1 14:00	-1650	-1700	0.443	1.223	0.135	0.130	8.18E-01	1.38E+02	1.15E+00	1.26E+00	
5/1 17:00	-1650	-1700	0.443	1.215	0.135	0.130	7.58E-01	1.35E+02	1.15E+00	1.25E+00	
5/1 20:00	-1650	-1650	0.445	1.223	0.135	0.135	1.08E+00	1.28E+02	1.14E+00	1.25E+00	
5/1 23:00	-1650	-1700	0.450	1.225	0.135	0.135	1.08E+00	1.30E+02	1.14E+00	1.24E+00	
5/2 2:00	-1650	-1700	0.450	1.233	0.135	0.135	1.71E-01	3.63E+01	1.14E+00	1.24E+00	
5/2 5:00	-1650	-1700	0.453	1.240	0.135	0.135	2.45E-01	3.72E+01	1.14E+00	1.23E+00	
5/2 8:00	-1650	-1700	0.448	1.243	0.135	0.135	7.81E-01	3.99E+01	1.14E+00	1.23E+00	
5/2 11:00	-1650	-1700	0.448	1.245	0.135	0.135	1.13E+00	5.81E+01	1.14E+00	1.22E+00	
5/2 14:00	-1650	-1700	0.443	1.245	0.135	0.135	9.47E-01	5.71E+01	1.14E+00	1.22E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
5/2 17:00	-1650	-1700	0.450	1.248	0.135	0.135	7.37E-01	4.70E+01	1.14E+00	1.22E+00	
5/2 20:00	-1700	-1750	0.450	1.255	0.135	0.135	7.71E-01	4.36E+01	1.14E+00	1.21E+00	
5/2 23:00	-1700	-1750	0.453	1.248	0.135	0.135	6.34E-01	3.70E+01	1.13E+00	1.21E+00	
5/3 2:00	-1700	-1700	0.455	1.250	0.135	0.135	8.02E-01	2.87E+02	1.13E+00	1.21E+00	
5/3 5:00	-1700	-1700	0.453	1.253	0.135	0.135	8.44E-01	6.97E+01	1.13E+00	1.20E+00	
5/3 8:00	-1700	-1700	0.455	1.250	0.135	0.135	8.20E-01	2.93E+02	1.13E+00	1.20E+00	
5/3 11:00	-1700	-1700	0.455	1.258	0.135	0.135	7.83E-01	4.12E+01	1.13E+00	1.20E+00	
5/3 14:00	-1700	-1750	0.450	1.255	0.135	0.135	8.70E-01	3.55E+01	1.13E+00	1.19E+00	
5/3 17:00	-1700	-1700	0.450	1.253	0.135	0.135	8.34E-01	3.48E+01	1.13E+00	1.19E+00	
5/3 20:00	-1700	-1700	0.455	1.255	0.135	0.135	1.11E+00	3.44E+01	1.13E+00	1.19E+00	
5/3 23:00	-1700	-1700	0.455	1.258	0.135	0.135	1.12E+00	7.82E+01	1.13E+00	1.20E+00	
5/4 2:00	-1700	-1700	0.458	1.263	0.135	0.135	1.08E+00	9.25E+01	1.13E+00	1.20E+00	
5/4 5:00	-1700	-1700	0.460	1.268	0.135	0.135	1.21E+00	3.80E+01	1.14E+00	1.20E+00	
5/4 8:00	-1700	-1700	0.455	1.270	0.135	0.135	1.26E+00	3.53E+01	1.14E+00	1.20E+00	
5/4 11:00	-1700	-1700	0.450	1.265	0.135	0.135	1.02E+00	3.17E+01	1.14E+00	1.19E+00	
5/4 14:00	-1700	-1650	0.453	1.260	0.135	0.135	9.40E-01	6.65E+01	1.14E+00	1.19E+00	
5/4 17:00	-1700	-1650	0.453	1.260	0.135	0.135	9.98E-01	4.05E+01	1.14E+00	1.19E+00	
5/4 20:00	-1650	-1650	0.450	1.265	0.135	0.135	1.33E+00	5.85E+01	1.14E+00	1.19E+00	
5/4 23:00	-1600	-1600	0.450	1.268	0.135	0.135	1.02E+00	3.01E+01	1.14E+00	1.19E+00	
5/5 2:00	-1600	-1600	0.455	1.273	0.135	0.135	7.33E-01	4.44E+01	1.14E+00	1.19E+00	
5/5 5:00	-1600	-1600	0.450	1.278	0.130	0.130	1.22E+00	5.29E+01	1.14E+00	1.18E+00	
5/5 8:00	-1650	-1600	0.450	1.275	0.130	0.130	1.17E+00	4.80E+01	1.14E+00	1.18E+00	
5/5 11:00	-1650	-1500	0.460	1.283	0.130	0.130	1.19E+00	5.80E+01	1.14E+00	1.18E+00	
5/5 14:00	-1650	-1500	0.460	1.283	0.130	0.130	1.20E+00	7.61E+01	1.14E+00	1.18E+00	
5/5 17:00	-1650	-1450	0.463	1.283	0.130	0.130	1.20E+00	4.18E+01	1.14E+00	1.18E+00	
5/5 20:00	-1700	-1450	0.460	1.280	0.130	0.125	1.23E+00	5.20E+01	1.14E+00	1.18E+00	
5/5 23:00	-1700	-1600	0.463	1.290	0.130	0.120	1.36E+00	2.05E+02	1.14E+00	1.18E+00	
5/6 2:00	-1700	-1650	0.448	1.280	0.130	0.120	1.70E+00	6.05E+01	1.14E+00	1.17E+00	
5/6 5:00	-1700	-1700	0.463	1.295	0.130	0.120	2.04E+00	2.22E+02	1.13E+00	1.17E+00	
5/6 8:00	-1700	-1650	0.460	1.288	0.130	0.120	1.15E+00	2.29E+02	1.13E+00	1.17E+00	
5/6 11:00	-1650	-1700	0.465	1.285	0.130	0.120	1.81E+00	2.19E+02	1.13E+00	1.16E+00	
5/6 14:00	-1650	-1700	0.463	1.290	0.125	0.120	1.93E+00	4.26E+01	1.13E+00	1.16E+00	
5/6 17:00	-1650	-1700	0.463	1.285	0.125	0.120	2.29E+00	3.71E+01	1.13E+00	1.16E+00	
5/6 20:00	-1650	-1700	0.460	1.295	0.125	0.115	2.80E+00	3.35E+01	1.12E+00	1.16E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
5/6 23:00	-1650	-1700	0.460	1.295	0.125	0.115	2.11E+00	3.27E+01	1.12E+00	1.16E+00	
5/7 2:00	-1650	-1650	0.468	1.303	0.125	0.115	2.54E+00	2.88E+01	1.12E+00	1.16E+00	
5/7 5:00	-1700	-1700	0.465	1.303	0.125	0.115	2.56E+00	3.40E+01	1.12E+00	1.15E+00	
5/7 8:00	-1700	-1650	0.468	1.293	0.125	0.115	2.65E+00	3.54E+01	1.12E+00	1.15E+00	
5/7 11:00	-1700	-1650	0.463	1.290	0.125	0.115	2.31E+00	3.20E+01	1.12E+00	1.15E+00	
5/7 14:00	-1650	-1650	0.460	1.285	0.125	0.115	2.60E+00	3.28E+01	1.12E+00	1.15E+00	
5/7 17:00	-1650	-1650	0.463	1.293	0.125	0.115	3.07E+00	3.80E+01	1.12E+00	1.15E+00	
5/7 20:00	-1700	-1700	0.463	1.293	0.120	0.110	3.26E+00	3.15E+01	1.12E+00	1.15E+00	
5/7 23:00	-1650	-1650	0.458	1.293	0.125	0.110	3.40E+00	3.38E+01	1.12E+00	1.15E+00	
5/8 2:00	-1650	-1700	0.460	1.298	0.120	0.110	2.94E+00	2.97E+01	1.12E+00	1.14E+00	
5/8 5:00	-1650	-1700	0.460	1.290	0.120	0.110	2.59E+00	3.63E+01	1.12E+00	1.14E+00	
5/8 8:00	-1700	-1700	0.458	1.293	0.120	0.110	3.48E+00	3.12E+01	1.12E+00	1.14E+00	
5/8 11:00	-1700	-1700	0.455	1.290	0.120	0.110	3.16E+00	3.00E+01	1.12E+00	1.14E+00	
5/8 14:00	-1700	-1700	0.458	1.290	0.120	0.110	3.25E+00	3.30E+01	1.12E+00	1.14E+00	
5/8 17:00	-1700	-1700	0.458	1.285	0.120	0.110	3.62E+00	4.52E+01	1.12E+00	1.14E+00	
5/8 20:00	-1700	-1700	0.458	1.295	0.120	0.110	3.05E+00	3.02E+01	1.11E+00	1.13E+00	
5/8 23:00	-1700	-1700	0.465	1.295	0.120	0.110	2.78E+00	3.81E+01	1.11E+00	1.13E+00	
5/9 2:00	-1650	-1700	0.460	1.290	0.120	0.105	2.88E+00	3.60E+01	1.11E+00	1.13E+00	
5/9 5:00	-1650	-1700	0.460	1.300	0.120	0.105	3.18E+00	2.76E+01	1.11E+00	1.13E+00	
5/9 8:00	-1650	-1700	0.458	1.293	0.120	0.105	3.10E+00	3.23E+01	1.11E+00	1.13E+00	
5/9 11:00	-1650	-1650	0.465	1.288	0.120	0.105	3.19E+00	4.48E+01	1.11E+00	1.12E+00	
5/9 14:00	-1650	-1650	0.458	1.290	0.120	0.105	3.71E+00	4.68E+01	1.11E+00	1.12E+00	
5/9 17:00	-1650	-1700	0.460	1.280	0.115	0.105	3.55E+00	2.48E+01	1.11E+00	1.12E+00	
5/9 20:00	-1650	-1700	0.460	1.278	0.120	0.105	3.30E+00	1.72E+02	1.11E+00	1.12E+00	
5/9 23:00	-1650	-1650	0.458	1.283	0.120	0.105	3.97E+00	3.19E+01	1.11E+00	1.12E+00	
5/10 2:00	-1650	-1650	0.465	1.280	0.120	0.105	3.73E+00	2.93E+01	1.11E+00	1.12E+00	
5/10 5:00	-1650	-1650	0.458	1.275	0.115	0.105	3.40E+00	1.72E+02	1.10E+00	1.11E+00	
5/10 8:00	-1650	-1650	0.463	1.280	0.120	0.105	3.76E+00	3.16E+01	1.10E+00	1.11E+00	
5/10 11:00		-1650	0.463	1.273	0.120	0.105	3.44E+00	1.50E+02	1.10E+00	1.11E+00	
5/10 14:00		-1650	0.463	1.273	0.120	0.105	3.69E+00	6.22E+01	1.10E+00	1.11E+00	
5/10 17:00		-1650	0.463	1.273	0.120	0.105	3.71E+00	1.70E+02	1.10E+00	1.11E+00	
5/10 20:00		-1650	0.463	1.278	0.120	0.105	3.28E+00	1.76E+02	1.10E+00	1.11E+00	
5/10 23:00		-1650	0.470	1.283	0.120	0.105	3.25E+00	3.10E+01	1.10E+00	1.10E+00	
5/11 2:00		-1700	0.465	1.285	0.120	0.105	3.20E+00	1.81E+02	1.10E+00	1.10E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
5/11 5:00		-1700	0.463	1.280	0.120	0.105	3.61E+00	1.81E+02	1.09E+00	1.10E+00	
5/11 8:00		-1700	0.465	1.288	0.120	0.105	3.56E+00	1.88E+02	1.09E+00	1.10E+00	
5/11 11:00		-1500	0.460	1.278	0.110	0.100	3.35E+00	1.95E+02	1.09E+00	1.10E+00	
5/11 14:00		-1450	0.458	1.278	0.115	0.100	3.33E+00	3.00E+01	1.09E+00	1.10E+00	
5/11 17:00		-1550	0.460	1.283	0.117	0.100	3.88E+00	2.01E+02	1.09E+00	1.10E+00	
5/11 20:00		-1650	0.458	1.285	0.118	0.100	3.48E+00	3.69E+01	1.09E+00	1.10E+00	
5/11 23:00		-1650	0.460	1.290	0.119	0.100	3.65E+00	2.04E+02	1.09E+00	1.09E+00	
5/12 5:00		-1650	0.463	1.293	0.120	0.100	3.65E+00	2.63E+01	1.09E+00	1.09E+00	
5/12 8:00		-1700	0.460	1.293	0.121	0.100	3.82E+00	2.07E+02	1.09E+00	1.09E+00	
5/12 11:00		-1700	0.465	1.300	0.121	0.100	3.59E+00	3.75E+01	1.09E+00	1.09E+00	
5/12 14:00		-1700	0.465	1.310	0.122	0.100	3.83E+00	2.12E+02	1.08E+00	1.09E+00	
5/12 17:00		-1700	0.470	1.305	0.122	0.100	4.13E+00	1.97E+02	1.08E+00	1.09E+00	
5/12 20:00		-1700	0.475	1.303	0.122	0.100	4.06E+00	2.08E+02	1.08E+00	1.09E+00	
5/12 23:00		-1650	0.480	1.303	0.121	0.100	3.87E+00	3.50E+01	1.08E+00	1.09E+00	
5/13 2:00		-1700	0.480	1.295	0.121	0.100	3.88E+00	2.08E+02	1.08E+00	1.08E+00	
5/13 5:00		-1700	0.485	1.295	0.120	0.100	3.50E+00	2.04E+02	1.07E+00	1.08E+00	
5/13 8:00		-1700	0.480	1.293	0.120	0.100	3.77E+00	2.15E+02	1.07E+00	1.08E+00	
5/13 11:00		-1700	0.478	1.298	0.120	0.100	3.78E+00	2.19E+02	1.07E+00	1.08E+00	
5/13 14:00		-1700	0.483	1.295	0.121	0.100	3.59E+00	2.23E+02	1.07E+00	1.08E+00	
5/13 17:00		-1700	0.480	1.298	0.121	0.100	4.15E+00	3.23E+01	1.07E+00	1.08E+00	
5/13 20:00		-1700	0.483	1.313	0.121	0.100	3.57E+00	2.26E+02	1.07E+00	1.08E+00	
5/13 23:00		-1700	0.480	1.318	0.121	0.100	3.50E+00	2.15E+02	1.07E+00	1.08E+00	
5/14 2:00		-1700	0.478	1.313	0.121	0.100	3.63E+00	2.22E+02	1.07E+00	1.07E+00	
5/14 5:00		-1700	0.480	1.310	0.121	0.100	3.54E+00	2.28E+02	1.06E+00	1.07E+00	
5/14 8:00		-1700	0.483	1.308	0.121	0.100	3.82E+00	2.20E+02	1.06E+00	1.07E+00	
5/14 11:00		-1700	0.483	1.305	0.121	0.100	3.67E+00	2.57E+02	1.06E+00	1.07E+00	
5/14 14:00		-1700	0.480	1.300	0.122	0.100	3.00E+00	2.54E+02	1.06E+00	1.07E+00	
5/14 17:00		-1700	0.478	1.300	0.121	0.100	3.90E+00	2.53E+02	1.06E+00	1.07E+00	
5/14 20:00		-1700	0.478	1.295	0.121	0.100	3.72E+00	2.51E+02	1.06E+00	1.07E+00	
5/14 23:00		-1700	0.488	1.313	0.122	0.100	3.63E+00	2.51E+02	1.06E+00	1.06E+00	
5/15 2:00		-1700	0.490	1.323	0.122	0.100	3.73E+00	3.07E+01	1.06E+00	1.06E+00	
5/15 5:00		-1700	0.488	1.330	0.122	0.100	3.62E+00	5.27E+01	1.06E+00	1.06E+00	
5/15 8:00		-1700	0.488	1.335	0.122	0.100	3.76E+00	4.90E+01	1.06E+00	1.06E+00	
5/15 11:00		-1700	0.485	1.335	0.122	0.100	3.80E+00	3.28E+01	1.05E+00	1.06E+00	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
5/15 14:00		-1700	0.485	1.330	0.122	0.100	3.99E+00	2.29E+02	1.05E+00	1.06E+00	
5/15 17:00		-1650	0.485	1.323	0.120	0.100	3.88E+00	2.29E+02	1.05E+00	1.06E+00	
5/15 20:00		-1700	0.483	1.330	0.119	0.100	4.06E+00	5.30E+01	1.05E+00	1.05E+00	
5/15 23:00		-1700	0.483	1.333	0.119	0.100	3.85E+00	4.40E+01	1.05E+00	1.05E+00	

measurement instrument
 measurement instrument

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Vessel Flange	Vessel Flange	Feedwater Nozzle N4B (end)	Feedwater Nozzle N4B (inside)	Feedwater Nozzle N4C (end)	Feedwater Nozzle N4C (inside)	Vessel Core	Reactor Pressure Vessel Bottom Part	CRD Housing Upper Part	CRD Housing Lower Part	Safety Valve (exhaust air) 203-4A①	Safety Valve (exhaust air) 203-4C②	Safety Valve (exhaust air) 203-4B③	SR Valve (exhaust air) 203-3A⑥	SR Valve (exhaust air) 203-3B⑦	SR Valve (exhaust air) 203-3C⑧	SR Valve (exhaust air) 203-3D⑨	D/W HVH Return Air Duct (HVH-12C)	RPV Bellows Air (HVH-12A)	S/C Pool Water Temperature A	S/C Pool Water Temperature B
5/14 14:00	92.5	90.5	110.7	90.4	89.9	89	89.8	90.3	91.1	90.8	107.3	98.7	93.1	100.6	97.3	100.6	93.7	85	90.4	52	51.8
5/14 17:00	91.8	90	110.9	89.9	89.3	88.3	89.1	89.7	90.7	90.4	106.6	98.1	92.5	99.8	96.7	99.9	93.1	84.5	89.9	52	51.8
5/14 20:00	91.6	89.9	111.1	89.8	89.2	88.1	88.9	89.5	90.6	90.3	106.6	98.1	92.3	99.7	96.5	99.9	92.9	84.4	89.7	51.9	51.8
5/14 23:00	91.3	89.6	109.7	89.6	88.9	87.9	88.7	89.2	90.4	90	106.6	97.9	92	99.4	96.3	99.6	92.6	84.2	89.5	52	51.8
5/15 2:00	91.1	89.3	110.4	89.3	88.7	87.7	88.5	89	90.1	89.8	106.3	97.8	91.9	98.8	96.1	98.9	92.4	84	89.3	52	51.8
5/15 5:00	90.8	89.1	110.2	89.2	88.5	87.5	88.3	88.8	89.9	89.6	106	97.7	91.6	98.5	95.9	98.6	92.1	84	89.1	52	51.8
5/15 8:00	90.8	89	109.9	89.1	88.4	87.4	88.2	88.7	89.8	89.5	105.8	97.8	91.5	98.3	95.9	98.4	92	84	89.1	52	51.8
5/15 11:00	90.8	89	110.4	88.9	88.3	87.3	88.1	88.6	89.7	89.4	105.6	98	91.3	98	95.8	98	91.7	84.1	89.1	52	51.8
5/15 14:00	90.9	89.1	110.9	88.9	88.3	87.3	88.1	88.7	89.7	89.4	105.4	98.1	91.2	97.8	95.6	97.9	91.6	84.2	89.2	52	51.9
5/15 17:00	90	88.2	107.8	88.1	87.5	86.6	87.4	87.9	88.9	88.5	103.2	96.9	90.5	96.3	94.1	96.2	90.7	83.7	88.3	52.1	51.9
5/15 20:00	89	87	101.2	87.1	86.6	85.6	86.4	86.8	88	87.6	101.3	95.8	89.6	94.5	92.5	94.2	89.7	83	87.4	52.1	51.9
5/15 23:00	88	86.1	99.1	86.4	85.8	84.8	85.6	86.1	87.3	86.9	99.7	94.7	88.8	93.3	91.4	93.1	88.8	82.5	86.7	52.1	51.9

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/11 20:00												
2011/3/11 20:07			7.000									
2011/3/11 20:15												
2011/3/11 20:30												
2011/3/11 21:00												
2011/3/11 21:30												
2011/3/11 22:00	3400											
2011/3/11 22:10	3400											
2011/3/11 22:20	3400											
2011/3/11 22:30												
2011/3/11 22:35	3400											
2011/3/11 22:47	3400											
2011/3/11 23:05	3400											
2011/3/11 23:20	3500											
2011/3/11 23:25			6.300		0.141							D/W pressure – converted from gage to abs
2011/3/11 23:30	3500											
2011/3/11 23:50	3500											
2011/3/11 23:55	3500											
2011/3/12 0:00	3500											
2011/3/12 0:30												
2011/3/12 0:43	3500											
2011/3/12 1:00	3600											
2011/3/12 1:25	3600											
2011/3/12 1:30			5.300		0.151							D/W pressure – converted from gage to abs
2011/3/12 1:40	3600											
2011/3/12 1:55	3600											
2011/3/12 2:12	3600											
2011/3/12 2:30	3600											
2011/3/12 2:50	3700		5.600									
2011/3/12 2:55												
2011/3/12 3:05	3700											
2011/3/12 3:15					0.161							D/W pressure – converted from gage to abs
2011/3/12 3:30	3700											
2011/3/12 3:40												
2011/3/12 3:55	3700											

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/12 4:19	3700											
2011/3/12 4:35	3700											
2011/3/12 4:55	3700											
2011/3/12 5:20	3700											
2011/3/12 5:30	3700											
2011/3/12 5:55	3700											
2011/3/12 6:00	3700											
2011/3/12 6:30	3700											
2011/3/12 6:47	3600											
2011/3/12 7:00	3600											
2011/3/12 7:15	3600											
2011/3/12 7:30	3600											
2011/3/12 7:55	3600											D/W pressure - converted from gage to abs
2011/3/12 8:10	3600											
2011/3/12 8:20												
2011/3/12 8:25												
2011/3/12 8:30	3600											
2011/3/12 8:38	3600											
2011/3/12 8:46	3600		6.000		0.186							
2011/3/12 8:49												
2011/3/12 8:58	3600											
2011/3/12 9:10												
2011/3/12 9:25	3600											
2011/3/12 9:30												D/W pressure - converted from gage to abs
2011/3/12 9:48	3600											
2011/3/12 10:41	3600											
2011/3/12 10:52	3600											
2011/3/12 11:20	3600											D/W pressure - converted from gage to abs
2011/3/12 11:30	3600											
2011/3/12 12:05												
2011/3/12 12:12	3600											
2011/3/12 12:35												
2011/3/12 12:55	3600		6.100		0.211							
2011/3/12 13:14	3600											

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/12 13:26	3600											D/W pressure – converted from gage to abs
2011/3/12 13:38	3600											
2011/3/12 13:58	3600											
2011/3/12 14:10	3600											
2011/3/12 14:50	3600											
2011/3/12 15:22	3600		6.300		0.231							
2011/3/12 15:37	3550											
2011/3/12 16:10	3600											
2011/3/12 16:31	3550											
2011/3/12 16:45	3550											
2011/3/12 17:00	3550											
2011/3/12 17:30	3550											
2011/3/12 18:00	3550											
2011/3/12 18:20			6.300		0.256							
2011/3/12 18:30	3550											
2011/3/12 19:00	3550											
2011/3/12 19:27	3550											
2011/3/12 19:42	3550											
2011/3/12 20:00	3550											
2011/3/12 20:30	3500											
2011/3/12 21:00	3550											
2011/3/12 21:30	3600											
2011/3/12 22:00	3600											
2011/3/12 22:20	3600											
2011/3/12 23:00	3600											
2011/3/12 23:30	3600											
2011/3/13 0:00	3600											
2011/3/13 0:30	3600											
2011/3/13 1:00	3650											
2011/3/13 2:00	3650											
2011/3/13 3:00	3650		6.098		0.315							
2011/3/13 3:38												
2011/3/13 4:00	3650		6.140									
2011/3/13 5:00	3650		6.140		0.330							
2011/3/13 5:30	3650		6.140		0.330							
2011/3/13 6:00	3650		6.120		0.340							
2011/3/13 6:30	3650		6.120		0.340							
2011/3/13 7:00	3650		6.120		0.340							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 7:30	3650		6.120		0.350							
2011/3/13 8:00	3650		6.100		0.350							
2011/3/13 8:20	3650		6.100		0.350							
2011/3/13 8:30												
2011/3/13 8:55	3700		6.080		0.360							
2011/3/13 9:25		3700	6.080		0.365							
2011/3/13 9:55		3700	1.283		0.160							
2011/3/13 10:30		3800			0.100							
2011/3/13 10:35		3700			0.010							
2011/3/13 10:40		3700										
2011/3/13 10:55		3700										
2011/3/13 11:05		3700										
2011/3/13 11:15		3700										
2011/3/13 11:25		3700										
2011/3/13 11:35		3700			0.380							
2011/3/13 11:45		3700										
2011/3/13 11:55	3750											
2011/3/13 12:10		3750										
2011/3/13 12:20		3750										
2011/3/13 12:30		3750										
2011/3/13 12:40		3750										
2011/3/13 13:00		3750										
2011/3/13 13:10		3750										
2011/3/13 13:45					0.390							
2011/3/13 13:58					0.390							
2011/3/13 14:10												
2011/3/13 14:15	3750				0.390							
2011/3/13 14:30		3750			0.390							
2011/3/13 14:45	3750				0.395							
2011/3/13 15:00		3750			0.395							
2011/3/13 15:15		3750			0.395							
2011/3/13 15:30		3750	5.850		0.400							
2011/3/13 15:45		3800	5.850		0.400							
2011/3/13 16:00		3750	5.850		0.400							
2011/3/13 16:15	3750	3800	5.850		0.400							
2011/3/13 16:30	3750	3800	5.850		0.400							
2011/3/13 16:45	3750	3800	5.810		0.405							
2011/3/13 17:00	3750	3800	5.810		0.405							
2011/3/13 17:15	3750	3800	5.810		0.405							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 17:30	3750	3750	5.780		0.410							
2011/3/13 18:00	3750	3800			0.410							
2011/3/13 18:20	3800	3800			0.410							
2011/3/13 18:40	3800	3750			0.410							
2011/3/13 18:45												
2011/3/13 19:00	3800	3800			0.420							
2011/3/13 19:30	3800	3800			0.420							
2011/3/13 20:00	3800	3800			0.420							
2011/3/13 20:15	3800	3800			0.420							
2011/3/13 20:30	3800	3800			0.420							
2011/3/13 21:00	3800	3850			0.420							
2011/3/13 21:30	3800	3850			0.425							
2011/3/13 22:00	3850	3900			0.430							
2011/3/13 22:30	3850	3900			0.430							
2011/3/13 23:00	3850	3900			0.430							
2011/3/13 23:30	3850	3900			0.435							
2011/3/14 0:00	3850	3900			0.435							
2011/3/14 0:30	3850	3900			0.435							
2011/3/14 1:00	3850	3900			0.435							
2011/3/14 1:30	3850	3900			0.440							
2011/3/14 2:00	3850	3900			0.440							
2011/3/14 2:30	3850	3900	5.470		0.440							
2011/3/14 2:45	3850	3900	5.450		0.440							
2011/3/14 3:00	3850	3900	5.450									
2011/3/14 3:30	3850	3900	5.450									
2011/3/14 4:00	3850	3900	5.420									
2011/3/14 4:30	3850	3900	5.400			0.467						
2011/3/14 5:00	3900	3900	5.400			0.467						
2011/3/14 5:30	3900	3900	5.400			0.469						
2011/3/15 6:00	3900	3900	5.355			0.471	1.00E-03		9.00E-03			
2011/3/14 6:10					0.455							
2011/3/14 6:30	3900	3900	5.355		0.455		1.00E-03		9.00E-03			
2011/3/14 7:00	3900	3950	5.333		0.455	0.473	1.00E-03		8.50E-03			
2011/3/14 7:15	3950	3950										
2011/3/14 7:30	3950	3950	5.333		0.455	0.473	1.00E-03		8.00E-03			
2011/3/14 8:00	3950	3950	5.310		0.455	0.474	1.00E-03		1.00E-02			
2011/3/14 8:30	3950	3950	5.310		0.455	0.474	1.00E-03		1.10E-02			
2011/3/14 8:45							1.00E-03		1.10E-02			
2011/3/14 9:00	3900	3950	5.310		0.460	0.478	1.00E-03		1.15E-02			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 9:35	3800	3850	5.468		0.460	0.476	1.00E-03		1.15E-02			
2011/3/14 9:37	3850	3850										
2011/3/14 9:45	3800	3800	5.445		0.460		1.00E-03		1.20E-02			
2011/3/14 10:00	3800	3850	5.490		0.460	0.480	1.00E-03		1.15E-02			
2011/3/14 10:15							1.00E-03		9.70E-03			
2011/3/14 10:30	3800	3850	5.648		0.460	0.481	1.00E-03		9.50E-03			
2011/3/14 11:30	3400	3400	6.008		0.460	0.485	1.00E-03		1.20E-02			
2011/3/14 12:00	3400	3400	6.008		0.460	0.485	1.00E-03		1.20E-02			
2011/3/14 12:30	2950	3000	6.188		0.465	0.486	1.00E-03		1.10E-02			
2011/3/14 13:00	2500	2500	7.065									
2011/3/14 13:10	2500	2500	7.065		0.465							
2011/3/14 13:24	2400	2400	7.470		0.465							
2011/3/14 13:30			7.459									
2011/3/14 13:40	2250	2250										
2011/3/14 13:45	2200	2200	7.225		0.460							
2011/3/14 14:00	2000	2000	7.639		0.460							
2011/3/14 14:10	1850	1850	7.392		0.460							
2011/3/14 14:20	1650	1650			0.455							
2011/3/14 14:27	1650	1650			0.455							
2011/3/14 14:40	1550	1550	7.425		0.450		1.00E-03		1.30E-02			
2011/3/14 14:50	1250	1250	7.470		0.445							
2011/3/14 15:00	1200	1200	7.392		0.440		1.00E-03		1.30E-02			
2011/3/14 15:15	1100	1100	7.302		0.440		1.08E-03		1.03E-02			
2011/3/14 15:30	900	900	7.020		0.430							
2011/3/14 15:40	700	700	7.070		0.430							
2011/3/14 15:50	500	500	7.425		0.420							
2011/3/14 16:00	300	300	7.448		0.420							
2011/3/14 16:10	100	100	7.448		0.420							
2011/3/14 16:20	0	0	6.998		0.420							
2011/3/14 16:34			6.998									
2011/3/14 16:36			7.403									
2011/3/14 16:39			7.425									
2011/3/14 16:43	-300											
2011/3/14 16:57	-520				0.400							
2011/3/14 17:12	-800		7.403									
2011/3/14 17:14	-850		7.403									
2011/3/14 17:16	-950		6.975									
2011/3/14 17:17	-1000											
2011/3/14 17:20			7.290									

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 17:24			7.358		0.400							
2011/3/14 17:28	-1050		7.358									
2011/3/14 17:30	-1100		6.970									
2011/3/14 17:31			7.380									
2011/3/14 17:33			7.880									
2011/3/14 17:35			6.975									
2011/3/14 17:48	-1450		7.358									
2011/3/14 17:52	-1500		7.358									
2011/3/14 17:55	-1600		6.975		0.400							
2011/3/14 18:00	-1600		7.133									
2011/3/14 18:03			6.075									
2011/3/14 18:05	-2000		5.625									
2011/3/14 18:06	-1100		5.400									
2011/3/14 18:07	-2100		4.950									
2011/3/14 18:08	-2000		4.500									
2011/3/14 18:09	-3000		3.150		0.395							
2011/3/14 18:10	-3000		2.995		0.395							
2011/3/14 18:12	-3250		2.475		0.395							
2011/3/14 18:13	-3400		2.183		0.395							
2011/3/14 18:14	-3500		1.913		0.395							
2011/3/14 18:17	-3500		1.643		0.395							
2011/3/14 18:18	-3600		1.513		0.400							
2011/3/14 18:19	-3600		1.463		0.400							
2011/3/14 18:20	-3600		1.395		0.400							
2011/3/14 18:21	-3600		1.305		0.400							
2011/3/14 18:22	-3700		1.215		0.400							
2011/3/14 18:23	-3700		1.170		0.400							
2011/3/14 18:24	-3700		1.125		0.400							
2011/3/14 18:25	-3700		0.125		0.400							
2011/3/14 18:26	-3700		1.035		0.400							
2011/3/14 18:27	-3700		0.990		0.400							
2011/3/14 18:28	-3700		0.945		0.400							
2011/3/14 18:29	-3700		0.900		0.400							
2011/3/14 18:30	-3700		0.878		0.400							
2011/3/14 18:31	-3700		0.855		0.400							
2011/3/14 18:32	-3700		0.810		0.400							
2011/3/14 18:33	-3700		0.780		0.400							
2011/3/14 18:34	-3700		0.765		0.400							
2011/3/14 18:35	-3700		0.720		0.400							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 18:36	-3700		0.698		0.400							
2011/3/14 18:37	-3700		0.675		0.400							
2011/3/14 18:40	-3700		0.653		0.400							
2011/3/14 18:39	-3700		0.540		0.400							
2011/3/14 18:40	-3700		0.563		0.400							
2011/3/14 18:42	-3700		0.540		0.400							
2011/3/14 18:45	-3700		0.563		0.400							
2011/3/14 18:47	-3700		0.585		0.400							
2011/3/14 18:50			0.585		0.400							
2011/3/14 18:52			0.638		0.400							
2011/3/14 18:55			0.638		0.400							
2011/3/14 19:00			0.630		0.400							
2011/3/14 19:03			0.630		0.400							
2011/3/14 19:12			0.653		0.400							
2011/3/14 19:13			0.653		0.400							
2011/3/14 19:18			0.653		0.400							
2011/3/14 19:22			0.650		0.395							
2011/3/14 19:35			0.608		0.395							
2011/3/14 19:45			0.585		0.395							
2011/3/14 19:49			0.585		0.395							
2011/3/14 19:54			0.563		0.395							
2011/3/14 19:55			0.563		0.395							
2011/3/14 19:57			0.560									
2011/3/14 19:59			0.563		0.455							
2011/3/14 20:03			0.540		0.410							
2011/3/14 20:05			0.540		0.410							
2011/3/14 20:07			0.540		0.415							
2011/3/14 20:08			0.563		0.415							
2011/3/14 20:10			0.540		0.418							
2011/3/14 20:12			0.563		0.419							
2011/3/14 20:13			0.540		0.420							
2011/3/14 20:15			0.540		0.420							
2011/3/14 20:18			0.563		0.420							
2011/3/14 20:20			0.563		0.420							
2011/3/14 20:21			0.563		0.420							
2011/3/14 20:23			0.563		0.420							
2011/3/14 20:26			0.585		0.420							
2011/3/14 20:28			0.608		0.420							
2011/3/14 20:32			0.608		0.420							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 20:33			0.653		0.420							
2011/3/14 20:37			0.810		0.421							
2011/3/14 20:43			0.833		0.421							
2011/3/14 20:54			1.170		0.420							
2011/3/14 20:59			1.373		0.419							
2011/3/14 21:03			1.418		0.419							
2011/3/14 21:06					0.419							
2011/3/14 21:09			1.440		0.418							
2011/3/14 21:18			1.463		0.418							
2011/3/14 21:20	-3400		0.833		0.470							
2011/3/14 21:21	-3500		0.675		0.465							
2011/3/14 21:26	-3300		0.608		0.470							
2011/3/14 21:27	-3300		0.563		0.470							
2011/3/14 21:29	-3200		0.518		0.475							
2011/3/14 21:30	-3000		0.495		0.475							
2011/3/14 21:31	-3000		0.450		0.480							
2011/3/14 21:32	-3000		0.450		0.480							
2011/3/14 21:33	-2000		0.450		0.480							
2011/3/14 21:34	-2000		0.405		0.480							
2011/3/14 21:35	-2000		0.405		0.480							
2011/3/14 21:38	-2000				0.480							
2011/3/14 21:42	-2000				0.480							
2011/3/14 21:55	-1800		0.405		0.470		5.36E+00		3.83E-01			
2011/3/14 22:00	-1600		0.405		0.480		5.79E+00		3.95E-01			
2011/3/14 22:10	-1600		0.405		0.480	0.400	6.49E+00		5.04E-01			
2011/3/14 22:20	-1400		0.405		0.480	0.370	6.88E+00		5.06E-01			
2011/3/14 22:30	-1200		0.405		0.482	0.370	7.46E+00		5.51E-01			
2011/3/14 22:40	-700		0.428		0.482	0.350	7.92E+00		7.35E-01			
2011/3/14 22:50	-1600		1.823		0.540	0.380	6.54E+00		1.01E+00			
2011/3/14 23:00	-1700		2.070		0.580	0.360						
2011/3/14 23:10	-2000		2.655		0.620	0.350						
2011/3/14 23:11	-2000		2.655		0.620	0.350						
2011/3/14 23:20			3.150				8.81E+00		6.61E+00			
2011/3/14 23:25			3.150		0.700		8.81E+00		6.61E+00			
2011/3/14 23:30			1.913		0.700	0.310	1.50E+01		7.40E+00			
2011/3/14 23:35			1.733		0.740	0.300						
2011/3/14 23:38			1.463			0.300						
2011/3/14 23:40			1.170		0.740	0.300						
2011/3/14 23:41			0.968		0.740	0.300						

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 23:42			0.810		0.740	0.300	2.25E+01		9.11E+00			
2011/3/14 23:44			0.698		0.750	0.340	2.29E+01		9.12E+00			
2011/3/14 23:46			0.675		0.750	0.350	2.33E+01		9.11E+00			
2011/3/14 23:50			0.675		0.750	0.330	2.35E+01		9.07E+00			
2011/3/14 23:52			0.653		0.750	0.300	2.42E+01		9.04E+00			
2011/3/14 23:54			0.653		0.745	0.300	2.45E+01		9.10E+00			
2011/3/15 0:02					0.740							
2011/3/15 0:04					0.740							
2011/3/15 0:05			0.653		0.740	0.300						
2011/3/15 0:06			0.675		0.740	0.300						
2011/3/15 0:07			0.675		0.740	0.300						
2011/3/15 0:08			0.788		0.740	0.300						
2011/3/15 0:10			0.833		0.740	0.300						
2011/3/15 0:16			1.035		0.740	0.300						
2011/3/15 0:22			1.170		0.735	0.300						
2011/3/15 0:28			1.350		0.730	0.300						
2011/3/15 0:32			1.485		0.725	0.330						
2011/3/15 0:41			1.710		0.720	0.330						
2011/3/15 0:45			1.823									
2011/3/15 0:49			2.003									
2011/3/15 1:00			2.430									
2011/3/15 1:02			2.520									
2011/3/15 1:10			1.440		0.725							
2011/3/15 1:11			1.058		0.725	0.330						
2011/3/15 1:12			0.923									
2011/3/15 1:13			0.855		0.730	0.330						
2011/3/15 1:14			0.743		0.730	0.310						
2011/3/15 1:16			0.698		0.720	0.310						
2011/3/15 1:18			0.675		0.730	0.300	2.88E+01		8.08E+00			
2011/3/15 1:20			0.653		0.730	0.330	2.89E+01		8.12E+00			
2011/3/15 1:22			0.653		0.730	0.310	2.90E+01		8.13E+00			
2011/3/15 1:28			0.630		0.730	0.330	2.90E+01		7.96E+00			
2011/3/15 1:31			0.630		0.730	0.320	2.91E+01		7.81E+00			
2011/3/15 1:40			0.630		0.725	0.310	2.94E+01		7.84E+00			
2011/3/15 1:48			0.630		0.725	0.310						
2011/3/15 1:53			0.630		0.725	0.330	3.04E+01		7.56E+00			
2011/3/15 2:03			0.630		0.725	0.330	3.04E+01		7.40E+00			
2011/3/15 2:08			0.630		0.725	0.330	3.09E+01		7.37E+00			
2011/3/15 2:10			0.630		0.730	0.340	3.11E+01		7.27E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/15 2:17			0.630		0.730	0.340	3.15E+01		7.15E+00			
2011/3/15 2:22			0.675		0.740	0.330	3.22E+01		7.00E+00			
2011/3/15 2:39			0.653		0.750	0.330	3.46E+01		6.96E+00			Instrument failure - S/C pressure
2011/3/15 2:45			0.653		0.750	0.320	3.65E+01		6.88E+00			
2011/3/15 2:50			0.653		0.750	0.330	3.78E+01		6.82E+00			
2011/3/15 3:00			0.653		0.750	0.330	4.09E+01		6.60E+00			
2011/3/15 3:05			0.653		0.750	0.330	4.18E+01		6.58E+00			
2011/3/15 3:20			0.653		0.750	0.330	4.30E+01		6.42E+00			
2011/3/15 3:30			0.653		0.750	0.330	4.59E+01		6.31E+00			
2011/3/15 3:40			0.653		0.750	0.330	4.76E+01		6.23E+00			
2011/3/15 3:50			0.653		0.750	0.330	4.94E+01		6.22E+00			
2011/3/15 4:00			0.653		0.750	0.330	5.01E+01		6.09E+00			
2011/3/15 4:05			0.653		0.750	0.330	5.12E+01		5.87E+00			
2011/3/15 4:10			0.653		0.750	0.310	5.19E+01		5.72E+00			
2011/3/15 4:20			0.637		0.750	0.310	5.32E+01		5.65E+00			
2011/3/15 4:30			0.632		0.750	0.300	5.44E+01		5.58E+00			
2011/3/15 4:45			0.632		0.750	0.310	5.55E+01		5.52E+00			
2011/3/15 5:00			0.626		0.750	0.300	5.75E+01		5.29E+00			
2011/3/15 5:15			0.623		0.740	0.300	5.83E+01		5.19E+00			
2011/3/15 5:30			0.621		0.730	0.310	5.95E+01		5.08E+00			
2011/3/15 5:45			0.617		0.740	0.320	6.06E+01		5.00E+00			
2011/3/15 6:00			0.614		0.730	0.270	6.16E+01		4.89E+00			
2011/3/15 6:02			0.612		0.730	0.000	6.26E+01		4.80E+00			
2011/3/15 6:10	-2800				0.730	0.000						
2011/3/15 6:20	-2700		0.612		0.730	0.000	6.27E+01		4.80E+00			
2011/3/15 6:25	-2300		0.610		0.730	0.000	4.30E+01		4.70E+00			
2011/3/15 7:20	-2500		0.612		0.730	0.000						
2011/3/15 11:25	-1200		0.270		0.155		4.56E+01		5.79E+00			
2011/3/15 11:42	-1400		0.315		0.155		4.61E+01		5.52E+00			
2011/3/15 11:58	-1350		0.428		0.155		4.65E+01		5.27E+00			
2011/3/15 13:00	-1700		0.608		0.415		4.77E+01		4.62E+00			
2011/3/15 15:25	-1950		0.119		0.275		1.35E+02		6.92E+00			
2011/3/15 15:50	-1750		0.117		0.270							
2011/3/15 16:10	-1700		0.119		0.270		1.38E+02		6.49E+00			
2011/3/15 18:43	-1200		0.099		0.250		1.22E+02		4.40E+00			
2011/3/16 1:24	-1400		-0.023		0.120		1.03E+02		3.68E+00			
2011/3/16 1:44	-1400		-0.023		0.120		1.02E+02		3.66E+00			
2011/3/16 1:54	-1400		-0.023		0.120		1.02E+02		3.65E+00			
2011/3/16 5:00	-1475		-0.038		0.125		9.85E+01		3.67E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/16 5:15	-1475		-0.041		0.120		9.83E+01		3.69E+00			
2011/3/16 5:35	-1450		-0.041		0.040		6.05E+01		2.43E+00			
2011/3/16 6:10	-1425		-0.043		0.050		9.77E+01		3.63E+00			
2011/3/16 6:55	-1400		-0.043		0.045		9.72E+01		3.57E+00			
2011/3/16 12:35	-1400				0.040		9.38E+01		3.01E+00			
2011/3/16 15:30	-1400		-0.061		0.075	0.145	9.24E+01		2.86E+00			
2011/3/16 20:00	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 20:20	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 20:40	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 23:50	-1400		-0.063		0.075							
2011/3/17 3:10	-1400		-0.065		0.075		8.70E+01		2.65E+00			
2011/3/17 6:00	-1400		-0.068		0.075		8.63E+01		2.63E+00			
2011/3/17 11:00	-1600		-0.029		0.110		8.46E+01		2.50E+00			
2011/3/17 11:15	-1700		-0.029		0.115		8.46E+01		2.50E+00			
2011/3/17 11:30	-1800		-0.029		0.115		8.46E+01		2.50E+00			
2011/3/17 12:50	-1800		-0.027		0.110		8.44E+01		2.43E+00			
2011/3/17 21:40	-1400				0.130		8.21E+01		2.40E+00			
2011/3/17 21:50	-1400				0.130		8.24E+01		2.41E+00			
2011/3/18 2:20	-1400		-0.018		0.130		8.02E+01		2.40E+00			
2011/3/18 2:50	-1400		-0.016		0.130		7.98E+01		2.40E+00			
2011/3/18 7:40	-1400		-0.014		0.130		7.81E+01		2.37E+00			
2011/3/18 7:55	-1400		-0.014		0.130		7.80E+01		2.37E+00			
2011/3/18 9:40	-1400		-0.009		0.135		7.74E+01		2.36E+00			
2011/3/18 16:00	-1400		-0.002		0.139		7.50E+01		2.34E+00			
2011/3/18 20:55	-1400		-0.002		0.140		7.35E+01		2.33E+00			
2011/3/18 21:10	-1400		-0.005		0.140		7.35E+01		2.32E+00			
2011/3/19 2:40	-1400		-0.005		0.135		7.18E+01		2.30E+00			
2011/3/19 3:30	-1400		-0.005		0.135		7.15E+01		2.30E+00			
2011/3/19 7:10	-1350		-0.005		0.135		7.06E+01		2.29E+00			
2011/3/19 11:00	-1400	-400	-0.009		0.135		6.96E+01		2.27E+00			
2011/3/19 16:30	-1300	-300	-0.009		0.135		6.83E+01		2.26E+00			
2011/3/19 19:00	-1300	-350	-0.009		0.135		6.76E+01		2.25E+00			
2011/3/19 22:30	-1350	-400	-0.009		0.130		6.68E+01		2.20E+00			
2011/3/20 0:00	-1300	-380	-0.007		0.130		6.58E+01		2.20E+00			
2011/3/20 4:50	-1300	-380	-0.014		0.130		6.97E+01		2.18E+00			
2011/3/20 5:00	-1300	-500	-0.014		0.130		6.47E+01		2.17E+00			
2011/3/20 10:00			-0.011		0.130		6.36E+01		2.16E+00			
2011/3/20 11:00	-1400	-400	-0.016		0.125		1.34E+01		2.15E+00			
2011/3/20 15:00	-1400	-400	-0.016	-0.020	0.125		6.25E+01		2.13E+00		0.060	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/20 22:00	-1400	-200	-0.018	-0.020	0.120		6.12E+01		2.11E+00		0.060	
2011/3/21 3:00	-1350	-250	-0.018	-0.020	0.120		6.01E+01		2.09E+00		0.060	
2011/3/21 8:00	-1350	-300	-0.020	-0.020	0.120		5.91E+01		2.06E+00		0.060	
2011/3/21 13:30	-1350	-200	-0.020	-0.025	0.120		5.83E+01		2.04E+00			
2011/3/21 14:00	-1350	-200	-0.023	-0.025	0.120		5.81E+01		2.03E+00			
2011/3/21 14:25	-1350	-200	-0.023	-0.025	0.120		5.81E+01		2.03E+00			
2011/3/22 0:15	-1400	-200	-0.025	-0.027	0.110		5.64E+01		1.99E+00			
2011/3/22 5:00	-1300	-100	-0.016	-0.018	0.110		5.55E+01		1.90E+00			
2011/3/22 6:00	-1350	0	-0.005	-0.029	0.110		5.54E+01		1.95E+00			
2011/3/22 10:30	-1350	0	-0.020	-0.023	0.110		5.47E+01		1.93E+00			
2011/3/22 11:20	-1350	175	-0.018	-0.018	0.110							
2011/3/22 15:30	-1300	-400	-0.029	-0.032	0.110		5.36E+01		1.90E+00			
2011/3/22 17:00	-1350	-150	-0.027	-0.032	0.110		5.35E+01		1.88E+00			
2011/3/22 18:00	-1350	-100	-0.029	-0.034	0.110		5.34E+01		1.88E+00			
2011/3/22 23:00	-1350	-500	-0.020	-0.043	0.110		5.28E+01		1.83E+00			
2011/3/23 4:20	-1300	0	-0.025	-0.025	0.110		5.20E+01		1.80E+00			
2011/3/23 9:00	-1300	-150	-0.023	-0.023	0.110		5.14E+01		1.76E+00			
2011/3/23 14:00	-1250	100	-0.036	-0.036	0.110		5.07E+01		1.67E+00			
2011/3/23 21:00	-1200	-550	-0.036	-0.036	0.110		4.98E+01		1.53E+00			
2011/3/24 1:00	-1200	-250	-0.025	-0.025	0.105		4.93E+01		1.49E+00			
2011/3/24 5:00	-1150	-100	-0.027	-0.027	0.110		4.88E+01		1.43E+00			
2011/3/24 9:00	-1150	-100	-0.135	-0.038	0.110		4.84E+01		1.40E+00		0.100	
2011/3/24 13:00	-1150	-200	-0.023	-0.025	0.100		4.79E+01		1.37E+00		0.100	
2011/3/24 17:00	-1200	-250	-0.036	-0.036	0.110		4.74E+01		1.36E+00			
2011/3/24 20:00	-1100	0	-0.036	-0.036	0.100		4.71E+01		1.34E+00			
2011/3/24 22:00	-1150	-150	-0.020	-0.020	0.105		4.68E+01		1.39E+00			
2011/3/24 22:30	-1150	-50	-0.032	-0.032	0.105		4.68E+01		1.47E+00			
2011/3/25 0:00	-1400	-600	-0.025	-0.027	0.120		4.66E+01		1.50E+00			
2011/3/25 1:20	-1600	-750	-0.025	-0.027	0.120						0.120	
2011/3/25 2:00	-1300	-1400	-0.023	-0.025	0.120		4.64E+01		1.52E+00			
2011/3/25 2:30	-1200	-300										
2011/3/25 6:00	-1100	-200	-0.020	-0.020	0.120		4.59E+01		1.54E+00		0.100	
2011/3/25 10:00	-1200	-500	-0.020	-0.020	0.120		4.56E+01		1.54E+00			
2011/3/25 14:00	-1400	-400	-0.016	-0.018	0.120		4.52E+01		1.54E+00			
2011/3/25 18:30	-1150	-250	-0.020	-0.018	0.120		4.47E+01		1.54E+00			
2011/3/25 23:00	-1150	-450	-0.009	-0.009	0.120		4.43E+01		1.53E+00			
2011/3/26 5:00	-1000	-300	-0.014	-0.014	0.120		4.38E+01		1.51E+00			
2011/3/26 9:30	-1100	-500	-0.014	-0.014	0.115		4.34E+01		1.49E+00			
2011/3/26 10:21	-1000	-500	-0.014	-0.014	0.115							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/26 10:40	-1100	-500	-0.014	-0.016	0.115							
2011/3/26 11:00	-1100	-500	-0.014	-0.016	0.115							
2011/3/26 11:30	-1100	-600	-0.025	-0.027	0.110		4.33E+01		1.49E+00			
2011/3/26 12:00	-1100	-700	-0.027	-0.027	0.110		4.32E+01		1.49E+00			
2011/3/26 13:00	-1200	-1000	-0.027	-0.027	0.110		4.32E+01		1.48E+00			
2011/3/26 17:30	-1150	-1600	-0.018	-0.038	0.110		4.28E+01		1.47E+00			
2011/3/26 17:50	-1150	-1650										
2011/3/26 18:00	-1200	-1600										
2011/3/26 18:10	-1200	-1600	-0.016	-0.016	0.110							
2011/3/26 18:30	-1200	-1550	-0.016	-0.016	0.110							
2011/3/26 19:00	-1200	-1650	-0.018	-0.016	0.110							
2011/3/26 21:00	-1200	-1850	-0.016	-0.018	0.110		4.26E+01		1.46E+00			
2011/3/27 1:00	-1200	-1850	-0.018	-0.018	0.110	0.160	4.22E+01		1.45E+00			
2011/3/27 5:00	-1200	-1850	-0.018	-0.018	0.110	0.040	4.19E+01		1.43E+00			
2011/3/27 9:00	-1200	-1850	-0.018	-0.020	0.110		4.16E+01		1.41E+00			
2011/3/27 15:30	-1250	-1900	-0.018	-0.020	0.110		4.11E+01		1.39E+00			
2011/3/27 16:20	-1150	-1850	-0.018	-0.020	0.110		4.11E+01		1.38E+00			
2011/3/27 17:50	-1200	-1900	-0.018	-0.020	0.110		4.10E+01		1.38E+00			
2011/3/27 18:40	-1400	-1850	-0.018	-0.020	0.110							
2011/3/27 19:00	-1250	-1950	-0.020	-0.020	0.110							
2011/3/27 19:20	-1300	-1900	-0.020	-0.023	0.110							
2011/3/27 19:40	-1400	-1900	-0.020	-0.020	0.110							
2011/3/27 20:00	-1400	-1900	-0.020	-0.023	0.110							
2011/3/27 20:20	-1500	-2000	-0.020	-0.023	0.110		4.08E+01		1.37E+00			
2011/3/27 20:40	-1500	-2000	-0.020	-0.023	0.110							
2011/3/27 22:00	-1500	-2050	-0.020	-0.020	0.110		4.07E+01		1.37E+00		0.120	
2011/3/28 0:00	-1400	-2000	-0.020	-0.020	0.110		4.06E+01		1.36E+00			
2011/3/28 0:15	-1400	-1950	-0.020	-0.020	0.110							
2011/3/28 0:35	-1500	-2100	-0.020	-0.020	0.110							
2011/3/28 0:55	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.36E+00			
2011/3/28 1:15	-1500	-2100	-0.020	-0.020	0.110							
2011/3/28 3:00	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.37E+00		0.150	
2011/3/28 3:30	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.37E+00			
2011/3/28 4:00	-1500	-2100	-0.020	-0.023	0.110		4.05E+01		1.37E+00			
2011/3/28 7:00	-1500	-2100	-0.020	-0.023	0.105		4.05E+01		1.39E+00			
2011/3/28 12:30	-1500	-2100	-0.032	-0.032	0.100		4.04E+01		1.39E+00			
2011/3/28 17:30	-1500	-2100	-0.032	-0.032	0.100		4.04E+01		1.40E+00			
2011/3/28 21:00	-1500	-2100	-0.034	-0.034	0.100		4.04E+01		1.40E+00			
2011/3/29 1:00	-1500	-2050	-0.027	-0.029	0.100		4.04E+01		1.39E+00		0.120	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/29 4:00	-1500	-2100	-0.027	-0.029	0.100		4.04E+01		1.37E+00		0.120	
2011/3/29 7:00	-1500	-2100	-0.027	-0.029	0.100		4.04E+01		1.36E+00		0.100	
2011/3/29 10:00	-1500	-2100	-0.025	-0.027	0.100		4.04E+01		1.35E+00		0.110	
2011/3/29 13:00	-1500	-2100	-0.025	-0.025	0.100		4.05E+01		1.33E+00		0.110	
2011/3/29 16:00	-1500	-2100	-0.025	-0.025	0.100		4.04E+01		1.32E+00		0.120	
2011/3/29 19:00	-1500	-2100	-0.034	-0.032	0.100		4.02E+01		1.31E+00		0.120	
2011/3/29 22:00	-1500	-2100	-0.032	-0.032	0.100		4.01E+01		1.30E+00		0.110	
2011/3/30 1:00	-1500	-2100	-0.025	-0.025	0.100		4.01E+01		1.29E+00		0.100	
2011/3/30 4:00	-1500	-2100	-0.025	-0.025	0.100		4.00E+01		1.28E+00		0.110	
2011/3/30 7:00	-1500	-2100	-0.032	-0.032	0.100		3.99E+01		1.28E+00		0.100	
2011/3/30 10:00	-1500	-2100	-0.032	-0.032	0.100		3.98E+01		1.27E+00		0.110	
2011/3/30 10:30	-1500	-2100	-0.025	-0.027	0.100							
2011/3/30 10:50	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 11:10	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 11:30	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 13:00	-1500	-2100	-0.023	-0.023	0.100		3.96E+01		1.26E+00		0.100	
2011/3/30 14:00	-1500	-2100	-0.025	-0.023	0.100							
2011/3/30 14:20	-1500	-2100	-0.027	-0.025	0.100							
2011/3/30 14:40	-1500	-2050	-0.027	-0.027	0.100							
2011/3/30 15:00	-1500	-2050	-0.027	-0.027	0.100							
2011/3/30 15:20	-1500	-2050	-0.029	-0.027	0.100							
2011/3/30 16:00	-1500	-2050	-0.032	-0.032	0.100		3.95E+01		1.24E+00		0.130	
2011/3/30 18:00	-1500	-2050	-0.029	-0.027	0.100		3.94E+01		1.23E+00		0.130	
2011/3/30 18:30	-1500	-2050	-0.029	-0.027	0.100							
2011/3/30 22:00	-1500	-2050	-0.014	-0.011	0.120		3.92E+01		1.22E+00		0.100	
2011/3/31 0:00	-1500	-2050	-0.027	-0.025	0.110		3.91E+01		1.21E+00		0.110	
2011/3/31 2:00	-1500	-2050	-0.025	-0.025	0.110		3.89E+01		1.21E+00		0.100	
2011/3/31 4:00	-1500	-2050	-0.018	-0.020	0.110		3.87E+01		1.19E+00		0.100	
2011/3/31 6:00	-1500	-2050	-0.014	-0.014	0.110		3.86E+01		1.19E+00		0.110	
2011/3/31 8:00	-1500	-2050	-0.016	-0.018	0.110		3.85E+01		1.17E+00		0.120	
2011/3/31 10:00	-1500	-2050	-0.018	-0.020	0.110		3.84E+01		1.17E+00		0.130	
2011/3/31 12:00	-1500	-2100	-0.011	-0.011	0.110		3.79E+01		1.16E+00		0.110	
2011/3/31 14:00	-1500	-2100	-0.011	-0.011	0.110		3.80E+01		1.16E+00		0.110	
2011/3/31 16:00	-1500	-2100	-0.009	-0.011	0.110		3.79E+01		1.16E+00		0.110	
2011/3/31 18:00	-1500	-2100	-0.011	-0.011	0.110		3.78E+01		1.15E+00		0.110	
2011/3/31 20:00	-1500	-2050	-0.014	-0.016	0.110		3.78E+01		1.15E+00		0.110	
2011/3/31 22:00	-1500	-2050	-0.007	-0.009	0.110		3.77E+01		1.14E+00		0.110	
2011/4/1 0:00	-1500	-2050	-0.014	-0.014	0.110		3.76E+01		1.14E+00		0.110	
2011/4/1 2:00	-1500	-2050	-0.014	-0.014	0.110		3.75E+01		1.14E+00		0.120	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/1 4:00	-1500	-2050	-0.009	-0.009	0.115		3.73E+01		1.13E+00		0.090	
2011/4/1 6:00	-1500	-2050	-0.014	-0.016	0.110		3.72E+01		1.11E+00		0.110	
2011/4/1 8:00	-1500	-2100	-0.014	-0.014	0.110		3.71E+01		1.10E+00		0.120	
2011/4/1 10:00	-1500	-2050	-0.007	-0.009	0.110		3.70E+01		1.09E+00		0.100	
2011/4/1 12:00	-1500	-2050	-0.007	-0.007	0.110		3.69E+01		1.08E+00		0.100	
2011/4/1 16:00	-1500	-2050	-0.005	-0.005	0.115		3.67E+01		1.06E+00		0.110	
2011/4/1 20:00	-1500	-2050	-0.011	-0.014	0.110		3.65E+01		1.04E+00		0.120	
2011/4/2 0:30	-1500	-2050	-0.011	-0.014	0.110		3.63E+01		9.93E-01		0.130	
2011/4/2 4:00	-1500	-2050	-0.011	-0.014	0.110		3.61E+01		9.81E-01		0.130	
2011/4/2 8:00	-1500	-2050	-0.007	-0.009	0.110		3.59E+01		9.72E-01		0.110	
2011/4/2 12:00	-1550	-2100	-0.007	-0.007	0.110		3.57E+01		9.66E-01		0.120	
2011/4/2 16:30	-1500	-2100	-0.011	-0.014	0.110		3.55E+01		9.59E-01		0.130	
2011/4/2 20:00	-1500	-2100	-0.007	-0.009	0.110		3.54E+01		9.53E-01		0.120	
2011/4/2 20:53	-1500	-2100	-0.009	-0.009	0.110							
2011/4/2 21:03	-1500	-2100	-0.007	-0.009	0.110							
2011/4/2 21:23	-1500	-2100	-0.009	-0.009	0.110		3.53E+01		9.50E-01		0.120	
2011/4/2 23:00	-1500	-2100	-0.014	-0.016	0.110		3.53E+01		9.51E-01		0.130	
2011/4/3 3:00	-1500	-2100	-0.016	-0.018	0.105		3.50E+01		9.47E-01		0.100	
2011/4/3 7:00	-1500	-2050	-0.016	-0.020	0.105		3.45E+01		9.39E-01		0.110	
2011/4/3 9:00	-1500	-2050	-0.016	-0.018	0.105		3.43E+01		9.35E-01		0.090	
2011/4/3 10:26	-1500	-2050	-0.018	-0.020	0.105							
2011/4/3 10:42	-1500	-2050	-0.018	-0.018	0.105							
2011/4/3 10:47	-1500	-2050	-0.018	-0.018	0.105							
2011/4/3 10:52			-0.016	-0.018	0.105							
2011/4/3 11:30	-1500	-2050	-0.011	-0.011	0.110		3.43E+01		9.32E-01		0.120	
2011/4/3 12:30	-1450	-1950	-0.011	-0.011	0.110							
2011/4/3 13:00	-1500	-1950	-0.011	-0.011	0.110							
2011/4/3 14:00	-1500	-2050	-0.016	-0.016	0.110		3.39E+01		9.25E-01		0.130	
2011/4/3 18:00	-1500	-2100	-0.011	-0.011	0.105		3.38E+01		9.20E-01		0.100	
2011/4/4 0:00	-1500	-2100	-0.011	-0.014	0.105		3.34E+01		9.11E-01		0.100	
2011/4/4 6:00	-1500	-2100	-0.011	-0.016	0.100		3.30E+01		9.02E-01		0.080	
2011/4/4 11:00	-1500	-2100	-0.018	-0.020	0.100		3.28E+01		8.79E-01		0.090	
2011/4/4 18:00	-1500	-2050	-0.014	-0.016	0.100		3.26E+01		8.86E-01		0.080	
2011/4/5 0:00	-1500	-2050	-0.016	-0.018	0.100		3.24E+01		8.76E-01		0.100	
2011/4/5 6:00	-1500	-2100	-0.018	-0.018	0.100		3.21E+01		8.67E-01		0.090	
2011/4/5 12:00	-1500	-2100	-0.020	-0.023	0.100		3.19E+01		8.58E-01		0.080	
2011/4/5 18:00	-1500	-2100	-0.014	-0.016	0.100		3.17E+01		8.49E-01		0.080	
2011/4/6 0:00	-1500	-2050	-0.018	-0.023	0.100		3.15E+01		8.39E-01		0.080	
2011/4/6 6:00	-1450	-2100	-0.016	-0.020	0.100		3.13E+01		8.33E-01		0.090	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/6 12:00	-1500	-2100	-0.016	-0.018	0.100		3.11E+01		8.25E-01		0.090	
2011/4/6 18:00	-1500	-2100	-0.014	-0.018	0.100		3.10E+01		8.17E-01		0.090	
2011/4/7 0:00	-1500	-2050	-0.011	-0.018	0.100		3.08E+01		8.09E-01		0.070	
2011/4/7 6:00	-1500	-2050	-0.018	-0.025	0.100		3.06E+01		8.01E-01			
2011/4/7 12:00	-1500	-2050	-0.009	-0.016	0.100		3.05E+01		7.94E-01		0.080	
2011/4/7 18:00	-1500	-2050	-0.011	-0.014	0.100		3.03E+01		7.87E-01		0.070	
2011/4/7 19:00	-1500	-2100	-0.011	-0.014	0.100						0.080	
2011/4/7 19:20	-1500	-2100	-0.011	-0.014	0.100							
2011/4/7 19:40	-1500	-2100	-0.011	-0.014	0.100							
2011/4/7 20:00	-1500	-2100	-0.011	-0.014	0.100							
2011/4/7 20:30	-1500	-2100	-0.011	-0.014	0.100							
2011/4/7 21:00	-1500	-2100	-0.011	-0.016	0.100						0.070	
2011/4/7 21:30	-1500	-2100	-0.011	-0.016	0.100							
2011/4/7 22:00	-1500	-2100	-0.011	-0.016	0.100							
2011/4/8 0:00	-1500	-2100	-0.009	-0.014	0.100		3.10E+01		7.81E-01		0.090	
2011/4/8 3:00	-1500	-2100	-0.011	-0.016	0.100		3.00E+01		7.72E-01		0.080	
2011/4/8 6:00	-1500	-2100	-0.016	-0.018	0.100		2.99E+01		7.75E-01		0.090	
2011/4/8 9:00	-1500	-2050	-0.014	-0.018	0.100							
2011/4/8 12:00	-1500	-2100	-0.020	-0.020	0.100		2.94E+01		7.65E-01		0.080	
2011/4/8 15:00	-1500	-2100	-0.018	-0.018	0.095		2.96E+01		7.59E-01		0.080	
2011/4/8 18:00	-1500	-2100	-0.018	-0.020	0.095		2.96E+01		7.56E-01		0.080	
2011/4/8 21:00	-1500	-2100	-0.018	-0.020	0.095		2.95E+01		7.54E-01		0.080	
2011/4/9 0:00	-1500	-2100	-0.018	-0.020	0.095		2.94E+01		7.51E-01		0.100	
2011/4/9 3:00	-1500	-2050	-0.018	-0.023	0.095		2.94E+01		7.50E-01		0.070	
2011/4/9 6:00	-1500	-2050	-0.018	-0.023	0.095		2.93E+01		7.48E-01		0.070	
2011/4/9 9:00	-1500	-2100	-0.018	-0.023	0.095		2.93E+01		7.46E-01		0.080	
2011/4/9 12:00	-1500	-2100	-0.020	-0.025	0.095		2.92E+01		7.43E-01		0.080	
2011/4/9 16:00	-1500	-2100	-0.018	-0.025	0.090		2.91E+01		7.42E-01		0.080	
2011/4/9 18:00	-1500	-2100	-0.018	-0.027	0.095		2.91E+01		7.41E-01		0.070	
2011/4/9 20:00	-1500	-2100	-0.018	-0.025	0.095		2.91E+01		7.41E-01		0.070	
2011/4/9 22:00	-1500	-2100	-0.020	-0.025	0.095		2.90E+01		7.40E-01		0.070	
2011/4/10 0:00	-1500	-2100	-0.020	-0.025	0.090		2.90E+01		7.39E-01		0.077	
2011/4/10 2:00	-1500	-2100	-0.020	-0.025	0.090		2.90E+01		7.39E-01		0.077	
2011/4/10 4:00	-1500	-2050	-0.020	-0.025	0.090		2.90E+01		7.38E-01		0.077	
2011/4/10 6:00	-1450	-2050	-0.020	-0.025	0.095		2.90E+01		7.37E-01		0.120	
2011/4/10 8:00	-1450	-2050	-0.018	-0.025	0.095		2.89E+01		7.35E-01		0.090	
2011/4/10 10:00	-1450	-2050	-0.020	-0.025	0.095		2.89E+01		7.34E-01		0.090	
2011/4/10 12:00	-1500	-2100	-0.020	-0.025	0.095		2.85E+01		7.32E-01		0.070	
2011/4/10 14:00	-1500	-2100	-0.023	-0.025	0.095		2.86E+01		7.31E-01		0.095	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/10 16:00	-1500	-2100	-0.023	-0.025	0.095		2.87E+01		7.30E-01		0.090	
2011/4/10 18:00	-1500	-2050	-0.023	-0.025	0.095		2.87E+01		7.28E-01		0.110	
2011/4/10 20:00	-1500	-2050	-0.023	-0.025	0.090		2.86E+01		7.27E-01		0.110	
2011/4/10 22:00	-1500	-2050	-0.023	-0.025	0.090		2.86E+01		7.26E-01		0.095	
2011/4/11 0:00	-1500	-2050	-0.020	-0.025	0.090		2.86E+01		7.25E-01		0.100	
2011/4/11 2:00	-1500	-2050	-0.025	-0.027	0.090		2.86E+01		7.24E-01		0.100	
2011/4/11 4:00	-1500	-2050	-0.020	-0.025	0.090		2.85E+01		7.22E-01		0.120	
2011/4/11 6:00	-1500	-2050	-0.025	-0.029	0.090		2.85E+01		7.21E-01		0.110	
2011/4/11 12:00	-1500	-2050	-0.020	-0.023	0.095		2.84E+01		7.17E-01		0.120	
2011/4/11 18:30	-1500	-2100	-0.020	-0.023	0.095	0.105	2.80E+01		6.92E-01		0.090	
2011/4/12 0:00	-1500	-2050	-0.023	-0.025	0.090	0.000	2.81E+01		6.85E-01		0.080	
2011/4/12 6:00	-1500	-2100	-0.023	-0.025	0.090		2.81E+01		6.81E-01		0.090	
2011/4/12 13:00	-1500	-2100	-0.027	-0.027	0.085		2.74E+01		6.72E-01		0.080	
2011/4/12 15:00	-1500	-2050	-0.020	-0.025	0.095		2.77E+01		6.72E-01		0.070	
2011/4/12 18:00	-1500	-2050	-0.018	-0.020	0.095		2.78E+01		6.70E-01		0.080	
2011/4/12 23:00	-1500	-2050	-0.023	-0.025	0.095		2.79E+01		6.63E-01		0.085	
2011/4/13 6:00	-1500	-2100	-0.018	-0.023	0.095		2.79E+01		6.56E-01		0.080	
2011/4/13 12:00	-1500	-2050	-0.016	-0.020	0.095		2.79E+01		6.53E-01		0.100	
2011/4/13 18:00	-1500	-2050	-0.016	-0.018	0.095		2.78E+01		6.48E-01		0.080	
2011/4/14 0:00	-1500	-2050	-0.016	-0.020	0.095		2.77E+01		6.45E-01		0.080	
2011/4/14 6:00	-1500	-2050	-0.016	-0.021	0.095		2.76E+01		6.41E-01		0.080	
2011/4/14 12:00	-1500	-2050	-0.016	-0.021	0.090		2.74E+01		6.37E-01		0.090	
2011/4/14 18:00	-1500	-2050	-0.018	-0.020	0.090		2.73E+01		6.33E-01		0.090	
2011/4/15 0:00	-1450	-2050	-0.018	-0.023	0.090		2.71E+01		6.29E-01		0.090	
2011/4/15 6:00	-1450	-2050	-0.018	-0.025	0.090		2.70E+01		6.24E-01		0.090	
2011/4/15 12:00	-1500	-2100	-0.018	-0.023	0.090		2.69E+01		6.20E-01		0.100	
2011/4/15 18:00	-1500	-2050	-0.018	-0.023	0.090		2.68E+01	3.04E+01	6.16E-01	5.62E+01	0.100	
2011/4/16 0:00	-1500	-2100	-0.018	-0.023	0.085		2.66E+01	3.02E+01	6.12E-01	7.00E+01	0.080	
2011/4/16 6:00	-1500	-2100	-0.018	-0.023	0.090		2.65E+01	3.01E+01	6.08E-01	1.33E+02	0.080	
2011/4/16 12:00	-1500	-2100	-0.018	-0.025	0.090		2.64E+01	3.00E+01	6.08E-01	1.35E+02	0.090	
2011/4/16 18:00	-1500	-2100	-0.020	-0.025	0.085		2.63E+01	2.99E+01	6.11E-01	1.27E+02	0.070	
2011/4/17 0:00	-1500	-2100	-0.023	-0.025	0.085		2.62E+01	2.98E+01	6.08E-01	1.13E+02	0.080	
2011/4/17 6:00	-1500	-2100	-0.025	-0.025	0.085		2.61E+01	2.96E+01	6.05E-01	1.18E+02	0.070	
2011/4/17 12:00	-1500	-2100	-0.023	-0.025	0.085		2.60E+01	2.95E+01	6.00E-01	1.21E+02	0.070	
2011/4/17 18:00	-1500	-2100	-0.023	-0.025	0.085		2.59E+01	2.94E+01	5.97E-01	1.08E+02	0.070	
2011/4/18 0:00	-1500	-2100	-0.023	-0.027	0.085		2.58E+01	2.93E+01	5.92E-01	1.08E+02	0.060	
2011/4/18 6:00	-1500	-2100	-0.025	-0.029	0.085		2.57E+01	2.92E+01	5.80E-01	1.01E+02	0.100	
2011/4/18 12:00	-1500	-2100	-0.023	-0.032	0.085		2.56E+01	2.91E+01	5.84E-01	1.01E+02	0.080	
2011/4/18 13:00	-1500	-2100	-0.023	-0.032	0.085		2.56E+01	2.91E+01	5.84E-01	1.01E+02	0.080	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/18 18:00	-1500	-2100	-0.018	-0.027	0.085		2.55E+01	2.90E+01	5.78E-01	8.54E+01	0.070	
2011/4/19 0:00	-1500	-2100	-0.020	-0.029	0.085		2.54E+01	2.89E+01	5.71E-01	9.72E+01	0.080	
2011/4/19 6:00	-1500	-2100	-0.020	-0.029	0.085		2.53E+01	2.88E+01	5.68E-01	1.14E+02	0.080	
2011/4/19 12:00	-1500	-2100	-0.020	-0.029	0.085		2.53E+01	2.87E+01	5.65E-01	1.08E+02	0.070	
2011/4/19 18:00	-1500	-2100	-0.023	-0.027	0.080		2.52E+01	2.86E+01	5.64E-01	9.92E+01	0.070	
2011/4/20 0:00	-1500	-2100	-0.020	-0.027	0.080		2.51E+01	2.85E+01	5.60E-01	8.93E+01	0.100	
2011/4/20 6:00	-1500	-2100	-0.023	-0.029	0.080		2.50E+01	2.84E+01	5.55E-01	1.05E+02	0.080	
2011/4/20 12:00	-1500	-2100	-0.023	-0.029	0.080		2.49E+01	2.83E+01	5.51E-01	1.03E+02	0.090	
2011/4/20 18:00	-1500	-2100	-0.023	-0.029	0.080		2.48E+01	2.81E+01	5.47E-01	1.01E+02	0.080	
2011/4/21 0:00	-1500	-2100	-0.023	-0.029	0.080		2.47E+01	2.81E+01	5.42E-01	1.08E+02	0.080	
2011/4/21 6:00	-1500	-2050	-0.023	-0.029	0.080		2.46E+01	2.80E+01	5.38E-01	1.09E+02	0.080	
2011/4/21 12:00	-1500	-2050	-0.023	-0.025	0.085		2.46E+01	2.79E+01	5.34E-01	1.14E+02	0.050	
2011/4/21 18:00	-1500	-2050	-0.020	-0.025	0.090		2.45E+01	2.78E+01	5.30E-01	1.20E+02	0.065	
2011/4/22 0:00	-1500	-2050	-0.018	-0.023	0.085		2.44E+01	2.77E+01	5.26E-01	1.32E+02	0.072	
2011/4/22 6:00	-1500	-2100	-0.023	-0.027	0.085		2.43E+01	2.76E+01	5.22E-01	1.37E+02	0.065	
2011/4/22 12:00	-1500	-2050	-0.023	-0.027	0.085		2.42E+01	2.75E+01	5.19E-01	1.36E+02	0.080	
2011/4/22 18:00	-1500	-2050	-0.027	-0.034	0.085		2.41E+01	2.74E+01	5.17E-01	1.35E+02	0.060	
2011/4/23 0:00	-1500	-2100	-0.023	-0.027	0.085		2.41E+01	2.73E+01	5.16E-01	1.32E+02	0.080	
2011/4/23 6:00	-1500	-2100	-0.023	-0.027	0.080		2.40E+01	2.70E+01	5.12E-01	1.35E+02	0.070	
2011/4/23 12:00	-1500	-2100	-0.023	-0.025	0.080		2.39E+01	2.68E+01	5.09E-01	1.36E+02	0.070	
2011/4/23 18:00	-1500	-2050	-0.020	-0.023	0.080		2.38E+01	2.67E+01	5.06E-01	1.28E+02	0.100	
2011/4/24 0:00	-1500	-2050	-0.020	-0.020	0.080		2.37E+01	2.66E+01	5.03E-01	1.26E+02	0.100	
2011/4/24 6:00	-1500	-2050	-0.020	-0.025	0.080		2.36E+01	2.65E+01	5.00E-01	1.10E+02	0.100	
2011/4/24 12:00	-1500	-2050	-0.018	-0.025	0.080		2.36E+01	2.65E+01	4.97E-01	1.15E+02	0.080	
2011/4/24 18:00	-1500	-2050	-0.020	-0.025	0.080		2.35E+01	2.64E+01	4.96E-01	1.07E+02	0.070	
2011/4/25 0:00	-1500	-2100	-0.020	-0.027	0.080		2.34E+01	2.63E+01	4.93E-01	1.19E+02	0.060	
2011/4/25 6:00	-1450	-2100	-0.020	-0.027	0.080		2.33E+01	2.62E+01	4.90E-01	1.03E+02	0.060	
2011/4/25 11:00	-1500	-2100	-0.020	-0.025	0.080		2.32E+01	2.61E+01	4.89E-01	9.41E+01	0.050	
2011/4/25 17:00	-1500	-2100	-0.018	-0.025	0.080		2.32E+01	2.60E+01	4.86E-01	9.86E+01	0.070	
2011/4/25 23:00	-1500	-2100	-0.020	-0.025	0.080		2.31E+01	2.60E+01	4.83E-01	1.05E+02	0.050	
2011/4/26 5:00	-1500	-2100	-0.020	-0.025	0.080		2.30E+01	2.59E+01	4.80E-01	1.04E+02	0.060	
2011/4/26 11:00	-1500	-2050	-0.016	-0.025	0.080		2.29E+01	2.58E+01	4.77E-01	7.64E+01	0.070	
2011/4/26 17:00	-1500	-2100	-0.018	-0.025	0.080		2.28E+01	2.57E+01	4.76E-01	1.06E+02	0.080	
2011/4/26 23:00	-1500	-2100	-0.020	-0.027	0.075		2.27E+01	2.56E+01	4.74E-01	5.77E+01	0.080	
2011/4/27 5:00	-1500	-2100	-0.018	-0.023	0.080		2.27E+01	2.56E+01	4.72E-01	4.33E+01	0.080	
2011/4/27 11:00	-1500	-2100	-0.018	-0.025	0.075		2.26E+01	2.55E+01	4.70E-01	4.59E+01	0.060	
2011/4/27 17:00	-1500	-2100	-0.020	-0.023	0.075		2.25E+01	2.54E+01	4.67E-01	4.33E+01	0.050	
2011/4/27 23:00	-1500	-2100	-0.018	-0.020	0.075		2.25E+01	2.53E+01	4.65E-01	4.19E+01	0.080	
2011/4/28 5:00	-1500	-2100	-0.016	-0.020	0.075		2.24E+01	2.52E+01	4.63E-01	4.08E+01	0.080	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/28 11:00	-1500	-2100	-0.020	-0.023	0.075		2.23E+01	2.52E+01	4.61E-01	3.97E+01	0.040	
2011/4/28 17:00	-1500	-2100	-0.020	-0.020	0.075		2.23E+01	2.51E+01	4.60E-01	3.83E+01	0.070	
2011/4/28 23:00	-1500	-2100	-0.020	-0.023	0.075		2.22E+01	2.50E+01	4.56E-01	3.74E+01	0.060	
2011/4/29 5:00	-1500	-2100	-0.023	-0.023	0.075		2.21E+01	2.49E+01	4.54E-01	3.59E+01	0.080	
2011/4/29 11:00	-1500	-2100	-0.020	-0.023	0.075		2.21E+01	2.48E+01	4.52E-01	3.71E+01	0.080	
2011/4/29 17:00	-1500	-2100	-0.025	-0.025	0.075		2.20E+01	2.48E+01	4.49E-01	3.61E+01	0.070	
2011/4/29 23:00	-1500	-2100	-0.025	-0.023	0.075		2.20E+01	2.47E+01	4.47E-01	3.85E+01	0.070	
2011/4/30 5:00	-1500	-2100	-0.025	-0.025	0.075		2.19E+01	2.46E+01	4.44E-01	4.52E+01	0.070	
2011/4/30 11:00	-1500	-2100	-0.023	-0.020	0.075		2.18E+01	2.46E+01	4.42E-01	4.56E+01	0.080	
2011/4/30 17:00	-1500	-2100	-0.020	-0.020	0.075		2.18E+01	2.45E+01	4.39E-01	4.49E+01	0.030	
2011/4/30 23:00	-1500	-2100	-0.020	-0.020	0.075		2.17E+01	2.44E+01	4.37E-01	4.62E+01	0.050	
2011/5/1 5:00	-1500	-2100	-0.023	-0.020	0.075		2.17E+01	2.44E+01	4.34E-01	4.64E+01	0.040	
2011/5/1 11:00	-1500	-2100	-0.020	-0.020	0.075		2.16E+01	2.43E+01	4.32E-01	4.22E+01	0.050	
2011/5/1 17:00	-1500	-2100	-0.020	-0.016	0.075		2.16E+01	2.42E+01	4.31E-01	4.33E+01	0.042	
2011/5/1 23:00	-1500	-2100	-0.018	-0.018	0.070		2.15E+01	2.42E+01	4.29E-01	3.98E+01	0.045	
2011/5/2 5:00	-1500	-2100	-0.023	-0.018	0.070		2.14E+01	2.41E+01	4.27E-01	3.91E+01	0.050	
2011/5/2 11:00	-1500	-2100	-0.020	-0.018	0.070		2.14E+01	2.41E+01	4.26E-01	4.13E+01	0.042	
2011/5/2 17:00	-1500	-2100	-0.020	-0.018	0.070		2.13E+01	2.40E+01	4.25E-01	4.33E+01	0.040	
2011/5/2 23:00	-1500	-2100	-0.020	-0.018	0.070		2.13E+01	2.39E+01	4.23E-01	4.50E+01	0.040	
2011/5/3 5:00	-1500	-2100	-0.020	-0.018	0.070		2.12E+01	2.39E+01	4.21E-01	4.35E+01	0.040	
2011/5/3 11:00	-1500	-2100	-0.023	-0.018	0.070		2.12E+01	2.38E+01	4.19E-01	4.72E+01	0.040	
2011/5/3 17:00	-1500	-2100	-0.023	-0.016	0.070		2.11E+01	2.37E+01	4.17E-01	4.94E+01	0.050	
2011/5/3 23:00	-1500	-2100	-0.023	-0.016	0.065		2.10E+01	2.37E+01	4.15E-01	4.63E+01	0.050	
2011/5/4 5:00	-1500	-2100	-0.023	-0.018	0.065		2.10E+01	2.36E+01	4.13E-01	5.34E+01	0.040	
2011/5/4 11:00	-1500	-2100	-0.020	-0.016	0.065		2.09E+01	2.36E+01	4.11E-01	5.58E+01	0.040	
2011/5/4 17:00	-1500	-2100	-0.020	-0.016	0.065		2.09E+01	2.35E+01	4.10E-01	5.97E+01	0.050	
2011/5/4 23:00	-1500	-2100	-0.023	-0.018	0.065		2.08E+01	2.35E+01	4.08E-01	6.97E+01	0.050	
2011/5/5 5:00	-1500	-2100	-0.023	-0.018	0.065		2.07E+01	2.34E+01	4.06E-01	7.66E+01	0.050	
2011/5/5 11:00	-1500	-2100	-0.023	-0.018	0.065		2.07E+01	2.33E+01	4.05E-01	8.35E+01	0.040	
2011/5/5 17:00	-1500	-2100	-0.023	-0.018	0.065		2.06E+01	2.33E+01	4.03E-01	9.52E+01	0.040	
2011/5/5 23:00	-1500	-2100	-0.023	-0.018	0.065		2.06E+01	2.32E+01	4.02E-01	1.06E+02	0.050	
2011/5/6 5:00	-1500	-2100	-0.023	-0.018	0.065		2.05E+01	2.32E+01	4.00E-01	1.18E+02	0.050	
2011/5/6 11:00	-1500	-2100	-0.020	-0.020	0.065		2.05E+01	2.31E+01	3.99E-01	1.30E+02	0.040	
2011/5/6 17:00	-1500	-2100	-0.020	-0.018	0.065		2.04E+01	2.30E+01	3.97E-01	1.37E+02	0.040	
2011/5/6 23:00	-1500	-2100	-0.020	-0.018	0.065		2.04E+01	2.30E+01	3.95E-01	1.33E+02	0.040	
2011/5/7 5:00	-1500	-2100	-0.018	-0.020	0.065		2.03E+01	2.29E+01	3.93E-01	1.30E+02	0.040	
2011/5/7 11:00	-1500	-2100	-0.020	-0.018	0.065		2.03E+01	2.29E+01	3.91E-01	1.35E+02	0.040	
2011/5/7 17:00	-1500	-2100	-0.020	-0.018	0.060		2.03E+01	2.28E+01	3.90E-01	1.45E+02	0.040	
2011/5/7 23:00	-1500	-2100	-0.023	-0.018	0.060		2.01E+01	2.27E+01	3.88E-01	1.48E+02	0.050	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/5/8 5:00	-1500	-2100	-0.020	-0.018	0.060		2.01E+01	2.27E+01	3.86E-01	1.48E+02	0.050	
2011/5/8 11:00	-1500	-2100	-0.020	-0.018	0.060		2.00E+01	2.26E+01	3.86E-01	1.40E+02	0.050	
2011/5/8 17:00	-1500	-2100	-0.020	-0.016	0.060		2.00E+01	2.26E+01	3.84E-01	1.38E+02	0.050	
2011/5/8 23:00	-1500	-2100	-0.020	-0.018	0.060		2.00E+01	2.25E+01	3.83E-01	1.32E+02	0.050	
2011/5/9 5:00	-1500	-2100	-0.023	-0.020	0.060		1.99E+01	2.25E+01	3.82E-01	1.28E+02	0.055	
2011/5/9 11:00	-1500	-2100	-0.020	-0.018	0.060	0.190	1.99E+01	2.24E+01	3.80E-01	1.24E+02	0.040	
2011/5/9 17:00	-1500	-2100	-0.023	-0.020	0.060		1.98E+01	2.23E+01	3.79E-01	1.22E+02	0.035	
2011/5/9 23:00	-1500	-2100	-0.020	-0.014	0.060		1.98E+01	2.23E+01	3.78E-01	1.18E+02	0.036	
2011/5/10 5:00	-1500	-2100	-0.020	-0.016	0.060		1.97E+01	2.22E+01	3.76E-01	1.17E+02	0.035	
2011/5/10 11:00	-1500	-2100	-0.020	-0.016	0.060		1.97E+01	2.22E+01	3.76E-01	1.20E+02	0.040	
2011/5/10 17:00	-1500	-2100	-0.023	-0.016	0.055		1.96E+01	2.21E+01	3.74E-01	1.13E+02	0.035	
2011/5/10 23:00	-1500	-2100	-0.020	-0.018	0.060		1.96E+01	2.21E+01	3.72E-01	1.10E+02	0.040	
2011/5/11 5:00	-1500	-2100	-0.023	-0.018	0.060		1.95E+01	2.20E+01	3.70E-01	1.06E+02	0.035	
2011/5/11 11:00	-1500	-2100	-0.023	-0.018	0.060		1.95E+01	2.20E+01	3.68E-01	1.01E+02	0.037	
2011/5/11 17:00	-1500	-2100	-0.023	-0.020	0.060		1.95E+01	2.19E+01	3.69E-01	1.02E+02	0.040	
2011/5/11 23:00	-1500	-2100	-0.023	-0.020	0.060		1.94E+01	2.19E+01	3.68E-01	9.85E+01	0.060	
2011/5/12 5:00	-1500	-2100	-0.023	-0.020	0.055		1.94E+01	2.18E+01	3.67E-01	9.29E+01	0.040	
2011/5/12 11:00	-1500	-2100	-0.023	-0.018	0.055		1.93E+01	2.17E+01	3.66E-01	9.02E+01	0.035	
2011/5/12 17:00	-1500	-2100	-0.023	-0.018	0.055		1.93E+01	2.16E+01	3.64E-01	8.76E+01	0.040	
2011/5/12 23:00	-1500	-2100	-0.023	-0.018	0.055		1.92E+01	2.16E+01	3.63E-01	8.58E+01	0.045	
2011/5/13 5:00	-1500	-2100	-0.018	-0.018	0.055		1.92E+01	2.15E+01	3.61E-01	8.24E+01	0.030	
2011/5/13 11:00	-1500	-2100	-0.018	-0.016	0.055		1.91E+01	2.15E+01	3.60E-01	8.17E+01	0.040	
2011/5/13 17:00	-1500	-2100	-0.020	-0.016	0.055		1.91E+01	2.15E+01	3.58E-01	8.02E+01	0.040	
2011/5/13 23:00	-1500	-2100	-0.023	-0.018	0.055		1.90E+01	2.14E+01	3.57E-01	7.70E+01	0.040	
2011/5/14 5:00	-1500	-2100	-0.023	-0.018	0.055		1.90E+01	2.14E+01	3.56E-01	7.21E+01	0.040	
2011/5/14 11:00	-1500	-2100	-0.023	-0.020	0.055		1.90E+01	2.13E+01	3.53E-01	7.61E+01	0.040	
2011/5/14 17:00	-1500	-2100	-0.025	-0.018	0.055		1.89E+01	2.13E+01	3.52E-01	7.28E+01	0.040	
2011/5/14 23:00	-1500	-2100	-0.023	-0.020	0.055		1.89E+01	2.12E+01	3.50E-01	7.19E+01	0.040	
2011/5/15 5:00	-1500	-2100	-0.023	-0.020	0.055		1.88E+01	2.12E+01	3.49E-01	7.00E+01	0.040	
2011/5/15 11:00	-1500	-2100	-0.023	-0.020	0.055		1.88E+01	2.11E+01	3.47E-01	6.84E+01	0.030	
2011/5/15 17:00	-1500	-2100	-0.018	-0.020	0.055		1.88E+01	2.11E+01	3.47E-01	6.58E+01	0.030	
2011/5/15 23:00	-1500	-2100	-0.020	-0.020	0.055		1.87E+01	2.10E+01	3.45E-01	6.50E+01	0.030	
							measurement instrument malfunction					

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Safety Relief Valve Leakage Detector RV-2-71A	Main Steam Isolation Valve Leakage Detector 2-86A	Feedwater Nozzle N-4B	ORD Housing Upper Part	Reactor Pressure Vessel Botom Head	Reactor Pressure Vessel Supporting Skirt Upper Part	Reactor Pressure Vessel Drain Pipe Upper Part	D/W HVH Return Air Duct (HVH-16A)	RPV Bellows Air	Reactor Supression Chamber Gas	S/C Pool Water A	S/C Pool Water B	note
3/20 22:00	150	49	108		120			105					
3/21 3:00	146	42	100		115			100					
3/21 8:00	150	45	105		115			105					
3/21 13:30	150	50	110		120			110					
3/21 14:00	140	50	110		110			100					
3/21 14:25	150	50	110		120			100					
3/22 0:15	146	47	101		109			102					
3/22 5:00	145	50	110		110			110					
3/22 6:00	145	45	100		110			101					
3/22 10:30	140	47	105		107			101					
3/22 11:20	142	47	105		109			103					
3/22 15:30	140	45	100		105			100					
3/22 17:00	142	46	102		111			100					
3/22 18:00	140	44	102		102			99					
3/22 23:00	142	47	105		105			100					
3/23 4:20	140	50	102		109			105					
3/23 9:00	140	47	105		105			101					
3/23 14:00	138	46	101		102			100					
3/23 21:00	134	45	100		103			96					
3/24 1:00	138	49	102		109			101					
3/24 5:00	135	49	100		109			96					
3/24 9:00	134	45	100		105			96					
3/24 13:00	130	50	100		110			100					
3/24 17:00	135	47	100		105			100					
3/24 20:00	130	42	100		105			95					
3/24 22:00	130	47	100		110			100					
3/24 22:30	130	45	101		109			100					
3/25 0:00	130	45	104		109			100					
3/25 2:00	135	45	105		105			100					
3/25 6:00	135	45	105		105			101					
3/25 10:00	135	45	107		105			104					
3/25 14:00	135	45	107		104			104					
3/25 18:30	132	42	107		94			99					
3/25 23:00	137	47	109		100			100					
3/26 9:30	137	50	107		100			104					
3/26 10:21	137	50	107		100			104					
3/26 10:40	137	47	107		100			104					
3/26 13:00	136	47	107		99			103					
3/26 17:30	148.1	63.6	121.8		111.1			106					
3/26 17:50	150.1	63.5	121.9		111.1			106					
3/26 18:00	150.1	63.5	122		111.1			106					
3/26 18:10	150.1	63.5	122		111.1			106					
3/26 18:30	150.2	63.6	122.1		111.2			106					
3/26 19:00	150.2	63.6	122.2		111.4			106					
3/26 21:00	150.7	63.7	123		111			103					
3/27 1:00	151.6	63.8	123.9		111.2			106					
3/27 5:00	151.6	63.7	123.9	123.3	96.6			106					
3/27 9:00	151.4	63.7	123.6	122.9	111.2			104					
3/27 15:30	150.8	63.8	123.2	122.6	123.4			119					
3/27 16:20	150.8	63.8	123.1	122.5	128.3			119					
3/27 17:50	150.6	63.8	123	122.4	97.3			118					
3/27 20:20	150.7	63.8	123.6	122.9	93			119					
3/27 22:00	151.5	63.8	124.6	123.9	88.4			119					
3/28 0:00	152.1	63.8	124.8	124.1	84.4			119					
3/28 0:55	152.4	63.8	125.5	124.8	84.4			120					
3/28 3:00	154.5	63.8	129	128.2	84			121					
3/28 3:30	154.9	63.8	129.6	128.7	82			121					
3/28 4:00	154.3	63.8	130.3	129.4	81.5			121					
3/28 7:00	158.7	63.7	135.4	134.5	76.8			124					
3/28 12:30	166.3	63.7	144.1	142.9	60			131					
3/28 17:30	171.9	63.4	148.3	147	67.3			136					
3/28 21:00	176.3	63.5	149.5	148.2	101.5			139					
3/29 1:00	180.9	63.4	152	150.7	71.4			142					
3/29 4:00	184.7	63.3	153.7	152.6	77.7			144.5					
3/29 7:00	188.5	63.2	156.2	154.9	120			147.5					
3/29 10:00	191.9	63.2	158.5	157.2	120.3			150					
3/29 13:00	195.4	63.2	160.5	161.6	143.6			152					

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Safety Relief Valve Leakage Detector RV-2-71A	Main Steam Isolation Valve Leakage Detector 2-86A	Feedwater Nozzle N-4B	CRD Housing Upper Part	Reactor Pressure Vessel Botom Head	Reactor Pressure Vessel Supporting Skirt Upper Part	Reactor Pressure Vessel Drain Pipe Upper Part	D/W HVH Return Air Duct (HVH-16A)	RPV Bellows Air	Reactor Supression Chamber Gas	S/C Pool Water A	S/C Pool Water B	note
3/29 16:00	198.6	63.7	198.2	-126.8	141.6			154					Instrument failure - temperature at upper CRD housing
3/29 17:30	200		164.7										
3/29 19:00	201.4	63.3	166.3	105.5	85.7			156					
3/29 22:00	204	63.3	167.4	140.5	80.8			158					
3/30 1:00	206.3	63.3	168.6	126.3	82.2			160					
3/30 4:00	208.9	63	170.7	-126.2	87.7			162					
3/30 7:00	211.4	63.2	172.4	-126	131.6			163.5					
3/30 10:00	212.6	63.3	172.9	-126	110.7			164					
3/30 10:30	212.8	63.3	173	-126	112.8			164					
3/30 10:50	212.9	63.3	173	-99.2	114.6			164					
3/30 11:10	213	63.2	173	-125.9	117.2			164					
3/30 11:30	213.3	63.3	173.3	-125.6	119.1			164					
3/30 13:00	215	63.3	174.3	-125.9	-125.7			165					Instrument failure - temperature at PPV bottom
3/30 14:00	215.8	63.4	186.5	-125.9	-125.7			169					
3/30 14:20	215.4	63.3	180.2	-125.8	-125.6			169					
3/30 14:40	214.9	63.3	179.9	-125.8	-125.6			168					
3/30 15:00	214.4	63.4	179.7	-125.7	-125.6			168					
3/30 15:20	214	63.4	179.5	-125.7	-102.3			168					
3/30 16:00	213.5	63.4	179.6	-125.7	-45.2			168					
3/30 18:00	214.6	63.5	180.6	-125.6	-125.5			168					
3/30 18:30	214.9	63.5	180.7	-125.6	-125.5			168					
3/30 22:00	218.2	63.6	184.9	-125.5	30.6			173.5					
3/31 0:00	217.2	63.6	183	228.3	-125.3			172					
3/31 2:00	217.1	63.6	183.4	561.6	-125.2			172.5					
3/31 4:00	216.8	63.7	181.2	561.7	-125.2			171					
3/31 6:00	211.8	63.8	178.7	561.7	-125.1			168					
3/31 8:00	209.4	63.9	175.3	561.7	-125			164					
3/31 10:00	207.2	64	173.4	556.6	-124.9			162					
3/31 12:00	207.1	64	172.4	561.7	-124.9			162					
3/31 14:00	208.1	64.2	172.2	561.7	-125			162					
3/31 16:00	207.7	64.2	172	230.7	-125			162					
3/31 18:00	207.3	64.3	171.5	215.2	-124.9			162					
3/31 20:00	207.1	64.3	169	204.6	-124.8			162					
3/31 22:00	206.2	64	168	193.3	-124.7	279	197	161		99			
4/1 0:00	205.4	64	167	222.1	-124.6	278	196	160		100			
4/1 2:00	203.6	64.4	165.3	220.6	-124.5	284.8	194.7	159		100			
4/1 4:00	201.9	64.4	164.4	208.9	-124.4	283.1	194.5	158		100			
4/1 6:00	200.5	64.4	163.5	219.4	-124.4	281.1	193.3	157		99			
4/1 8:00	199	64.5	162.1	208.7	-124.3	270.7	192	156		100			
4/1 10:00	197.7	64.6	161	219.3	-124.5	277.7	190.7	155		100			
4/1 12:00	196.3	64.7	160.1	198.2	-124.5	265.3	189.5	154		100			
4/1 16:00	193.7	64.7	158.1	210.8	-125.3	258.9	187.1	152		100			
4/1 20:00	191.7	64.8	156.9	194.1	-114	265	185.9	150		100			
4/2 0:30	189.8	64.8	156.1	190.6	-61.4	251.9	184.4	149		100			
4/2 4:00	188.3	64.9	155	179.4	-30.6	259.4	183.1	148		99			
4/2 8:00	186.6	64.9	153.7	174.9	41.3	243.8	181.6	146		99			
4/2 12:00	185.3	65	152.9	185.3	81.1	251.7	180.3	146		99			
4/2 16:30	183.9	64.9	151.9	232.5	88.1	253.7	179.3	144.5		99	98.9		
4/2 20:00	183.6	64.8	151.3	164.5	112.4	248.6	178.2	144		99	98.8		
4/2 21:23	183.4	64.8	151.1	162.9	114.8	241.4	177.7	144		99	98.7		
4/2 23:00	183.5	64.8	151.7	164.8	125.6	244.2	177.8	144		99	98.5		
4/3 3:00	185	64.9	153.4	159.2	144	252.1	178.5	145		99	98.1		
4/3 7:00	185.6	64.8	151	157.6	148.9	258.6	177.9	142		98	98.1		
4/3 9:00	185.4	64.8	150.5	157	146.1	254	176.8	141		98	97.6		
4/3 11:30	186.6	64.8	152.3	161.1	134.9	258.4	177.1	143		98	98.5		
4/3 14:00	170.3	64.9	144.5	148.1	130	245.7	173.8	138		98	98.5		
4/3 18:00	165.8	64.9	143.6	145.4	132.3	247.7	172.6	135		98	98.5		
4/4 0:00	163	64.9	140.3	141.6	138.2	251.7	170.6	127		98	98.3		
4/4 6:00	161.5	64.8	138.8	139.6	129.5	249.3	168.5	124		98	98.1		
4/4 11:00	162.1	64.7	139	139.6	127.7	251.8	169	124		98	97.9		
4/4 18:00	163	64.7	140.5	140.8	115.2	256.3	166.4	125		98	97.6		
4/5 0:00	164.2	64.7	141.7	141.2	110.5	258.9	166.4	124		98	97.4		
4/5 6:00	164.3	64.6	141.7	146.2	133.7	263	166	126		97	97.3		
4/5 12:00	163.1	64.7	140.3	143.9	124.7	252.7	164.1	126		98	97.2		
4/5 18:00	163.4	64.8	140.7	141.1	118.7	254.9	165.2	126		97	97		

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Safety Relief Valve Leakage Detector RV-2-71A	Main Steam Isolation Valve Leakage Detector 2-86A	Feedwater Nozzle N-4B	ORD Housing Upper Part	Reactor Pressure Vessel Botom Head	Reactor Pressure Vessel Supporting Skirt Upper Part	Reactor Pressure Vessel Drain Pipe Upper Part	D/W HVH Return Air Duct (HVH-16A)	RPV Bellows Air	Reactor Suppression Chamber Gas	S/C Pool Water A	S/C Pool Water B	note
4/6 0:00	163.6	64.7	140.9	142.6	139.6	257.5	164.5	127		97	97		
4/6 6:00	163.5	64.7	141.6	111.8	137.7	257.3	131.1	127		97	96.7		
4/6 12:00	164.1	64.8	142.5	124.4	119.6	262.2	165.3	128		97	96.8		
4/6 18:00	165	64.8	143.6	124.4	111.8	257.7	165.7	129		97	96.6		
4/7 0:00	165.6	64.8	144.2	127.6	57.8	259.6	166.8	130		97	96.6		
4/7 6:00	165.5	64.8	144.2	138.2	23	253.5	166.8	130		97	96.5		
4/7 12:00	164.2	64.9	143.6	134.3	23.6	149.3	167.5	129		98	96.6		
4/7 18:00	162.3	65	141.5	132.5		147.7	165.7	128		96	96.5		
4/7 19:00	162	65	141.4	131	1.5	175	165.5	128			96.3		
4/7 19:20	161.9	65	141.3	126.4		277.7	165.5	128		96	96.2		
4/7 19:40	161.9	65	141.2	126.4		287.1	165.5	128		96	96.2		
4/7 20:00	161.8	65	141.2	126.4		283.3	165.4	128		96	96.1		
4/7 20:30	161.7	65	141.2	127.6		288.6	165.4	128		96	96.1		
4/7 21:00	161.5	65	141	124.3	-6.5	279.6	165.3	128		97	96		
4/7 21:30	161.5	65	141			273.8	165.3	128			95.9		
4/7 22:00	161.5	65	141			282.6	165.3	128			95.8		
4/8 0:00	160.6	65	143.3	148	33.7	276.6	170.3	128		97	96.6		
4/8 3:00	158.5	65	143			251.5	154.3	128			96		
4/8 6:00	158.8	65	143.9	127.2	74.8	141.7	153.9	128		96	94.6		
4/8 9:00	159	65	143.6			252.4	151.6	128.5			93.7		
4/8 12:00	157.9	65	141.2	50	130.1	259.9	154.7	128		96	92.8		
4/8 15:00	157.2	65	140.3			121	253.1	156.8	126		92.1		
4/8 18:00	157.9	64.9	140.3	-7.3	131.4	264.2	165.2	126		95	91.4		
4/8 21:00	158.1	64.9	140.5			137.1	257.9	164.1	127		90.9		
4/9 0:00	159.8	64.8	141.5	-66.3	177.2	267.5	163.7	128		96	90.3		
4/9 3:00	160.4	64.7	142.5			187.1	261.1	129			89.8		
4/9 6:00	161.1	64.7	143	-27.3	150.9	262.3	165.2	130		95	89.3		
4/9 9:00	162.6	64.6	143.9			135.9	259.8	132		95	88.9		
4/9 12:00	163.5	64.6	144.5	60.8	126.4	253.6	166.7	132		95	88.5		
4/9 16:00	164.8	64.6	145.5			144.5	255.6	167.6			88		
4/9 18:00	165.5	64.6	146	118.4	142.8	255.7	162.4	134		95	87.7		
4/9 20:00	166.7	64.6	147.1			138.2	261	157	134		87.5		
4/9 22:00	167.4	64.6	148.3			140.2	261.3	173.5	135		87.2		
4/10 0:00	167.9	64.5	149.7	162.1	139.1	261.8	174.4	136		95	86.9		
4/10 2:00	167.8	64.5	149.2			140.8	264.4	173	137		86.7		
4/10 4:00	167.8	64.5	149.2			140.1	257.7	170.4	137		86.5		
4/10 6:00	168.3	64.5	149.4	194.2	143.8	152.1	167.8	138		95	86.2		
4/10 8:00	168.4	64.5	149.5			142	151.5	168.1	136		86		
4/10 10:00	168.8	64.5	149.6			144.3	158	168.6	138		85.8		
4/10 12:00	168.9	64.5	150	240.3	142.8	161.1	162.9	138		94	85.5		
4/10 14:00	169.2	64.5	150.5			146.4	161.6	169.9	139		85.3		
4/10 16:00	169.9	64.5	151			145.7	161.4	170.6	139.5		85.1		
4/10 18:00	170.3	64.5	151.4	279.1	145.8	152.5	171.2	140		94	84.9		
4/10 20:00	170.7	64.5	151.9			142.3	158.8	171.8	140		84.8		
4/10 22:00	171.2	64.4	152.3			132.4	162.6	172.4	140.5		84.6		
4/11 0:00	171.5	64.4	152.6	319.9	130.1	157.5	172.9	141		94	84.4		
4/11 2:00	171.2	64.4	152.8			131.3	156.1	173.2	141		84.2		
4/11 4:00	171.5	64.4	153.2			152.9	160.3	173.6	142		84.1		
4/11 6:00	172.3	64.5	153.6	390.5	169.2	157.4	173.9	142		94	83.9		
4/11 12:00	173.4	64.5	154.8	446.6	201.9	158.1	175.3	143		94	83.5		
4/11 18:30	172.5	64.4	156	493.8	226.4	161.9	189	144		93	81.5		
4/12 0:00	171.6	64.2	156.2	498.2	225.2	163.9	185.2	144		94	81.4		
4/12 6:00	176.3	63.9	165.8	564.6	208.1	170.9	265.5	151		93	84.6		
4/12 8:00			165.6	564.6	206.9	169.1	266.7						
4/12 13:00	176.7	63.4	165.9	563.4	193.2	172	258.2	152		92	82.9		
4/12 15:00	178.3	64	167.6	564.2	186.3	176.1	258.4	153		94	82.8		
4/12 18:00	186.5	64.2	171.7	564.4	187.1	183.5	191.5	162		92	87		
4/12 23:00	187.5	64.4	169.7	564.6	193.3	176.3	118.6	159		92	85.1		
4/13 6:00	190.2	64.4	170.1	564.7	183.2	177.1	118.1	160		93	83.9		
4/13 12:00	186.2	64.7	166.9	291.6	69.1	172.3	122	156		94	83.3		
4/13 18:00	182.4	65	163.2	477.2	-9.2	168.2	118.6	152		94	82.8		
4/14 0:00	178.7	65.1	159.7	418.4	-104.7	163.8	120.7	148		94	82.4		
4/14 6:00	175.3	65.2	156.8	395.2	-116.3	160.8	118.3	146		94	82.3		
4/14 12:00	172.3	65.3	154.1	309.6	-116.3	157.9	119.2	144		94	82		
4/14 18:00	169.4	65.4	151.8	258.4	-116.2	155.8	118	141		94	81.7		
4/15 0:00	167.5	65.4	150	164.6	-116	154	116.5	139		94	81.3		
4/15 6:00	165.7	65.4	148.2	148.8	-115.9	152.1	118.6	138		94	81		
4/15 12:00	164.1	65.5	146.6	255.6	-115.8	150.4	116.7	136		94	80.6		
4/15 18:00	162.8	65.6	145.7	322.4	-115.7	149.4	116.7	135		94	80.3		

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Safety Relief Valve Leakage Detector RV-2-71A	Main Steam Isolation Valve Leakage Detector 2-86A	Feedwater Nozzle N-4B	ORD Housing Upper Part	Reactor Pressure Vessel Bottom Head	Reactor Pressure Vessel Supporting Skirt Upper Part	Reactor Pressure Vessel Drain Pipe Upper Part	D/W HVH Return Air Duct (HVH-16A)	RPV Bellows Air	Reactor Suppression Chamber Gas	S/C Pool Water A	S/C Pool Water B	note
4/16 0:00	161.2	65.6	144.3	328.8	-115.5	147.8	116.7	134		94	79.9		
4/16 6:00	159.5	65.6	142.8	324.2	-115.3	146.3	114.8	132		94	79.5		
4/16 12:00	158.6	65.6	141.6	316.4	-115.3	145	117.1	131		94	79.1		
4/16 18:00	158.7	65.4	141.6	119.7	-115.2	144.9	119.9	131		94	78.6		
4/17 0:00	159	65.4	142	227.1	-115.1	145.1	121.3	132		94	78.1		
4/17 6:00	158.9	65.3	141.5	64.6	-115	144.7	119.8	132		94	77.6		
4/17 12:00	158.5	65.4	141.1	76.1	-114.8	144.1	119.9	131		94	77	77.4	
4/17 18:00	158.8	65.4	141.5	99.5	-114.8	144.4	121.4	132		94	76.5	77	
4/18 0:00	158.5	65.4	141.7	3.7	-114.6	144.5	121.3	132		94	76.1	76.4	
4/18 6:00	158.6	65.3	141.8	-9.8	-114.5	144.6	119.5	132		93	75.6	76	
4/18 12:00	158.2	65.4	140.9	-14.4	-114.9	143.7	120.3	132		93	75.2	75.5	
4/18 13:00			140.8	-3.8	-114.7	143.6	121.4				75.2	75.5	
4/18 18:00	156.5	65.4	140	-14.4	-114.4	196.6	120	130		93	74.9	75.2	
4/19 0:00	154.1	65.4	138.2	-35.7	-114.3	193	117.1	129		93	74.6	74.9	
4/19 6:00	152	65.4	136.5	-71.1	-114.2	189.9	123.3	128		94	74.5	74.8	
4/19 12:00	149.9	65.6	135.4	-114.6	-114.4	187.9	127.8	127		93	74.4	74.8	
4/19 18:00	147.9	65.7	134.6	-114.7	-114.4	182.5	127.5	126		93	74.4	74.8	
4/20 0:00	147.5	65.1	133.4	123	-114.1	137.1	126.2	124		93	74.3	74.6	
4/20 6:00	151	65.2	133.6	118.4	-114	136.9	125.8	122		93	74	74.3	
4/20 12:00	153.9	65.2	134.7	125.2	-114	137.6	126.2	123		92	73.7	74	
4/20 18:00	155.3	65.4	135.5	130	-114.1	138.5	126.9	124		93	73.4	73.7	
4/21 0:00	156.2	65.3	136	132.1	-114.1	138.7	127.2	126		93	73.2	73.5	
4/21 6:00	155.9	65.2	136.1	130.9	-114.1	138.8	128.4	126		93	72.9	73.2	
4/21 12:00	156.2	65.3	136	129.4	-114.2	138.7	128.4	126		93	72.8	73	
4/21 18:00	153.8	65.5	134.6	124.4	-114.3	137.2	127.6	125		94	72.6	72.9	
4/22 0:00	151.2	65.5	133.1	-54	-114.3	135.9	126.7	124		94	72.6	72.9	
4/22 6:00	146.1	65.7	131.2	123.9	-114.2	134.4	125.5	122		93	72.5	72.8	
4/22 12:00	141.8	65.7	129.2	-48.2	-114	132.4	124.4	120		93	72.4	72.7	
4/22 18:00	140.7	65.7	128.8	-20.8	-114	131.7	120.4	118		93	72.3	72.6	
4/23 0:00	140.1	65.7	128.4	157.2	-113.9	131	108.4	117		93	72.2	72.5	
4/23 6:00	140	65.8	128	45.8	-114	131.6	108.5	116		93	72.1	72.3	
4/23 12:00	139.8	65.8	127.7	-43.2	-113.9	133.4	111	116		93	72	72.2	
4/23 18:00	138.7	65.8	127.2	-80.7	-113.8	130.1	112.5	116		93	71.9	72.1	
4/24 0:00	136.6	65.8	126.3	-113.9	-113.7	129.1	118.1	115		93	71.8	72.1	
4/24 6:00	134	65.8	125.2	-92.9	-113.6	129.1	119.8	114		92	71.7	71.9	
4/24 12:00	140.2	65.8	124.2	-42.4	-113.5	128.5	118.9	114		92	71.5	71.8	
4/24 18:00	138.9	65.8	123.4	8	-113.5	123.3	117.2	114		92	71.4	71.6	
4/25 0:00	138.1	65.8	122.9	-3.7	-113.3	123.2	114.4	113		92	71.3	71.6	
4/25 6:00	137.6	65.7	122.5	35.9	-113.1	122	115.5	114		93	71.2	71.4	
4/25 11:00	137.2	65.7	122.3	-40.4	-113.1	122.9	116.3	114		92	71.1	71.3	
4/25 17:00	137.4	65.7	122.5	-28.4	-113.1	122.2	115.6	114		92	71	71.3	
4/25 23:00	137.1	65.7	121.9	-61.5	-112.9	120.5	116.4	114		92	70.9	71.1	
4/26 5:00	136.4	65.6	121.2	-70.8	-112.8	120	117.5	113		92	70.8	70.9	
4/26 11:00	135.4	65.7	120.5	-50.3	-112.7	120.1	116.2	112		92	70.7	71	
4/26 17:00	135.4	65.8	120.2	-39.5	-112.7	117.3	115	112		92	70.7	70.9	
4/26 23:00	135	65.7	120.4	-65.5	-112.6	117	115.7	112		92	70.6	70.9	
4/27 5:00	134.9	65.7	120.4	-62.5	-112.6	117.6	114	112		92	70.5	70.8	
4/27 11:00	134.4	65.7	120.3	-111.7	-112.6	116	114.2	111		92	70.5	70.8	
4/27 17:00	134	65.8	120.1	-101.6	-112.6	116.5	113.4	111		92	70.5	70.7	
4/27 23:00	134.4	65.8	120.1	-112.7	-112.4	117.6	116.1	111		92	70.4	70.7	
4/28 5:00	133.8	65.7	119.9	-112.5	-112.3	117.1	113.3	111		92	70.4	70.7	
4/28 11:00	133.4	65.7	119.8	-112.4	-112.3	116.2	113.1	110		92	70.3	70.6	
4/28 17:00	133.2	65.6	119.6	-112.1	-111.9	117	116.3	110		92	70.3	70.5	
4/28 23:00	133	65.6	119.4	-111.8	-111.8	116.2	116.1	110		92	70	70.3	
4/29 5:00	132.9	65.6	119.2	-111.7	-111.7	88.3	116.5	110		92	69.7	70	
4/29 11:00	132.6	65.7	119.2	-111.8	-111.6	118.3	115.8	110		92	69.6	69.8	
4/29 17:00	128	65.8	119.3	-111.7	-111.5	116.7	113	108		92	69.3	69.6	
4/29 23:00	132.9	65.7	119.3	-111.5	-111.3	117.5	115.8	108		92	69.1	69.3	
4/30 5:00	129.6	65.6	119.1	-111.3	-111.1	116.8	115.3	109		92	68.8	69.1	
4/30 11:00	132.1	65.6	118.9	-111.1	-110.9	105.9	117.1	108		93	68.6	68.8	
4/30 17:00	127.3	65.6	118.9	-111.1	-110.9	104.7	123.2	108		92	68.5	68.7	
4/30 23:00	129.1	65.7	118.8	-110.9	-110.9	105	123.2	109		92	68.3	68.6	
5/1 5:00	131.9	65.5	118.7	-110.9	-110.9	104.7	119.1	109		92	68.2	68.5	
5/1 11:00	131.6	65.5	118.5	-110.7	-110.7	106.2	119.6	115		92	68.2	68.4	
5/1 17:00	131.4	65.5	118.3	-110.6	-110.6	106.3	117.1	113.4		92	68.2	68.4	
5/1 23:00	130.9	65.5	118	-110.2	-110.2	105.4	116.8	112.5		92	68.2	68.4	
5/2 5:00	123.5	65.5	117.9	-110	-110	102.4	117.7	113.9		92	68.1	68.3	
5/2 11:00	123.4	65.5	117.6	-109.8	-109.8	104.4	119.1	113.4		92	68	68.2	
5/2 17:00	116.9	65.5	117.6	-109.6	-109.6	102.7	122.2	113.7		92	67.8	68.1	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/11 19:30					0.1450							
2011/3/11 19:37			7.170									
2011/3/11 20:00					0.1450							
2011/3/11 20:07			7.100									
2011/3/11 20:15					0.1450							
2011/3/11 20:30			7.100		0.1450							
2011/3/11 21:10			7.190		0.1550							
2011/3/11 21:30			7.250									
2011/3/11 22:00			7.200									
2011/3/11 22:10			7.260									
2011/3/11 22:20			7.200									
2011/3/11 22:30			7.300									
2011/3/11 22:58			7.300									
2011/3/11 23:05			7.300									
2011/3/11 23:19			7.380									
2011/3/11 23:35			7.320									
2011/3/11 23:50			7.340									
2011/3/12 0:00			7.340		0.2200							
2011/3/12 0:30			7.350		0.2300							
2011/3/12 1:00			7.400		0.2400							
2011/3/12 1:25			7.100		0.2450							
2011/3/12 1:55			7.370		0.2500							
2011/3/12 2:30			7.340		0.2650							
2011/3/12 2:50												
2011/3/12 3:30			7.400		0.2800							
2011/3/12 3:40												
2011/3/12 3:55			7.470		0.2850							
2011/3/12 4:19			6.800		0.2900							
2011/3/12 4:35			7.400		0.2950							
2011/3/12 4:55			7.400		0.3000							
2011/3/12 5:20			7.400		0.3000							
2011/3/12 5:30			7.290		0.3050							
2011/3/12 5:55			7.430		0.3100							
2011/3/12 6:00			7.250		0.3100							
2011/3/12 6:30			7.490		0.3200							
2011/3/12 7:00			7.390		0.3300							
2011/3/12 7:30			7.230		0.3400							
2011/3/12 8:30			7.520		0.3500							
2011/3/12 8:30			7.520		0.3500							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/12 9:10			7.460		0.3600							
2011/3/12 9:30			7.460		0.3600							
2011/3/12 11:23			7.360		0.3600							
2011/3/12 12:10			7.530		0.3900							
2011/3/12 12:45			5.600		0.3800							
2011/3/12 13:05			4.800		0.3700							
2011/3/12 13:14			4.200		0.3650							
2011/3/12 13:38			4.000		0.3600							
2011/3/12 13:58			3.630		0.3600							
2011/3/12 14:25			3.560		0.3600							
2011/3/12 17:00			2.900		0.3000							
2011/3/12 18:30			1.350		0.2800							
2011/3/12 19:00			0.950		0.2850							
2011/3/12 19:42			0.820		0.2800							
2011/3/12 20:00			0.820		0.2800							
2011/3/12 20:15			0.800		0.2700							
2011/3/12 20:30			0.820									
2011/3/12 20:40			0.820									
2011/3/12 21:00			0.720									
2011/3/12 21:30			0.970									
2011/3/12 22:00			0.970		0.1700							
2011/3/12 22:30			0.970									
2011/3/12 23:00			0.960									
2011/3/12 23:30			0.970									
2011/3/13 0:00			0.970									
2011/3/13 0:30			0.970									
2011/3/13 1:00			0.970									
2011/3/13 2:00			0.850									
2011/3/13 2:44			0.580									
2011/3/13 3:00			0.770									
2011/3/13 3:44			4.100									
2011/3/13 5:00	-2000		7.380		0.3600							
2011/3/13 5:10	-2300		7.350		0.3450							
2011/3/13 5:25	-2400		7.270		0.3550							
2011/3/13 6:00	-2600		7.390		0.3900							
2011/3/13 6:30	-2800		7.390		0.4250							
2011/3/13 6:50	-2850		7.350		0.4400							
2011/3/13 7:05	-2900		7.350		0.4500	0.4300						
2011/3/13 7:10	-2900		7.340		0.4500	0.4300						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 7:15	-2950		7.340		0.4550	0.4350						
2011/3/13 7:25	-2950		7.330		0.4550	0.4350						
2011/3/13 7:30	-2950		7.330		0.4600	0.4400						
2011/3/13 7:35	-3000		7.320		0.4600	0.4400						
2011/3/13 7:39	-3000		7.310		0.4600	0.4400						
2011/3/13 7:45	-3000		7.310		0.4600	0.4400						
2011/3/13 7:50	-3000		7.270		0.4650	0.4450						
2011/3/13 7:55	-3000		7.260		0.4650	0.4450						
2011/3/13 8:00	-3000		7.270		0.4650	0.4450						
2011/3/13 8:05	-3000		7.250		0.4650	0.4450						
2011/3/13 8:10	-3000		7.250		0.4650	0.4450						
2011/3/13 8:15	-3000		7.240		0.4650	0.4450						
2011/3/13 8:20	-3000		7.240		0.4650	0.4450						
2011/3/13 8:30	-3000		7.240		0.4650	0.4450						
2011/3/13 8:35	-3000		7.240		0.4650	0.4450						
2011/3/13 8:55	-3000		7.300		0.4700	0.4550						
2011/3/13 9:10	1800		0.460		0.6370	0.5900						
2011/3/13 9:15	900	1150	0.410		0.6300	0.5900						
2011/3/13 9:20			0.390		0.5700	0.5200						
2011/3/13 9:20			0.380		0.5600	0.5000						
2011/3/13 9:22	700	1300	0.380		0.5500	0.5000						
2011/3/13 9:24			0.360		0.5400	0.4900						
2011/3/13 9:25	1000	1300	0.350		0.5300	0.4700						
2011/3/13 9:27	1000	1100	0.340		0.5000	0.4500						
2011/3/13 9:29	1050	1650	0.340		0.5000	0.4500						
2011/3/13 9:30	1000	900	0.320		0.4800	0.4300						
2011/3/13 9:32	1000	600	0.310		0.4750	0.4250						
2011/3/13 9:35	1000	600	0.300		0.4700	0.4200						
2011/3/13 9:36	1000	700	0.290		0.4600	0.4100						
2011/3/13 9:37	900	800	0.280		0.4500	0.4000						
2011/3/13 9:38	1000	800	0.280		0.4400	0.3900						
2011/3/13 9:40	900	700	0.270		0.4350	0.3850						
2011/3/13 9:41	900	700	0.260		0.4250	0.3750						
2011/3/13 9:43	1000	800	0.250		0.4200	0.3700						
2011/3/13 9:45	800	650	0.250		0.4100	0.3600						
2011/3/13 9:47	1000	600	0.250		0.4050	0.3550						
2011/3/13 9:49	1000	600	0.240		0.4000	0.3500						
2011/3/13 9:53	850	1550	0.230		0.3900	0.3350						
2011/3/13 9:55	1000	600	0.240		0.4000	0.3500						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 9:56	850	450	0.210		0.3800	0.3300						
2011/3/13 9:59	500	300	0.210		0.3700	0.3200						
2011/3/13 10:02	2300	2400	0.380		0.3700	0.3300						
2011/3/13 10:35	-200	-700	0.120		0.2800	0.2300						
2011/3/13 10:55	-900	-1200	0.100		0.2700	0.2200						
2011/3/13 11:25	0	1600	0.110		0.2800	0.2300						
2011/3/13 11:55	1000	1000	0.120									
2011/3/13 12:40	-1400	0	0.450		0.4800	0.4800						
2011/3/13 13:00	-1400	-2000	0.190		0.3000	0.2500						
2011/3/13 14:10	-1800	-2200	0.080		0.2350	0.1850						
2011/3/13 14:30	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 15:00	-1600	-2000	0.090		0.2600	0.2100						
2011/3/13 15:30	-1500	-1900	0.140		0.3100	0.2600						
2011/3/13 16:00	-1500	-2000	0.180		0.3500	0.3000						
2011/3/13 16:15	-1500	-2000	0.190		0.3600	0.3100						
2011/3/13 16:30	-1500	-1700	0.260		0.3950	0.3450						
2011/3/13 16:45	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:00	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:15	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:30	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 18:00	-1800	-2100	0.250		0.4200	0.3700						
2011/3/13 18:20	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:40	-1800	-2200	0.250		0.4200	0.3750						
2011/3/13 19:00	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:30	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 20:00	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 20:15	-1800	-2200			0.4250	0.3750						
2011/3/13 20:30	-1800	-2200			0.4250	0.3750						
2011/3/13 20:45	-1800	-2200			0.4100	0.3700						
2011/3/13 21:00	-1800	-2200			0.3950	0.3650						
2011/3/13 21:15	-1800	-2200			0.3750	0.3550						
2011/3/13 21:30	-1800	-2200			0.3400	0.3300						
2011/3/13 21:40	-1800	-2200			0.3200	0.3200						
2011/3/13 21:45	-1800	-2200			0.3200	0.3100						
2011/3/13 22:00	-1800	-2250			0.3050	0.3000						
2011/3/13 22:05	-1800	-2250			0.3000	0.3000						
2011/3/13 22:15	-1800	-2250			0.2950	0.2950						
2011/3/13 22:30	-1800	-2200			0.2850	0.2900						
2011/3/13 23:00	-1800	-2250	0.084	0.082	0.2650	0.2750						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 23:15	-1800	-2250			0.2600	0.2700						
2011/3/13 23:30	-1800	-2250	0.062	0.064	0.2500	0.2600						
2011/3/14 0:00	-1800	-2250	0.050	0.050	0.2400	0.2550						
2011/3/14 0:10	-1800	-2250			0.2400	0.2550						
2011/3/14 0:20	-1800	-2250			0.2400	0.2550						
2011/3/14 0:30	-1800	-2250	0.048	0.048	0.2400	0.2550						
2011/3/14 0:40	-1800	-2250			0.2400	0.2550						
2011/3/14 0:50	-1800	-2250			0.2400	0.2600						
2011/3/14 1:00	-1800	-2250	0.054	0.057	0.2450	0.2600						
2011/3/14 1:10	-1800	-2250			0.2450	0.2600						
2011/3/14 1:20	-1800	-2250			0.2500	0.2650						
2011/3/14 1:30	-1800	-2250	0.062	0.062	0.2550	0.2650						
2011/3/14 1:40	-1800	-2250			0.2550	0.2700						
2011/3/14 1:50	-1800	-2250			0.2600	0.2750						
2011/3/14 2:00	-1800	-2250	0.073	0.075	0.2650	0.2750						
2011/3/14 2:10	-1800	-2250			0.2700	0.2800						
2011/3/14 2:30	-1850	-2250	0.091	0.091	0.2800	0.2800						
2011/3/14 2:45	-1850	-2300			0.3050	0.3000						
2011/3/14 2:50	-1850	-2300			0.3100	0.3000						
2011/3/14 3:00	-1850	-2300	0.127	0.127	0.3150	0.3050						
2011/3/14 3:10	-1850	-2300			0.3200	0.3100						
2011/3/14 3:15	-1850											
2011/3/14 3:20	-1850	-2300			0.3300	0.3100						
2011/3/14 3:30	-1850	-2400	0.137	0.139	0.3300	0.3200						
2011/3/14 4:00	-1800	-2800	0.150	0.150	0.3400	0.3250						
2011/3/14 4:30	-1850	-3000	0.166	0.166	0.3600	0.3400						
2011/3/14 4:40	-1850	-3000			0.3600	0.3400						
2011/3/14 5:00	-2000		0.171	0.171	0.3650	0.3450	1.58E+02		3.78E+00			
2011/3/14 5:30	-2000				0.3900	0.3650						
2011/3/14 5:40	-1800				0.4100	0.3900						
2011/3/14 6:00	-2350		0.225	0.229	0.4250	0.4000	1.66E+02		3.77E+00			
2011/3/14 6:20					0.4700	0.4500						
2011/3/14 6:30	-100	-3500			0.4950	0.4700						
2011/3/14 7:00		-3000	0.319	0.315	0.5200	0.5000	1.67E+02		4.00E+00			
2011/3/14 7:10		-2700	0.303	0.307	0.5100	0.4900						
2011/3/14 7:15	1000	-2100	0.299	0.303	0.5050	0.4900						
2011/3/14 7:20	2000	-1600	0.298	0.299	0.5000	0.4800						
2011/3/14 7:25	1700	-1300	0.298	0.299	0.5000	0.4800						
2011/3/14 7:30	1500	-1400	0.298	0.301	0.5000	0.4800						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 7:35	1400	-1500	0.295	0.301	0.5000	0.4850						
2011/3/14 7:40	1100	-800	0.293	0.301	0.5000	0.4800						
2011/3/14 7:45	800	-500	0.295	0.299	0.5000	0.4800						
2011/3/14 7:50	400	100	0.298	0.293	0.5000	0.4800						
2011/3/14 8:00	-1000	650	0.291	0.298	0.5000	0.4800	1.60E+02		4.40E+00			
2011/3/14 8:05	-800	2100	0.289	0.293	0.5400	0.4800						
2011/3/14 8:10	-500	2800	0.287	0.291	0.4950	0.4750						
2011/3/14 8:15	-200	3100	0.285	0.289	0.4950	0.4750						
2011/3/14 8:20	-200	2600	0.285	0.289	0.4900	0.4700						
2011/3/14 8:30	-1800	200	0.281	0.287	0.4900	0.4700						
2011/3/14 8:40	-1800	1200	0.289	0.287	0.4900	0.4700						
2011/3/14 8:45	-1700	1600	0.289	0.285	0.4900	0.4750	1.57E+02		4.56E+00			
2011/3/14 8:55	-1700	2500	0.285	0.291	0.4900	0.4750	1.58E+02		4.53E+00			
2011/3/14 9:05	-1500	2800	0.287	0.291	0.4900	0.4750	1.57E+02		4.50E+00			
2011/3/14 9:10	-1700	3100	0.287	0.293	0.4950	0.4750	1.57E+02		4.49E+00			
2011/3/14 9:15	-1500	2500	0.289	0.295	0.4950	0.4750	1.57E+02		4.47E+00			
2011/3/14 9:20	-1500	1700	0.293	0.298	0.4950	0.4800	1.56E+02		4.42E+00			
2011/3/14 9:25	-1500	1100	0.295	0.299	0.5000	0.4800	1.56E+02		4.42E+00			
2011/3/14 9:30	-1500	800	0.298	0.301	0.5000	0.4800	1.55E+02		4.36E+00			
2011/3/14 9:35	-1500	200	0.299	0.301	0.5000	0.4850	1.55E+02		4.39E+00			
2011/3/14 9:40	-1500	-400	0.299	0.303	0.5000	0.4850	1.56E+02		4.48E+00			
2011/3/14 9:45	-1500	-400	0.299	0.305	0.5000	0.4850	1.55E+02		4.55E+00			
2011/3/14 9:50	-1400	-400	0.301	0.307	0.5000	0.4850	1.55E+02		4.55E+00			
2011/3/14 9:55	-1500	800	0.303	0.309	0.5050	0.4900	1.54E+02		4.47E+00			
2011/3/14 10:00	-1400	-300	0.305	0.311	0.5100	0.4900	1.54E+02		4.41E+00			
2011/3/14 10:05	-1500	800	0.309	0.314	0.5100	0.4950	1.54E+02		4.40E+00			
2011/3/14 10:10	-1600	-200	0.309	0.315	0.5150	0.4950	1.55E+02		4.38E+00			
2011/3/14 10:15	-1700	600	0.314	0.317	0.5150	0.4950	1.54E+02		4.35E+00			
2011/3/14 10:20	-1400	-100	0.315	0.319	0.5200	0.5000	1.54E+02		4.28E+00			
2011/3/14 10:25	-1700	-500	0.315	0.321	0.5200	0.5000	1.54E+02		4.30E+00			
2011/3/14 10:30	-1500	-1000	0.315	0.321	0.5200	0.5000	1.54E+02		4.35E+00			
2011/3/14 10:35	-1600	-600	0.315	0.321	0.5200	0.5000	1.54E+02		4.35E+00			
2011/3/14 10:40	-1700	0	0.315	0.321	0.5200	0.5000	1.55E+02		4.34E+00			
2011/3/14 10:45	-1700	-100	0.315	0.321	0.5200	0.5000	1.55E+02		4.35E+00			
2011/3/14 10:50	-1800	-400	0.317	0.323	0.5200	0.5000	1.54E+02		4.35E+00			
2011/3/14 10:55	-1500	-600	0.317	0.323	0.5200	0.5000	1.54E+02		4.34E+00			
2011/3/14 11:02	-1400	3200	0.291	0.285	0.4800	0.4700						
2011/3/14 11:15	-1600		0.195	0.203	0.3800	0.3900						
2011/3/14 11:20	-1800		0.166	0.175	0.3600	0.3800						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 11:25	-1800		0.175	0.180	0.3600	0.3800						
2011/3/14 11:30	-1800		0.166	0.175	0.3600	0.3800						
2011/3/14 11:35	-1800		0.164	0.171	0.3600	0.3800						
2011/3/14 11:45	-1800	-2200	0.169	0.175	0.3600	0.3800						
2011/3/14 11:55	-1800	-2200	0.173	0.180	0.3600	0.3800						
2011/3/14 12:05	-1800	-2200	0.180	0.187	0.3700	0.3900						
2011/3/14 12:15	-1800	-2200	0.189	0.190	0.3800	0.3900						
2011/3/14 12:30	-1800	-2200	0.205	0.219	0.4000	0.4050						
2011/3/14 12:40	-1800	-2200	0.214	0.219	0.4050	0.4100						
2011/3/14 12:50	-1800	-2200	0.223	0.229	0.4150	0.4200						
2011/3/14 13:00	-1800	-2200	0.233	0.237	0.4300	0.4300						
2011/3/14 13:10	-1800	-2200	0.241	0.247	0.4400	0.4300						
2011/3/14 13:20	-1800	-2200	0.247	0.251	0.4450	0.4400						
2011/3/14 13:30	-1800	-2200	0.251	0.255	0.4500	0.4400						
2011/3/14 13:40	-1800	-2200	0.255	0.259	0.4500	0.4450						
2011/3/14 13:50	-1800	-2200	0.257	0.261	0.4500	0.4450						
2011/3/14 14:00	-1800	-2200	0.261	0.265	0.4600	0.4500						
2011/3/14 14:10	-1800	-2200	0.267	0.269	0.4600	0.4550						
2011/3/14 14:20	-1800	-2200	0.273	0.275	0.4700	0.4600						
2011/3/14 14:30	-1800	-2200	0.273	0.277	0.4700	0.4600						
2011/3/14 14:40	-1800	-2200	0.275	0.279	0.4750	0.4650						
2011/3/14 14:50	-1800	-2300	0.277	0.281	0.4800	0.4700						
2011/3/14 15:00	-1800	-2200	0.279	0.281	0.4800	0.4700						
2011/3/14 15:10	-1800	-2200	0.279	0.281	0.4800	0.4700						
2011/3/14 15:20	-1800	-2200	0.281	0.283	0.4800	0.4700						
2011/3/14 15:30	-1800	-2200	0.281	0.283	0.4800	0.4700						
2011/3/14 15:40	-1800	-2200	0.283	0.285	0.4800	0.4700						
2011/3/14 15:50	-1800	-2200	0.285	0.285	0.4800	0.4750						
2011/3/14 16:00	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:10	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:20	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:30	-1800	-2200	0.285	0.287	0.4800	0.4750						
2011/3/14 16:40	-1800	-2200	0.279	0.264	0.4750	0.4700						
2011/3/14 16:50	-1800	-2200	0.259	0.261	0.4600	0.4500						
2011/3/14 17:00	-1800	-2200	0.247	0.247	0.4400	0.4400						
2011/3/14 17:10	-1800	-2200	0.233	0.235	0.4300	0.4300						
2011/3/14 17:20	-1800	-2200	0.223	0.225	0.4200	0.0200						
2011/3/14 17:30	-1800	-2200	0.213	0.213	0.4000							
2011/3/14 17:40	-1800	-2200	0.205	0.205	0.4000							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 17:50	-1800	-2200	0.195	0.195	0.3850							
2011/3/14 18:00	-1850	-2200	0.191	0.191	0.3800							
2011/3/14 18:10	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 18:20	-1850	-2300	0.180	0.180	0.3700							
2011/3/14 18:30	-1850	-2300	0.179	0.179	0.3700							
2011/3/14 18:40	-1900	-2300	0.175	0.175	0.3600							
2011/3/14 18:50	-1900	-2300	0.175	0.175	0.3600							
2011/3/14 19:00	-1900	-2300	0.173	0.173	0.3600							
2011/3/14 19:10	-1900	-2300	0.173	0.173	0.3600							
2011/3/14 19:20	-1900	-2300	0.173	0.173	0.3600							
2011/3/14 19:30	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 20:00	-1900	-2300	0.175	0.175	0.3550							
2011/3/14 20:10	-1900	-2300	0.175	0.175	0.3550							
2011/3/14 20:20	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 20:30	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 20:40	-1850	-2300	0.173	0.173	0.3600							
2011/3/14 20:50	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:00	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:10	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:20	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:30	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:40	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 22:00	-1850	-2300	0.177	0.177	0.3600							
2011/3/14 22:15	-1850	-2300	0.179	0.179	0.3600							
2011/3/14 22:30	-1900	-2300	0.180	0.180	0.3600							
2011/3/14 22:40	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 22:45	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 23:00	-1900	-2300	0.189	0.189	0.3700							
2011/3/14 23:15	-1900	-2300	0.193	0.193	0.3700							
2011/3/14 23:30	-1850	-2300	0.195	0.195	0.3800							
2011/3/14 23:45	-1900	-2300	0.201	0.198	0.3950							
2011/3/15 0:00	-1900	-2300	0.203	0.203	0.3900							
2011/3/15 0:15	-1900	-2300	0.207	0.205	0.3900							
2011/3/15 0:30	-1900	-2300	0.211	0.211	0.4000							
2011/3/15 0:45	-1900	-2300	0.211	0.211	0.4000							
2011/3/15 1:00	-1900	-2300	0.211	0.213	0.4000							
2011/3/15 1:15	-1800	-2200	0.214	0.214	0.4000							
2011/3/15 1:30	-1800	-2300	0.214	0.214	0.4000							
2011/3/15 1:45	-1850	-2300	0.219	0.219	0.4000							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/15 2:00	-1900	-2300	0.221	0.221	0.4000							
2011/3/15 2:15	-1900	-2300	0.221	0.221	0.4100							
2011/3/15 2:30	-1900	-2300	0.225	0.223	0.4050							
2011/3/15 2:45	-1900	-2300	0.227	0.227	0.4050							
2011/3/15 3:00	-1900	-2300	0.229	0.229	0.4100							
2011/3/15 3:10	-1900	-2300	0.233	0.233	0.4150							
2011/3/15 3:45	-1900	-2300	0.233	0.233	0.4150							
2011/3/15 4:00	-1900	-2300	0.235	0.235	0.4150							
2011/3/15 4:15	-1900	-2300	0.235	0.235	0.4150							
2011/3/15 4:30	-1800	-2300	0.233	0.233	0.4150							
2011/3/15 4:47	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:00	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:30	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 6:00	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 11:20	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 11:30	-1900	-2300	0.235	0.235	0.4200							
2011/3/15 11:50	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 13:00	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 16:00	-1900	-2300	0.227	0.227	0.4150							
2011/3/15 20:45	-1900	-2300	0.170	0.170	0.3400							
2011/3/15 20:55	-1900	-2300	0.170	0.170	0.3400							
2011/3/15 21:05	-1900	-2300	0.161	0.170	0.3350							
2011/3/16 1:35	-1900	-2300	0.146	0.151	0.3200							
2011/3/16 2:05	-1900	-2300	0.143	0.149	0.3200							
2011/3/16 2:20	-1900	-2300	0.143	0.149	0.3200							
2011/3/16 6:15	-1900	-2300	0.117	0.117	0.2950							
2011/3/16 9:10	-1900	-2300	0.128	0.134	0.3050							
2011/3/16 9:20	-1900	-2300	0.100	0.104	0.2750							
2011/3/16 9:30	-1900	-2300	0.094	0.098	0.2700							
2011/3/16 9:40	-1900	-2300	0.094	0.090	0.2650							
2011/3/16 9:55	-1900	-2300	0.083	0.090	0.2600							
2011/3/16 10:00	-1900	-2300	0.077	0.077	0.2500							
2011/3/16 10:10	-1900	-2300	0.073	0.078	0.2500							
2011/3/16 10:20	-1900	-2300	0.068	0.075	0.2450							
2011/3/16 10:30	-1900	-2300	0.072	0.079	0.2450							
2011/3/16 11:45	-1900	-2300	0.051	0.058	0.2250							
2011/3/16 12:20	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:35	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:40	-1900	-2300	0.056	0.061	0.2300							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/16 12:45	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 14:35	-1900	-2300	0.043	0.051	0.2200							
2011/3/16 14:45	-1900	-2300	0.043	0.051	0.2200							
2011/3/16 19:25	-1900	-2300	0.036	0.041	0.1900							
2011/3/16 20:40	-1900	-2300	0.041	0.041	0.1900							
2011/3/16 23:50	-1950	-2300	0.009	0.015	0.1850							
2011/3/17 0:07	-1950	-2300	0.010	0.017	0.1850							
2011/3/17 3:05	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 3:20	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 4:00	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 6:15	-1900	-2300	0.022	0.030	0.2000	0.0100						
2011/3/17 6:30	-1900	-2300	0.024	0.032	0.2000	0.0950						
2011/3/17 6:45	-1900	-2300	0.024	0.032	0.2000	0.3250						
2011/3/17 6:50	-1900	-2300	0.024	0.032	0.2000	0.2250						
2011/3/17 6:55	-1900	-2300	0.024	0.032	0.2000	0.1250						
2011/3/17 7:00	-1900	-2300	0.024	0.032	0.2000	0.1900						
2011/3/17 7:05	-1900	-2300	0.024	0.032	0.2000	0.2700						
2011/3/17 7:10	-1900	-2300	0.024	0.032	0.2000	0.1700						
2011/3/17 7:15	-1900	-2300	0.024	0.032	0.2000	0.3850						
2011/3/17 7:20	-1900	-2300	0.026	0.034	0.2000	0.0700						
2011/3/17 7:25	-1900	-2300	0.026	0.034	0.2000	0.5500						
2011/3/17 7:30	-1900	-2300	0.024	0.034	0.2000	0.4150						
2011/3/17 7:35	-1900	-2300	0.026	0.034	0.2000	0.0500						
2011/3/17 7:45	-1900	-2300	0.026	0.034	0.2000	0.1900						
2011/3/17 7:55	-1900	-2350	0.026	0.034	0.2000	0.4150						
2011/3/17 8:15	-1900	-2300	0.026	0.034	0.2000	0.1500						
2011/3/17 8:30	-1900	-2300	0.026	0.034	0.2000	0.2500						
2011/3/17 8:45	-1900	-2300	0.026	0.036	0.2000	0.2800						
2011/3/17 11:06	-1950	-2300	0.013	0.024	0.1900	0.3250						
2011/3/17 11:10	-1950	-2300	0.013	0.022	0.1900							
2011/3/17 16:10	-1950	-2300			0.1700							
2011/3/17 16:17	-1950	-2300			0.1700							
2011/3/17 16:25	-1950	-2300	0.005	0.017	0.1700							
2011/3/17 16:35	-1950	-2300	0.005	0.017	0.1700							
2011/3/17 21:35	-1950	-2300	-0.030	-0.017	0.1500							
2011/3/17 21:50	-1950	-2300	0.010	0.008	0.1500							
2011/3/17 22:00	-1950	-2300	-0.009	0.005	0.1500							
2011/3/18 2:00	-2000	-2300	-0.007	0.009	0.1500							
2011/3/18 2:20	-2000	-2300	-0.009	0.009	0.1500							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/18 2:30	-2000	-2300	-0.005	0.013	0.1550							
2011/3/18 2:45	-2000	-2300	-0.005	0.013	0.1550							
2011/3/18 7:20	-1900	-2300	-0.010	0.007	0.1500							
2011/3/18 7:30	-1900	-2300	-0.007	0.009	0.1500							
2011/3/18 7:50	-1900	-2300	-0.009	0.009	0.1500							
2011/3/18 8:00	-1900	-2300	-0.005	0.009	0.1500		5.44E+01		3.40E+00			
2011/3/18 11:50	-1900	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 12:15	-2000	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 12:35	-2000	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 15:45	-2000	-2300	0.015	-0.015	0.1600		1.02E+02	9.33E+01	5.28E+00	3.71E+00	0.400	
2011/3/18 15:55	-2000	-2300	0.015	-0.015	0.1600		1.02E+02	9.33E+01	5.28E+00	3.71E+00		
2011/3/18 20:50	-1900	-2300	0.017	-0.015	0.1600		9.68E+01	9.07E+01	5.10E+00	3.58E+00		
2011/3/18 21:05	-1900	-2300	0.015	-0.015	0.1600		9.64E+01	9.06E+01	5.09E+00	3.58E+00		
2011/3/19 2:10	-3200	-3300	0.020	-0.143	0.0550		9.21E+01	8.41E+01	4.90E+00	3.46E+00		
2011/3/19 2:25	-3200	-3350	0.020	-0.143	0.0550		9.24E+01	8.58E+01	4.90E+00	3.45E+00		
2011/3/19 2:40	-3250	-3350	0.019	-0.015	0.0500		9.19E+01	8.56E+01	4.89E+00	3.45E+00		
2011/3/19 2:55	-3300	-3400	0.019	-0.015	0.0450		9.19E+01	8.53E+01	4.88E+00	3.44E+00		
2011/3/19 3:11	-3350	-3400	0.026	-0.015	0.0400		9.14E+01	8.51E+01	4.88E+00	3.44E+00		
2011/3/19 4:40							8.99E+01	8.40E+01	4.36E+00	3.21E+00		
2011/3/19 5:40	-1650	-2300	0.010	0.043	0.1900		9.09E+01	8.33E+01	3.70E+00	3.15E+00		
2011/3/19 6:00	-1300	-2300	0.005	0.041	0.1850		8.86E+01	8.32E+01	3.78E+00	3.11E+00		
2011/3/19 6:10	-1200	-2300	0.005	0.043	0.1850		8.83E+01	8.31E+01	3.76E+00	3.09E+00		
2011/3/19 8:00	-2400	-2300	0.009	0.044	0.1800		8.74E+01	8.27E+01	3.72E+00	3.06E+00		
2011/3/19 8:20	-2700	-2300	0.015	0.053	0.1900		8.97E+01	8.25E+01	3.80E+00	3.13E+00		
2011/3/19 8:30	-2600	-2300	0.013	0.051	0.1900		8.95E+01	8.24E+01	3.83E+00	3.12E+00	0.350	
2011/3/19 11:00	-1950	-2300	0.017	-0.019	0.1600							
2011/3/19 11:15	-1950	-2300	0.015	-0.022	0.1600						0.320	
2011/3/19 16:35	-1950	-2300	0.060	-0.026	0.1900		7.63E+01	7.76E+01	3.52E+00	3.31E+00		
2011/3/19 16:50	-1950	-2300	0.084	-0.043	0.2100		7.85E+01	7.79E+01	3.90E+00	3.68E+00		
2011/3/19 17:25	-1850	-2300	0.081	-0.047	0.2100		7.84E+01	7.78E+01	3.85E+00	3.49E+00		
2011/3/19 21:30	-1950	-2250	0.112	0.081	0.2550						0.330	
2011/3/19 21:55	-1950	-2250	0.115	0.083	0.2550						0.330	
2011/3/20 0:25	-1950	-2350	0.136	0.104	0.2700		6.12E+01	6.70E+01	3.24E+00	3.39E+00	0.300	
2011/3/20 0:50	-1950	-2350	0.138	0.102	0.2800		6.59E+01	6.71E+01	3.10E+00	3.35E+00	0.300	
2011/3/20 1:10	-1950	-2350	0.141	0.107	0.2800		6.70E+01	6.80E+01	3.12E+00	3.37E+00	0.300	
2011/3/20 3:10	-1950	-2250	0.187	0.151	0.3200	0.1800	7.20E+01	6.47E+01	3.08E+00	3.04E+00	0.330	
2011/3/20 4:10	-1950	-2300	0.197	0.163	0.3350	0.0600	7.05E+01	6.45E+01	3.07E+00	2.88E+00	0.330	
2011/3/20 4:30	-1950	-2300	0.204	0.170	0.3400	0.0500	6.96E+01	6.47E+01	3.07E+00	2.86E+00	0.330	
2011/3/20 9:55	-1950	-2350	0.180	0.146	0.3200	0.4000	7.08E+01	6.31E+01	2.30E+00	2.31E+00	0.330	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/20 10:10	-1950	-2350	0.175	0.136	0.3100	0.4000	7.11E+01	6.29E+01	2.23E+00	2.25E+00	0.330	
2011/3/20 10:35	-1950	-2300	0.170	0.132	0.3100	0.4000	7.08E+01	6.28E+01	2.18E+00	2.23E+00	0.330	
2011/3/20 11:00	-1950	-2250	0.179	0.141	0.3100	0.4000	7.09E+01	6.28E+01	2.20E+00	2.25E+00	0.330	
2011/3/20 15:00	-1600	-2000	0.155	0.121	0.3000	0.3150	7.20E+01	6.30E+01	2.02E+00	2.11E+00	0.330	
2011/3/20 15:35	-1550	-2000	0.158	0.117	0.2900	0.1250	7.18E+01	6.29E+01	2.01E+00	2.09E+00	0.330	
2011/3/20 16:00	-1650	-2000	0.153	0.112	0.2900	0.4000	7.17E+01	6.28E+01	2.00E+00	2.08E+00	0.330	
2011/3/20 19:40	-2000	-2000	0.095	0.056	0.2300		7.11E+01	6.27E+01	1.93E+00	2.05E+00	0.330	
2011/3/20 19:50	-2000	-2000	0.095	0.056	0.2300		7.11E+01	6.27E+01	1.93E+00	2.05E+00	0.330	
2011/3/20 20:00	-1625	-1900	0.094	0.049	0.2250		7.10E+01	6.25E+01	1.92E+00	2.05E+00	0.330	
2011/3/21 1:25	-1700	-2000	8.968	-0.005	0.1800		6.99E+01	6.14E+01	1.88E+00	2.00E+00	0.310	
2011/3/21 1:45	-1650	-2000	11.571	-0.010	0.1700		6.97E+01	6.12E+01	1.88E+00	2.00E+00	0.300	
2011/3/21 2:30	-1650	-2000	10.774	-0.009	0.1700		6.96E+01	6.10E+01	1.87E+00	2.00E+00	0.290	
2011/3/21 4:00	-1650	-1950	0.202	-0.026	0.1600		6.92E+01	6.05E+01	1.88E+00	1.99E+00	0.290	
2011/3/21 10:00	-2550	-2750	-0.500	-0.043	0.1200		6.74E+01	5.90E+01	1.86E+00	1.87E+00	0.290	
2011/3/21 12:15	-1600	-2000	0.041	-0.078	0.1200		6.72E+01	5.86E+01	1.83E+00	1.85E+00	0.290	
2011/3/21 14:40	-1550	-2025	0.043	-0.083	0.1100		6.63E+01	5.76E+01			0.280	
2011/3/21 14:55	-1550	-2025	0.043	-0.083	0.1100						0.280	
2011/3/21 23:40	-1500	-2300	0.039	-0.094	0.1000						0.280	
2011/3/22 0:15	-1575	-2250	0.041	-0.094	0.1000						0.280	
2011/3/22 5:15	-1550	-2350	0.036	-0.095	0.1000						0.280	
2011/3/22 5:30	-1575	-2350	0.036	-0.095	0.1000						0.280	
2011/3/22 10:20	-1575	-2325	0.036	-0.094	0.1000						0.260	
2011/3/22 10:35	-1575	-2350	0.034	-0.095	0.1000		6.00E+01	5.28E+01	1.58E+00	1.59E+00	0.260	
2011/3/22 17:10	-1525	-2250	0.036	-0.094	0.1000						0.240	
2011/3/22 17:40	-1525	-2250	0.034	-0.094	0.1000						0.240	
2011/3/22 22:00	-1750	-2350	0.036	-0.094	0.1000						0.240	
2011/3/22 22:40	-1750	-2350	0.036	-0.094	0.1000		6.10E+01	5.15E+01	1.69E+00	1.59E+00	0.240	
2011/3/23 3:00	-1900	-2300	0.032	-0.098	0.1000		6.05E+01	5.05E+01	1.75E+00	1.60E+00	0.240	
2011/3/23 4:00	-1900	-2300	0.034	-0.095	0.1000		6.05E+01	5.04E+01	1.75E+00	1.60E+00	0.240	
2011/3/23 8:20	-1800	-2300	0.034	-0.098	0.1000		6.02E+01	4.95E+01	1.74E+00	1.57E+00	0.240	
2011/3/23 8:50	-1900	-2300	0.032	-0.098	0.1000		6.02E+01	4.94E+01	1.74E+00	1.57E+00	0.250	
2011/3/23 9:10	-1800	-2300	0.032	-0.098	0.1000		6.02E+01	4.93E+01	1.74E+00	1.56E+00	0.250	
2011/3/23 13:40	-1800	-2300	0.041	-0.094	0.1000		5.95E+01	4.85E+01	1.72E+00	1.54E+00	0.230	
2011/3/23 21:10	-1700	-2300	0.041	-0.095			5.88E+01	4.73E+01	1.69E+00	1.51E+00	0.200	
2011/3/23 21:40	-1800	-2300	0.036	-0.098			5.87E+01	4.72E+01	1.68E+00	1.51E+00	0.200	
2011/3/24 2:20	-1800	-2300	0.041	-0.092			5.81E+01	4.65E+01	1.66E+00	1.50E+00	0.230	
2011/3/24 2:40	-1800	-2300	0.039	-0.092			5.79E+01	4.64E+01	1.66E+00	1.50E+00	0.220	
2011/3/24 6:20	-1800	-2300	0.039	-0.090	0.1076	0.1955	5.80E+01	4.59E+01	1.64E+00	1.49E+00	0.210	
2011/3/24 6:35	-1800	-2300	0.039	-0.090	0.1078	0.1958	5.72E+01	4.57E+01	1.64E+00	1.49E+00	0.200	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/24 10:00	-1900	-2300	0.036	-0.094	0.1074	0.1978	5.59E+01	4.50E+01	1.62E+00	1.48E+00	0.200	
2011/3/24 10:20	-1900	-2300	0.034	-0.094	0.1071	0.1986	5.59E+01	4.49E+01	1.62E+00	1.47E+00	0.200	
2011/3/24 18:00	-1850	-2300	0.036	-0.095	0.1073	0.1999	5.33E+01	4.37E+01	1.45E+00	1.59E+00	0.300	
2011/3/24 21:40	-1900	-2300	0.041	-0.092	0.1066	0.1993	5.47E+01	4.28E+01	1.57E+00	1.42E+00	0.250	
2011/3/24 22:00	-1800	-2300	0.030	-0.098	0.1068	0.1997	5.29E+01	4.28E+01	1.56E+00	1.42E+00	0.240	
2011/3/24 23:30	-1700	-2300	0.039	-0.092	0.1085	0.1981	5.20E+01	4.25E+01	1.55E+00	1.41E+00	0.250	
2011/3/25 0:30	-1700	-2300	0.041	-0.092	0.1085	0.1972	5.18E+01	4.24E+01	1.54E+00	1.40E+00	0.250	
2011/3/25 5:30	-1900	-2300	0.039	-0.092	0.1076	0.1948	5.00E+01	4.15E+01	1.50E+00	1.36E+00	0.200	
2011/3/25 6:10	-1900	-2300	0.036	-0.092	0.1074	0.1937	5.10E+01	4.14E+01	1.50E+00	1.36E+00	0.200	
2011/3/25 9:30	-1900	-2300	0.034	-0.092	0.1074	0.1923	4.93E+01	4.08E+01	1.47E+00	1.34E+00	0.200	
2011/3/25 14:10	-1900	-2300	0.036	-0.098	0.1089	0.1913	4.85E+01	4.00E+01	1.31E+00	1.44E+00	0.200	
2011/3/25 16:10	-1900	-2300	0.034	-0.094	0.1075	0.1895	3.88E+01	2.94E+01	1.31E+00	1.44E+00		
2011/3/25 18:10	-1800	-2300	0.036	-0.098	0.1069	0.1883	3.78E+01	2.85E+01	1.43E+00	1.30E+00	0.170	
2011/3/25 19:10	-1900	-2300	0.034	-0.098	0.1069	0.1824	3.73E+01	2.83E+01	1.42E+00	1.20E+00	0.180	
2011/3/26 4:20	-1825	-2300	0.036	-0.094	0.1068	0.1850	3.68E+01	2.77E+01	1.41E+00	1.30E+00	0.180	
2011/3/26 5:05	-1850	-2300	0.036	-0.095	0.1069	0.1848	3.66E+01	2.77E+01	1.41E+00	1.30E+00	0.180	
2011/3/26 10:00	-1800	-2300	0.036	-0.095	0.1066	0.1839	3.61E+01	2.75E+01	1.40E+00	1.30E+00	0.190	
2011/3/26 11:15	-1850	-2300	0.036	-0.095	0.1068	0.1836	3.61E+01	2.74E+01	1.40E+00	1.30E+00	0.220	
2011/3/26 14:30	-1850	-2300	0.032	-0.100	0.1068	0.1831	3.57E+01	2.71E+01	1.30E+00	1.39E+00	0.200	
2011/3/26 16:00	-1900	-2250	0.034	-0.100	0.1066	0.1825	3.55E+01	2.69E+01	1.39E+00	1.29E+00	0.190	
2011/3/26 20:00	-1900	-2300	0.034	-0.098	0.1071	0.1824	3.56E+01	2.66E+01	1.37E+00	1.28E+00	0.170	
2011/3/26 21:20	-1900	-2250	0.036	-0.098	0.1071	0.1818	3.50E+01	2.64E+01	1.37E+00	1.27E+00	0.170	
2011/3/26 23:10	-1900	-2250	0.034	-0.094	0.1076	0.1818	3.49E+01	2.62E+01	1.36E+00	1.27E+00	0.170	
2011/3/27 4:15	-1850	-2300	0.030	-0.092	0.1073	0.1804	3.41E+01	2.57E+01	1.34E+00	1.25E+00	0.160	
2011/3/27 4:45	-1850	-2300	0.027	-0.094	0.1073	0.1804	3.42E+01	2.56E+01	1.34E+00	1.25E+00	0.160	
2011/3/27 9:25	-1900	-2300	0.027	-0.094	0.1078	0.1808	3.43E+01	2.52E+01	1.32E+00	1.23E+00	0.160	
2011/3/27 10:10	-1900	-2300	0.030	-0.094	0.1076	0.1806	3.37E+01	2.51E+01	1.31E+00	1.23E+00	0.170	
2011/3/27 16:00	-1850	-2300	0.027	-0.094	0.1069	0.1797	3.31E+01	2.45E+01	1.31E+00	1.22E+00	0.160	
2011/3/27 16:25	-1850	-2300	0.032	-0.092	0.1069	0.1797	3.22E+01	2.45E+01	1.30E+00	1.22E+00	0.160	
2011/3/27 17:30	-1900	-2300	0.030	-0.092	0.1073	0.1799	3.29E+01	2.44E+01	1.29E+00	1.21E+00	0.150	
2011/3/27 18:30	-1900	-2300	0.032	-0.092	0.1075	0.1801	3.31E+01	2.43E+01	1.29E+00	1.21E+00	0.150	
2011/3/27 19:00	-1900	-2300	0.030	-0.094	0.1080	0.1804	3.29E+01	2.43E+01	1.29E+00	1.21E+00	0.150	
2011/3/28 0:00	-1900	-2300	0.027	-0.087	0.1082	0.1796	3.20E+01	2.38E+01	1.26E+00	1.18E+00	0.150	
2011/3/28 0:50	-1900	-2300	0.026	-0.087	0.1083	0.1797	3.20E+01	2.38E+01	1.26E+00	1.18E+00	0.150	
2011/3/28 5:00	-1900	-2300	0.030	-0.085	0.1085	0.1797	3.16E+01	2.35E+01	1.24E+00	1.17E+00	0.140	
2011/3/28 5:30	-1900	-2300	0.027	-0.085	0.1083	0.1794	3.15E+01	2.34E+01	1.24E+00	1.16E+00	0.140	
2011/3/28 10:00	-1850	-2250	0.024	-0.090	0.1082	0.1799	3.11E+01	2.31E+01	1.23E+00	1.14E+00	0.140	
2011/3/28 10:30	-1850	-2250	0.024	-0.090	0.1076	0.1792	3.10E+01	2.31E+01	1.23E+00	1.14E+00	0.140	
2011/3/28 15:00	-1850	-2250	0.027	-0.092	0.1076	0.1797	3.06E+01	2.27E+01	1.21E+00	1.13E+00	0.150	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/28 16:00	-1850	-2300	0.030	-0.090	0.1078	0.1797	3.05E+01	2.27E+01	1.21E+00	1.13E+00	0.140	
2011/3/28 19:30	-1850	-2300	0.030	-0.087	0.1083	0.1794	3.01E+01	2.24E+01	1.20E+00	1.12E+00	0.140	
2011/3/28 20:35	-1850	-2300	0.030	-0.087	0.1085	0.1797	3.00E+01	2.04E+01	1.20E+00	1.12E+00	0.150	
2011/3/28 21:00	-1850	-2300	0.030	-0.087	0.1083	0.1796	3.00E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 21:20	-1900	-2300	0.026	-0.090	0.1082	0.1794	2.99E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 21:40	-1900	-2300	0.026	-0.090	0.1082	0.1796	3.01E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 23:30	-1800	-2250	0.034	-0.090	0.1082	0.1796	3.09E+01	2.22E+01	1.19E+00	1.11E+00	0.140	
2011/3/29 0:00	-1800	-2250	0.027	-0.087	0.1073	0.1792	2.95E+01	2.21E+01	1.19E+00	1.11E+00	0.140	
2011/3/29 4:45	-1900	-2300	0.032	-0.085	0.1085	0.1792	2.92E+01	2.18E+01	1.18E+00	1.09E+00	0.140	
2011/3/29 5:15	-1900	-2300	0.026	-0.090	0.1083	0.1792	2.91E+01	2.18E+01	1.17E+00	1.09E+00	0.130	
2011/3/29 10:15	-1900	-2300	0.027	-0.087	0.1075	0.1790	2.93E+01	2.15E+01	1.16E+00	1.08E+00	0.140	
2011/3/29 10:45	-1850	-2250	0.024	-0.092	0.1073	0.1790	2.86E+01	2.14E+01	1.16E+00	1.08E+00	0.150	
2011/3/29 12:00	-1850	-2250	0.027	-0.090	0.1075	0.1796	2.86E+01	2.14E+01	1.16E+00	1.08E+00	0.150	
2011/3/29 14:30	-1900	-2250	0.026	-0.092	0.1068	0.1785	2.86E+01	2.12E+01	1.15E+00	1.07E+00	0.130	
2011/3/29 15:15	-1850	-2250	0.026	-0.094	0.1076	0.1803	2.86E+01	2.12E+01	1.15E+00	1.07E+00	0.130	
2011/3/29 15:45	-1850	-2250	0.027	-0.092	0.1073	0.1801	2.84E+01	2.11E+01	1.15E+00	1.07E+00	0.140	
2011/3/29 16:50	-1850	-2250	0.027	-0.092	0.1069	0.1790	2.84E+01	2.11E+01	1.14E+00	1.06E+00	0.130	
2011/3/29 22:10	-1900	-2300	0.027	-0.090	0.1069	0.1790	2.80E+01	2.08E+01	1.13E+00	1.05E+00	0.130	
2011/3/29 23:00	-1900	-2300	0.027	-0.090	0.1069	0.1785	2.78E+01	2.07E+01	1.13E+00	1.05E+00	0.130	
2011/3/30 3:20	-1900	-2250	0.024	-0.087	0.1071	0.1780	2.77E+01	2.05E+01	1.11E+00	1.04E+00	0.140	
2011/3/30 3:50	-1850	-2250	0.022	-0.087	0.1071	0.1780	2.76E+01	2.05E+01	1.11E+00	1.03E+00	0.130	
2011/3/30 8:30	-1850	-2250	0.022	-0.087	0.1073	0.1782	2.72E+01	2.02E+01	1.10E+00	1.02E+00	0.130	
2011/3/30 13:00	-1850	-2250	0.024	-0.085	0.1062	0.1771	2.69E+01	2.00E+01	1.09E+00	1.01E+00	0.140	
2011/3/30 13:30	-1850	-2250	0.017	-0.090	0.1064	0.1775	2.68E+01	2.00E+01	1.09E+00	1.01E+00	0.140	
2011/3/30 18:20	-1850	-2250	0.019	-0.087	0.1068	0.1773	2.65E+01	1.97E+01	1.07E+00	9.90E-01	0.140	
2011/3/30 19:00	-1850	-2250	0.022	-0.085	0.1068	0.1769	2.64E+01	1.97E+01	1.07E+00	9.98E-01	0.140	
2011/3/30 23:20	-1850	-2250	0.022	-0.085	0.1071	0.1775	2.61E+01	1.95E+01	1.06E+00	9.88E-01	0.130	
2011/3/30 23:50	-1850	-2250	0.019	-0.085	0.1073	0.1773	2.61E+01	1.95E+01	1.06E+00	9.87E-01	0.130	
2011/3/31 4:10	-1900	-2300	0.019	-0.085	0.1075	0.1768	2.60E+01	1.93E+01	1.05E+00	9.79E-01	0.130	
2011/3/31 4:40	-1900	-2300	0.019	-0.085	0.1073	0.1764	2.57E+01	1.92E+01	1.05E+00	9.77E-01	0.130	
2011/3/31 9:40	-1850	-2250	0.015	-0.087	0.1066	0.1755	2.54E+01	1.90E+01	1.04E+00	9.67E-01	0.130	
2011/3/31 16:10	-1900	-2250	0.015	-0.085	0.1071	0.1761	2.51E+01	1.87E+01	1.02E+00	9.55E-01	0.130	
2011/3/31 16:45	-1900	-2250	0.017	-0.085	0.1071	0.1761	2.59E+01	1.87E+01	1.02E+00	9.54E-01	0.130	
2011/3/31 19:00	-1850	-2250	0.010	-0.090	0.1069	0.1761	2.48E+01	1.86E+01	1.02E+00	9.49E-01	0.130	
2011/3/31 19:30	-1850	-2250	0.019	-0.083	0.1064	0.1754	2.54E+01	1.86E+01	1.02E+00	9.49E-01	0.130	
2011/3/31 19:50	-1850	-2250	0.022	-0.083	0.1068	0.1759	2.48E+01	1.86E+01	1.02E+00	9.47E-01	0.130	
2011/4/1 0:00	-1900	-2250	0.015	-0.083	0.1068	0.1755	2.40E+01	1.80E+01	1.00E+00	9.30E-01	0.120	
2011/4/1 0:45	-1900	-2250	0.015	-0.081	0.1073	0.1838	2.40E+01	1.80E+01	1.00E+00	9.30E-01	0.120	
2011/4/1 5:15	-1900	-2250	0.017	-0.083	0.1071	0.1755	2.47E+01	1.82E+01	9.96E-01	9.25E-01	0.120	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/1 5:45	-1900	-2250	0.017	-0.081	0.1071	0.1775	2.45E+01	1.82E+01	9.95E-01	9.24E-01	0.120	
2011/4/1 11:10	-1900	-2250	0.017	-0.081	0.1071	0.1759	2.45E+01	1.80E+01	9.83E-01	9.12E-01	0.120	
2011/4/1 11:45	-1900	-2250	0.015	-0.083	0.1068	0.1757	2.42E+01	1.80E+01	9.82E-01	9.12E-01	0.120	
2011/4/1 15:00	-1850	-2250	0.017	-0.083	0.1059	0.1755	2.43E+01	1.78E+01	9.75E-01	9.05E-01	0.120	
2011/4/1 15:30	-1850	-2250	0.015	-0.085	0.1061	0.1755	2.40E+01	1.78E+01	9.74E-01	9.04E-01	0.120	
2011/4/1 20:00	-1850	-2250	0.015	-0.085	0.1066	0.1754	2.36E+01	1.77E+01	9.65E-01	8.95E-01	0.120	
2011/4/1 20:30	-1850	-2250	0.017	-0.083	0.1066	0.1754	2.38E+01	1.76E+01	9.64E-01	8.94E-01	0.120	
2011/4/2 1:00	-1850	-2250	0.019	-0.081	0.1066	0.1755	2.37E+01	1.75E+01	9.55E-01	8.85E-01	0.120	
2011/4/2 1:30	-1850	-2250	0.024	-0.081	0.1055	0.1748	2.40E+01	1.75E+01	9.55E-01	8.85E-01	0.120	
2011/4/2 5:55	-1850	-2250	0.013	-0.087	0.1061	0.1754	2.41E+01	1.73E+01	9.46E-01	8.71E-01	0.120	
2011/4/2 6:25	-1850	-2250	0.019	-0.083	0.1062	0.1754	2.33E+01	1.73E+01	9.46E-01	8.77E-01	0.120	
2011/4/2 11:05	-1850	-2250	0.019	-0.085	0.1055	0.1754	2.31E+01	1.72E+01	9.37E-01	8.70E-01	0.130	
2011/4/2 11:40	-1850	-2250	0.017	-0.087	0.1054	0.1752	2.58E+01	1.71E+01	9.36E-01	8.69E-01	0.120	
2011/4/2 12:10	-1850	-2250	0.013	-0.090	0.1050	0.1748	2.32E+01	1.71E+01	9.35E-01	8.68E-01	0.120	
2011/4/2 16:00	-1850	-2250	0.017	-0.085	0.1050	0.1747	2.31E+01	1.70E+01	9.30E-01	8.63E-01	0.120	
2011/4/2 16:30	-1850	-2250	0.013	-0.085	0.1052	0.1748	2.28E+01	1.70E+01	9.29E-01	8.62E-01	0.120	
2011/4/2 21:00	-1850	-2250	0.009	-0.090	0.1054	0.1747	2.30E+01	1.68E+01	9.20E-01	8.55E-01	0.120	
2011/4/2 21:30	-1850	-2250	0.007	-0.087	0.1055	0.1747	2.27E+01	1.68E+01	9.19E-01	8.54E-01	0.120	
2011/4/3 2:30	-1850	-2250	0.010	-0.083	0.1061	0.1748	2.22E+01	1.67E+01	9.11E-01	8.46E-01	0.110	
2011/4/3 7:00	-1850	-2250	0.009	-0.081	0.1066	0.1750	2.22E+01	1.66E+01	9.03E-01	8.39E-01	0.100	
2011/4/3 7:30	-1850	-2250	0.010	-0.078	0.1066	0.1750	2.18E+01	1.65E+01	9.02E-01	8.39E-01	0.120	
2011/4/3 9:15	-1850	-2250	0.013	-0.078	0.1062	0.1750	2.18E+01	1.65E+01	8.99E-01	8.36E-01	0.100	
2011/4/3 10:00	-1850	-2250	0.013	-0.078	0.1064	0.1750	2.17E+01	1.65E+01	8.98E-01	8.35E-01	0.100	
2011/4/3 10:30	-1850	-2250	0.010	-0.078	0.1062	0.1750	2.17E+01	1.65E+01	8.97E-01	8.34E-01	0.100	
2011/4/3 12:00	-1850	-2250	0.007	-0.085	0.1062	0.1752	2.17E+01	1.64E+01	8.94E-01	8.32E-01	0.100	
2011/4/3 12:30	-1850	-2250	0.013	-0.078	0.1061	0.1750	2.17E+01	1.64E+01	8.94E-01	8.31E-01	0.100	
2011/4/3 13:00	-1850	-2250	0.007	-0.083	0.1064	0.1754	2.17E+01	1.64E+01	8.93E-01	8.31E-01	0.100	
2011/4/3 13:30	-1850	-2250	0.010	-0.081	0.1062	0.1754	2.17E+01	1.64E+01	8.92E-01	8.30E-01	0.100	
2011/4/3 17:00	-1850	-2250	0.015	-0.081	0.1057	0.1750	2.17E+01	1.63E+01	8.86E-01	8.21E-01	0.100	
2011/4/3 17:35	-1850	-2250	0.010	-0.081	0.1059	0.1752	2.24E+01	1.63E+01	8.85E-01	8.21E-01	0.100	
2011/4/3 18:00	-1850	-2250	0.009	-0.083	0.1059	0.1752	2.18E+01	1.63E+01	8.84E-01	8.20E-01	0.100	
2011/4/3 21:00	-1900	-2250	0.010	-0.078	0.1064	0.1754	2.15E+01	1.62E+01	8.80E-01	8.17E-01	0.100	
2011/4/3 22:00	-1850	-2250	0.009	-0.078	0.1068	0.1754	2.15E+01	1.62E+01	8.79E-01	8.16E-01	0.100	
2011/4/4 3:00	-1800	-2250	0.007	-0.077	0.1073	0.1754	2.13E+01	1.60E+01	8.72E-01	8.10E-01	0.100	
2011/4/4 3:30	-1800	-2250	0.007	-0.077	0.1073	0.1754	2.15E+01	1.60E+01	8.71E-01	8.10E-01	0.100	
2011/4/4 8:00	-1850	-2250	0.007	-0.077	0.1071	0.1755	2.11E+01	1.59E+01	8.66E-01	8.05E-01	0.110	
2011/4/4 8:30	-1750	-2250	0.009	-0.077	0.1068	0.1754	2.15E+01	1.59E+01	8.65E-01	8.04E-01	0.100	
2011/4/4 9:30	-1750	-2250	0.005	-0.078	0.1069	0.1757	2.11E+01	1.59E+01	8.64E-01	8.03E-01	0.110	
2011/4/4 14:30	-1850	-2250	0.005	-0.081	0.1071	0.1754	2.07E+01	1.58E+01	8.57E-01	7.97E-01	0.110	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/4 18:30	-1850	-2250	0.007	-0.081	0.1066	0.1743	2.25E+01	1.57E+01	8.52E-01	7.93E-01	0.100	
2011/4/4 19:00	-1850	-2250	0.007	-0.081	0.1071	0.1745	2.04E+01	1.57E+01	8.51E-01	7.93E-01	0.110	
2011/4/5 0:00	-1850	-2250	0.005	-0.078	0.1073	0.1736	2.04E+01	1.55E+01	8.45E-01	7.86E-01	0.110	
2011/4/5 0:30	-1850	-2250	0.005	-0.081	0.1069	0.1731	2.05E+01	1.55E+01	8.44E-01	7.86E-01	0.110	
2011/4/5 5:10	-1850	-2250	0.009	-0.078	0.1078	0.1733	2.12E+01	1.54E+01	8.39E-01	7.80E-01	0.110	
2011/4/5 5:40	-1850	-2250	0.010	-0.077	0.1078	0.1733	2.10E+01	1.54E+01	8.39E-01	7.80E-01	0.110	
2011/4/5 10:20	-1850	-2250	0.005	-0.078	0.1071	0.1733	2.06E+01	1.53E+01	8.33E-01	7.74E-01	0.110	
2011/4/5 17:10	-1850	-2250	0.007	-0.077	0.1071	0.1734	2.03E+01	1.52E+01	8.23E-01	7.66E-01	0.110	
2011/4/5 18:30	-1850	-2250	0.007	-0.077	0.1069	0.1727	2.03E+01	1.52E+01	8.22E-01	7.65E-01	0.120	
2011/4/6 0:00	-1850	-2250	0.009	-0.077	0.1069	0.1733	2.09E+01	1.51E+01	8.15E-01	7.58E-01	0.120	
2011/4/6 6:30	-1800	-2200	0.007	-0.077	0.1076	0.1731	1.98E+01	1.49E+01	8.07E-01	7.50E-01	0.120	
2011/4/6 12:30	-1800	-2200	0.005	-0.081	0.1069	0.1731	1.95E+01	1.48E+01	7.99E-01	7.43E-01	0.120	
2011/4/6 18:00	-1800	-2200	0.004	-0.081	0.1066	0.1731	1.95E+01	1.47E+01	7.92E-01	7.37E-01	0.110	
2011/4/7 0:00	-1800	-2250	0.002	-0.079	0.1071	0.1729	1.95E+01	1.46E+01	7.84E-01	7.29E-01	0.120	
2011/4/7 6:00	-1850	-2250	-0.002	-0.079	0.1075	0.1729	1.96E+01	1.45E+01	7.77E-01	7.22E-01	0.110	
2011/4/7 12:00	-1900	-2250	0.000	-0.081	0.1059	0.1720	1.93E+01	1.44E+01	7.68E-01	7.14E-01	0.100	
2011/4/7 18:00	-1950	-2250	0.000	-0.079	0.1062	0.1727	1.92E+01	1.43E+01	7.59E-01	7.06E-01	0.110	
2011/4/7 19:30	-2000	-2250	0.000	-0.081	0.1062	0.1727	1.92E+01	1.43E+01	7.57E-01	7.04E-01	0.110	
2011/4/8 1:30	-2000	-2250	-0.002	-0.081	0.1061	0.1726	1.90E+01	1.42E+01	7.48E-01	6.94E-01	0.110	
2011/4/8 6:40	-2000	-2250	-0.002	-0.081	0.1057	0.1722	1.89E+01	1.41E+01	7.43E-01	6.89E-01	0.120	
2011/4/8 12:00	-1850	-2250	-0.004	-0.079	0.1052	0.1722	1.88E+01	1.40E+01	7.38E-01	6.84E-01	0.140	
2011/4/8 18:00	-1700	-2200	0.006	-0.081	0.1047	0.1720	1.87E+01	1.40E+01	7.33E-01	6.80E-01	0.100	
2011/4/9 0:00	-1950	-2300	-0.002	-0.085	0.1054	0.1727	1.86E+01	1.39E+01	7.28E-01	6.75E-01	0.130	
2011/4/9 6:15	-1850	-2250	-0.002	-0.081	0.1057	0.1726	1.85E+01	1.38E+01	7.23E-01	6.71E-01	0.100	
2011/4/9 12:25	-1700	-2250	-0.004	-0.081	0.1055	0.1722	1.84E+01	1.37E+01	7.17E-01	6.66E-01	0.090	
2011/4/9 18:25	-1900	-2250	-0.011	-0.079	0.1054	0.1715	1.83E+01	1.36E+01	7.13E-01	6.61E-01	0.090	
2011/4/10 0:00	-1900	-2250	-0.011	-0.081	0.1055	0.1717	1.82E+01	1.36E+01	7.08E-01	6.56E-01	0.090	
2011/4/10 6:00	-1900	-2250	-0.009	-0.077	0.1061	0.1717	1.81E+01	1.35E+01	7.03E-01	6.52E-01	0.090	
2011/4/10 12:00	-1900	-2250	-0.009	-0.079	0.1054	0.1713	1.80E+01	1.34E+01	6.98E-01	6.48E-01	0.090	
2011/4/10 18:00	-1900	-2250	-0.013	-0.083	0.1052	0.1708	1.79E+01	1.34E+01	6.94E-01	6.43E-01	0.080	
2011/4/11 0:00	-1900	-2250	-0.017	-0.083	0.1050	0.1703	1.78E+01	1.33E+01	6.90E-01	6.40E-01	0.080	
2011/4/11 6:00	-1900	-2250	-0.015	-0.081	0.1031	0.1698	1.78E+01	1.32E+01	6.85E-01	6.36E-01	0.080	
2011/4/11 12:00	-1900	-2250	-0.017	-0.083	0.1043	0.1699	1.77E+01	1.32E+01	6.81E-01	6.32E-01	0.075	
2011/4/11 18:30	-1850	-2250	-0.017	-0.083	0.1043	0.1698	1.75E+01	1.31E+01	6.24E-01	6.80E-01	0.085	
2011/4/12 0:00	-1850	-2250	-0.015	-0.079	0.1045	0.1696	1.75E+01	1.31E+01	6.75E-01	6.20E-01	0.090	
2011/4/12 6:00	-1850	-2250	-0.019	-0.079	0.1052	0.1692	1.74E+01	1.30E+01	6.71E-01	6.17E-01	0.075	
2011/4/12 12:00	-1850	-2250	-0.017	-0.083	0.1048	0.1689	1.73E+01	1.29E+01	6.68E-01	6.13E-01	0.080	
2011/4/12 15:10	-1850	-2250	-0.019	-0.085	0.1048	0.1689	1.72E+01	1.29E+01	6.63E-01	6.11E-01	0.090	
2011/4/12 18:00	-1850	-2250	-0.019	-0.083	0.1050	0.1689	1.72E+01	1.29E+01	6.62E-01	6.09E-01	0.080	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/12 22:10	-1850	-2250	-0.018	-0.086	0.1055	0.1685	1.71E+01	1.29E+01	6.61E-01	6.07E-01	0.070	
2011/4/13 6:00	-1850	-2250	-0.019	-0.079	0.1055	0.1680	1.70E+01	1.28E+01	6.57E-01	6.03E-01	0.085	
2011/4/13 7:00	-1850	-2250	-0.019	-0.079	0.1054	0.1680	1.70E+01	1.28E+01	6.56E-01	6.03E-01	0.080	
2011/4/13 12:10	-1750	-2200	-0.023	-0.083	0.1036	0.1677	1.69E+01	1.27E+01	6.53E-01	6.00E-01	0.080	
2011/4/13 18:00	-1750	-2250	-0.021	-0.085	0.1036	0.1677	1.68E+01	1.27E+01	6.50E-01	5.97E-01	0.080	
2011/4/14 0:00	-1750	-2250	-0.017	-0.083	0.1047	0.1680	1.67E+01	1.26E+01	6.47E-01	5.95E-01	0.080	
2011/4/14 6:05	-1800	-2250	-0.017	-0.083	0.1045	0.1673	1.67E+01	1.26E+01	6.43E-01	5.92E-01	0.080	
2011/4/14 12:00	-1800	-2250	-0.017	-0.085	0.1040	0.1671	1.66E+01	1.25E+01	6.40E-01	5.89E-01	0.080	
2011/4/14 18:00	-1800	-2250	-0.017	-0.085	0.1041	0.1670	1.65E+01	1.25E+01	6.37E-01	5.86E-01	0.080	
2011/4/15 0:00	-1800	-2250	-0.019	-0.085	0.1043	0.1664	1.65E+01	1.24E+01	6.34E-01	5.84E-01	0.080	
2011/4/15 6:00	-1800	-2250	-0.023	-0.083	0.1043	0.1661	1.64E+01	1.24E+01	6.31E-01	5.81E-01	0.080	
2011/4/15 12:00	-1800	-2250	-0.021	-0.085	0.1040	0.1661	1.63E+01	1.24E+01	6.28E-01	5.79E-01	0.080	
2011/4/15 18:00	-1800	-2250	-0.026	-0.087	0.1033	0.1654	1.63E+01	1.23E+01	6.25E-01	5.76E-01	0.080	
2011/4/16 0:00	-1800	-2250	-0.028	-0.085	0.1038	0.1656	1.73E+01	1.23E+01	6.22E-01	5.74E-01	0.080	
2011/4/16 6:00	-1800	-2250	-0.030	-0.085	0.1038	0.1656	1.62E+01	1.22E+01	6.20E-01	5.71E-01	0.080	
2011/4/16 12:10	-1800	-2250	-0.023	-0.085	0.1031	0.1654	2.00E+01	1.22E+01	6.16E-01	5.68E-01	0.110	
2011/4/16 18:00	-1800	-2250	-0.030	-0.083	0.1034	0.1658	1.59E+01	1.21E+01	6.14E-01	5.65E-01	0.075	
2011/4/17 0:00	-1800	-2250	-0.032	-0.085	0.1043	0.1666	1.59E+01	1.21E+01	6.11E-01	5.64E-01	0.070	
2011/4/17 6:00	-1800	-2250	-0.030	-0.083	0.1047	0.1675	1.59E+01	1.21E+01	6.10E-01	5.62E-01	0.070	
2011/4/17 14:00	-1800	-2250	-0.030	-0.085	0.1043	0.1684	1.58E+01	1.20E+01	6.07E-01	5.60E-01	0.070	
2011/4/17 19:00	-1800	-2250	-0.032	-0.083	0.1045	0.1687	1.58E+01	1.20E+01	6.05E-01	5.59E-01	0.070	
2011/4/18 0:00	-1800	-2250	-0.034	-0.085	0.1045	0.1696	1.58E+01	1.19E+01	6.04E-01	5.57E-01	0.065	
2011/4/18 6:00	-1800	-2250	-0.034	-0.081	0.1048	0.1701	1.58E+01	1.19E+01	6.02E-01	5.56E-01	0.065	
2011/4/18 12:00	-1800	-2250	-0.034	-0.081	0.1047	0.1710	1.58E+01	1.19E+01	6.00E-01	5.54E-01	0.065	
2011/4/18 13:10	-1800	-2250	-0.034	-0.085	0.1047	0.1712	1.58E+01	1.19E+01	5.99E-01	5.54E-01	0.065	
2011/4/18 13:45	-1800	-2250	-0.034	-0.081	0.1047	0.1713	1.58E+01	1.19E+01	5.99E-01	5.54E-01	0.065	
2011/4/18 18:00	-1850	-2250	-0.034	-0.085	0.1045	0.1715	1.57E+01	1.18E+01	5.98E-01	5.52E-01	0.065	
2011/4/19 0:00	-1850	-2250	-0.036	-0.085	0.1041	0.1720	1.57E+01	1.18E+01	5.96E-01	5.51E-01	0.070	
2011/4/19 6:00	-1850	-2250	-0.034	-0.085	0.1041	0.1724	1.57E+01	1.18E+01	5.94E-01	5.49E-01	0.065	
2011/4/19 12:00	-1850	-2250	-0.040	-0.085	0.1036	0.1722	1.56E+01	1.17E+01	5.92E-01	5.47E-01	0.080	
2011/4/19 18:10	-1850	-2250	-0.040	-0.083	0.1034	0.1727	1.56E+01	1.17E+01	5.90E-01	5.46E-01	0.065	
2011/4/20 0:02	-1850	-2250	-0.038	-0.087	0.1041	0.1734	1.56E+01	1.17E+01	5.88E-01	5.44E-01	0.055	
2011/4/20 6:00	-1850	-2250	-0.038	-0.089	0.1045	0.1741	1.55E+01	1.16E+01	5.87E-01	5.42E-01	0.070	
2011/4/20 12:00	-1850	-2250	-0.043	-0.089	0.1045	0.1748	1.55E+01	1.16E+01	5.85E-01	5.41E-01	0.065	
2011/4/20 18:10	-1850	-2250	-0.043	-0.087	0.1047	0.1754	1.55E+01	1.16E+01	5.82E-01	5.40E-01	0.065	
2011/4/20 23:50	-1850	-2250	-0.045	-0.087	0.1054	0.1761	1.54E+01	1.15E+01	5.80E-01	5.39E-01	0.065	
2011/4/21 6:00	-1850	-2250	-0.043	-0.085	0.1061	0.1768	1.54E+01	1.15E+01	5.79E-01	5.38E-01	0.065	
2011/4/21 12:00	-1850	-2250	-0.043	-0.087	0.1050	0.1769	1.54E+01	1.15E+01	5.77E-01	5.37E-01	0.065	
2011/4/21 18:00	-1850	-2250	-0.043	-0.085	0.1052	0.1775	1.53E+01	1.14E+01	5.75E-01	5.35E-01	0.065	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/4/22 0:00	-1850	-2250	-0.047	-0.089	0.1055	0.1776	1.51E+01	1.14E+01	5.73E-01	5.34E-01	0.065	
2011/4/22 6:00	-1850	-2250	-0.047	-0.087	0.1055	0.1780	1.52E+01	1.14E+01	5.70E-01	5.32E-01	0.070	
2011/4/22 11:50	-1850	-2250	-0.049	-0.089	0.1048	0.1780	1.52E+01	1.14E+01	5.69E-01	5.31E-01	0.070	
2011/4/22 17:50	-1850	-2250	-0.049	-0.089	0.1047	0.1783	1.52E+01	1.13E+01	5.68E-01	5.30E-01	0.080	
2011/4/23 0:00	-1850	-2250	-0.053	-0.087	0.1047	0.1785	1.52E+01	1.13E+01	5.66E-01	5.28E-01	0.060	
2011/4/23 6:15	-1850	-2250	-0.049	-0.087	0.1045	0.1782	1.51E+01	1.13E+01	5.64E-01	5.27E-01	0.070	
2011/4/23 11:55	-1850	-2250	-0.049	-0.087	0.1038	0.1778	1.51E+01	1.13E+01	5.63E-01	5.26E-01	0.060	
2011/4/23 18:00	-1850	-2250	-0.051	-0.089	0.1033	0.1776	1.50E+01	1.12E+01	5.62E-01	5.25E-01	0.060	
2011/4/24 0:00	-1850	-2250	-0.055	-0.091	0.1027	0.1776	1.50E+01	1.12E+01	5.61E-01	5.23E-01	0.070	
2011/4/24 5:50	-1850	-2250	-0.053	-0.089	0.1031	0.1778	1.50E+01	1.12E+01	5.60E-01	5.22E-01	0.060	
2011/4/24 12:00	-1850	-2250	-0.051	-0.091	0.1031	0.1780	1.49E+01	1.11E+01	5.58E-01	5.21E-01	0.070	
4/24 18:00	-1850	-2250	-0.051	-0.091	0.1034	0.1785	1.49E+01	1.11E+01	5.57E-01	5.20E-01	0.070	
4/25 0:00	-1850	-2250	-0.055	-0.089	0.1038	0.1787	1.48E+01	1.11E+01	5.56E-01	5.19E-01	0.070	
4/25 6:00	-1850	-2250	-0.053	-0.089	0.1041	0.1789	1.48E+01	1.11E+01	5.54E-01	5.18E-01	0.070	
4/25 11:00	-1800	-2250	-0.055	-0.091	0.1029	0.1787	1.47E+01	1.10E+01	5.53E-01	5.17E-01	0.050	
4/25 17:00	-1850	-2250	-0.055	-0.089	0.1034	0.1787	1.47E+01	1.10E+01	5.52E-01	5.16E-01	0.050	
4/25 23:00	-1800	-2250	-0.055	-0.091	0.1041	0.1792	1.46E+01	1.10E+01	5.51E-01	5.15E-01	0.050	
4/26 5:00	-1850	-2250	-0.055	-0.087	0.1043	0.1794	1.46E+01	1.10E+01	5.50E-01	5.14E-01	0.040	
4/26 9:00	-1850	-2250	-0.055	-0.089	0.1041	0.1794	1.45E+01	1.09E+01	5.49E-01	5.13E-01	0.040	
4/26 17:00	-1850	-2250	-0.051	-0.089	0.1033	0.1790	1.39E+01	1.09E+01	5.17E-01	5.11E-01	0.050	
4/26 23:00	-1850	-2250	-0.049	-0.089	0.1034	0.1792	1.42E+01	1.09E+01	5.30E-01	5.10E-01	0.050	
4/27 5:00	-1850	-2250	-0.053	-0.089	0.1031	0.1787	1.43E+01	1.09E+01	5.32E-01	5.08E-01	0.050	
4/27 11:00	-1850	-2250	-0.053	-0.089	0.1029	0.1792	1.43E+01	1.08E+01	5.34E-01	5.07E-01	0.040	
4/27 17:00	-1850	-2250	-0.053	-0.089	0.1022	0.1789	1.43E+01	1.08E+01	5.34E-01	5.05E-01	0.050	
4/27 23:00	-1850	-2250	-0.055	-0.087	0.1022	0.1789	1.43E+01	1.08E+01	5.34E-01	5.04E-01	0.045	
4/28 5:00	-1850	-2250	-0.055	-0.089	0.1017	0.1783	1.42E+01	1.08E+01	5.33E-01	5.02E-01	0.050	
4/28 11:00	-1850	-2250	-0.055	-0.089	0.1017	0.1785	1.42E+01	1.07E+01	5.32E-01	5.01E-01	0.050	
4/28 17:10	-1850	-2250	-0.055	-0.085	0.1017	0.1790	1.42E+01	1.07E+01	5.32E-01	5.00E-01	0.050	
4/28 23:00	-1850	-2250	-0.060	-0.089	0.1027	0.1792	1.41E+01	1.07E+01	5.30E-01	4.98E-01	0.040	
4/29 5:00	-1850	-2250	-0.062	-0.091	0.1036	0.1799	1.41E+01	1.06E+01	5.29E-01	4.96E-01	0.050	
4/29 11:00	-1850	-2250	-0.060	-0.091	0.1033	0.1796	1.70E+01	1.06E+01	5.27E-01	4.95E-01	0.050	
4/29 17:00	-1850	-2250	-0.060	-0.089	0.1038	0.1799	1.40E+01	1.06E+01	5.26E-01	4.94E-01	0.050	
4/29 23:00	-1850	-2250	-0.064	-0.089	0.1040	0.1804	1.40E+01	1.05E+01	5.25E-01	4.92E-01	0.050	
4/30 5:00	-1850	-2250	-0.066	-0.091	0.1043	0.1803	1.39E+01	1.05E+01	5.24E-01	4.91E-01	0.040	
4/30 10:00	-1850	-2250	-0.064	-0.091	0.1041	0.1803	1.39E+01	1.04E+01	5.23E-01	4.90E-01	0.040	
4/30 11:30	-1850	-2250	-0.064	-0.091	0.1040	0.1801	1.33E+01	1.04E+01	4.94E-01	4.88E-01	0.040	
4/30 17:00	-1850	-2250	-0.064	-0.091	0.1034	0.1797	1.37E+01	1.04E+01	5.15E-01	4.88E-01	0.040	
4/30 23:00	-1850	-2250	-0.066	-0.089	0.1033	0.1797	1.37E+01	1.04E+01	5.16E-01	4.86E-01	0.050	
5/1 5:00	-1850	-2250	-0.066	-0.089	0.1033	0.1796	1.37E+01	1.03E+01	5.16E-01	4.85E-01	0.050	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
5/1 10:15	-1800	-2250	-0.068	-0.089	0.1027	0.1792	1.37E+01	1.03E+01	5.15E-01	4.84E-01	0.050	
5/1 17:00	-1850	-2250	-0.064	-0.087	0.1012	0.1785	1.36E+01	1.02E+01	5.14E-01	4.82E-01	0.050	
5/1 22:50	-1850	-2250	-0.064	-0.087	0.1013	0.1787	1.35E+01	1.02E+01	5.13E-01	4.81E-01	0.050	
5/2 5:00	-1850	-2250	-0.064	-0.089	0.1019	0.1790	1.34E+01	1.01E+01	5.12E-01	4.80E-01	0.040	
5/2 11:00	-1850	-2250	-0.064	-0.087	0.1019	0.1785	1.33E+01	1.00E+01	5.11E-01	4.79E-01	0.040	
5/2 17:00	-1850	-2250	-0.066	-0.085	0.1022	0.1794	1.32E+01	9.95E+00	5.09E-01	4.77E-01	0.040	
5/2 23:00	-1850	-2250	-0.064	-0.087	0.1027	0.1796	1.32E+01	9.88E+00	5.09E-01	4.76E-01	0.040	
5/3 5:00	-1850	-2250	-0.068	-0.089	0.1038	0.1806	1.31E+01	9.81E+00	5.08E-01	4.75E-01	0.050	
5/3 11:00	-1850	-2250	-0.070	-0.089	0.1031	0.1796	1.30E+01	9.74E+00	5.06E-01	4.74E-01	0.035	
5/3 17:00	-1850	-2250	-0.070	-0.091	0.1031	0.1799	1.29E+01	9.68E+00	5.05E-01	4.72E-01	0.050	
5/3 23:00	-1850	-2250	-0.072	-0.089	0.1033	0.1799	1.28E+01	9.62E+00	5.04E-01	4.71E-01	0.050	
5/4 5:00	-1850	-2250	-0.068	-0.089	0.1034	0.1799	1.27E+01	9.57E+00	5.03E-01	4.70E-01	0.050	
5/4 11:00	-1800	-2200	-0.077	-0.091	0.1033	0.1803	1.27E+01	9.52E+00	5.02E-01	4.69E-01	0.045	
5/4 14:00	-1850	-2200	-0.074	-0.091	0.1027	0.1801	1.26E+01	9.50E+00	5.01E-01	4.68E-01	0.045	
5/4 17:00	-1850	-2250	-0.072	-0.089	0.1029	0.1804	1.52E+01	9.47E+00	5.00E-01	4.68E-01	0.045	
5/4 23:00	-2000	-2250	-0.074	-0.089	0.1036	0.1813	1.23E+01	9.42E+00	4.99E-01	4.66E-01	0.040	
5/5 2:00	-2050	-2250	-0.074	-0.089	0.1038	0.1815	1.24E+01	9.40E+00	4.99E-01	4.66E-01	0.040	
5/5 5:00	-2050	-2200	-0.077	-0.089	0.1038	0.1817	1.27E+01	9.39E+00	4.98E-01	4.65E-01	0.045	
5/5 11:00	-2050	-2200	-0.074	-0.091	0.1038	0.1824	1.26E+01	9.37E+00	4.97E-01	4.64E-01	0.045	
5/5 17:00	-2000	-2200	-0.077	-0.091	0.1038	0.1827	1.24E+01	9.36E+00	4.95E-01	4.62E-01	0.045	
5/5 23:00	-2000	-2200	-0.077	-0.089	0.1041	0.1829	1.24E+01	9.35E+00	4.94E-01	4.60E-01	0.035	
5/6 5:00	-2000	-2150	-0.079	-0.089	0.1045	0.1834	1.24E+01	9.34E+00	4.92E-01	4.59E-01	0.040	
5/6 11:00	-2100	-2200	-0.079	-0.091	0.1043	0.1836	1.24E+01	9.33E+00	4.90E-01	4.57E-01	0.045	
5/6 17:00	-2050	-2100	-0.077	-0.089	0.1040	0.1836	1.24E+01	9.31E+00	4.89E-01	4.56E-01	0.045	
5/6 23:00	-2000	-2050	-0.081	-0.091	0.1040	0.1836	1.23E+01	9.30E+00	4.88E-01	4.55E-01	0.045	
5/7 5:00	-2050	-2150	-0.081	-0.091	0.1036	0.1836	1.23E+01	9.28E+00	4.87E-01	4.53E-01	0.040	
5/7 11:00	-2050	-2150	-0.079	-0.091	0.1027	0.1832	1.23E+01	9.27E+00	4.85E-01	4.52E-01	0.040	
5/7 17:00	-2050	-2150	-0.079	-0.089	0.1026	0.1832	1.23E+01	9.25E+00	4.84E-01	4.51E-01	0.040	
5/7 23:00	-2000	-2100	-0.083	-0.089	0.1022	0.1831	1.23E+01	9.24E+00	4.83E-01	4.49E-01	0.040	
5/8 5:00	-2100	-2150	-0.085	-0.089	0.1020	0.1832	1.22E+01	9.22E+00	4.81E-01	4.48E-01	0.040	
5/8 11:00	-2100	-2150	-0.081	-0.087	0.1015	0.1834	1.22E+01	9.21E+00	4.79E-01	4.47E-01	0.040	
5/8 17:00	-2100	-2150	-0.077	-0.083	0.1013	0.1836	1.22E+01	9.19E+00	4.78E-01	4.45E-01	0.040	
5/8 23:00	-2100	-2150	-0.083	-0.083	0.1022	0.1839	1.22E+01	9.17E+00	4.77E-01	4.44E-01	0.040	
5/9 5:00	-2100	-2150	-0.085	-0.091	0.1027	0.1841	1.21E+01	9.16E+00	4.77E-01	4.44E-01	0.045	
5/9 11:00	-1900	-2100	-0.081	-0.091	0.1026	0.1843	1.21E+01	9.14E+00	4.76E-01	4.43E-01	0.041	
5/9 17:00	-1850	-2100	-0.079	-0.087	0.1020	0.1841	1.21E+01	9.13E+00	4.75E-01	4.42E-01	0.040	
5/9 23:00	-1850	-2100	-0.083	-0.089	0.1019	0.1839	1.21E+01	9.11E+00	4.75E-01	4.41E-01	0.040	
5/10 5:00	-1800	-2100	-0.079	-0.085	0.1008	0.1834	1.21E+01	9.10E+00	4.73E-01	4.40E-01	0.040	
5/10 11:00	-1800	-2100	-0.079	-0.083	0.1006	0.1836	1.20E+01	9.09E+00	4.71E-01	4.38E-01	0.041	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]

Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
5/10 17:00	-1750	-2000	-0.083	-0.085	0.1013	0.1841	1.20E+01	9.07E+00	4.69E-01	4.35E-01	0.041	
5/10 23:00	-1750	-2000	-0.081	-0.091	0.1020	0.1841	1.20E+01	9.05E+00	4.66E-01	4.33E-01	0.042	
5/11 5:00	-1750	-2000	-0.081	-0.096	0.1022	0.1841	1.19E+01	9.03E+00	4.64E-01	4.31E-01	0.038	
5/11 11:00	-1750	-2000	-0.087	-0.091	0.1022	0.1845	1.19E+01	9.01E+00	4.62E-01	4.29E-01	0.034	
5/11 17:00	-1750	-2000	-0.087	-0.091	0.1022	0.1843	1.19E+01	9.00E+00	4.61E-01	4.27E-01	0.040	
5/11 22:50	-1750	-1950	-0.089	-0.096	0.1026	0.1843	1.20E+01	8.99E+00	4.59E-01	4.26E-01	0.040	
5/12 5:00	-1750	-1950	-0.089	-0.096	0.1024	0.1843	1.18E+01	8.96E+00	4.57E-01	4.24E-01	0.038	
5/12 9:15	-1700	-1950	-0.087	-0.096	0.1026	0.1843	1.18E+01	8.95E+00	4.56E-01	4.23E-01	0.040	
5/12 11:15	-1700	-1950	-0.087	-0.096	0.1027	0.1846	1.12E+01	8.95E+00	4.28E-01	4.21E-01	0.041	
5/12 16:50	-1700	-1950	-0.089	-0.096	0.1020	0.1839	1.17E+01	8.92E+00	4.50E-01	4.21E-01	0.032	
5/12 20:00	-1750	-2000	-0.087	-0.096	0.1019	0.1839	1.17E+01	8.64E+00	4.50E-01	4.21E-01	0.034	
5/12 23:00	-1700	-1950	-0.089	-0.096	0.1012	0.1836	1.17E+01	8.56E+00	4.51E-01	4.20E-01	0.034	
5/13 2:00	-1650	-1900	-0.091	-0.091	0.1006	0.1832	1.17E+01	8.50E+00	4.50E-01	4.20E-01	0.032	
5/13 5:00	-1800	-1900	-0.091	-0.094	0.1003	0.1832	1.17E+01	8.44E+00	4.50E-01	4.19E-01	0.032	
5/13 8:00	-1800	-1900	-0.091	-0.094	0.1005	0.1834	1.17E+01	8.38E+00	4.49E-01	4.18E-01	0.032	
5/13 11:00	-1800	-2250	-0.089	-0.091	0.0998	0.1839	1.16E+01	8.28E+00	4.49E-01	4.18E-01	0.038	
5/13 14:00	-1800	-2250	-0.085	-0.087	0.0996	0.1843	1.16E+01	8.19E+00	4.48E-01	4.17E-01	0.035	
5/13 17:00	-1800	-2250	-0.083	-0.085	0.0998	0.1846	1.15E+01	8.09E+00	4.48E-01	4.16E-01	0.035	
5/13 20:00	-1800	-2250	-0.087	-0.087	0.0999	0.1843	1.15E+01	7.98E+00	4.47E-01	4.16E-01	0.045	
5/13 23:00	-1850	-2250	-0.094	-0.087	0.1005	0.1850	1.13E+01	7.77E+00	4.46E-01	4.15E-01	0.040	
5/14 2:00	-1850	-2250	-0.089	-0.089	0.1008	0.1850	1.11E+01	7.57E+00	4.46E-01	4.14E-01	0.038	
5/14 5:00	-1800	-2250	-0.091	-0.091	0.1012	0.1853	1.10E+01	7.36E+00	4.46E-01	4.14E-01	0.040	
5/14 8:00	-1800	-2250	-0.091	-0.091	0.1010	0.1855	1.08E+01	7.19E+00	4.45E-01	4.13E-01	0.038	
5/14 11:00	-1800	-2250	-0.085	-0.087	0.1005	0.1857	1.06E+01	6.98E+00	4.45E-01	4.13E-01	0.038	
5/14 14:00	-1900	-2250	-0.089	-0.087	0.1003	0.1859	1.05E+01	6.77E+00	4.44E-01	4.12E-01	0.038	
5/14 17:00	-1800	-2250	-0.085	-0.085	0.1006	0.1867	1.03E+01	6.61E+00	4.44E-01	4.12E-01	0.033	
5/14 20:00	-1800	-2250	-0.083	-0.083	0.1010	0.1874	1.02E+01	6.45E+00	4.43E-01	4.11E-01	0.036	
5/14 23:00	-1800	-2250	-0.085	-0.083	0.1013	0.1881	1.40E+01	6.33E+00	4.43E-01	4.10E-01	0.035	
5/15 2:00	-1850	-2250	-0.085	-0.085	0.1013	0.1887	1.07E+01	6.24E+00	4.45E-01	4.11E-01	0.033	
5/15 5:00	-1900	-2250	-0.085	-0.085	0.1020	0.1892	1.00E+01	6.15E+00	4.46E-01	4.13E-01	0.037	
5/15 8:00	-1900	-2300	-0.089	-0.089	0.1020	0.1892	9.90E+00	6.08E+00	4.12E-01	4.46E-01	0.036	
5/15 9:00	-1900	-2300	-0.087	-0.089	0.1020	0.1894	9.93E+00	6.06E+00	4.12E-01	4.46E-01	0.035	
5/15 11:00	-1950	-2300	-0.089	-0.087	0.1022	0.1895	9.90E+00	6.01E+00	4.45E-01	4.12E-01	0.035	
5/15 14:00	-2000	-2300	-0.085	-0.085	0.1015	0.1899	9.83E+00	5.94E+00	4.44E-01	4.11E-01	0.035	
5/15 17:00	-2000	-2300	-0.085	-0.085	0.1020	0.1908	9.90E+00	5.88E+00	4.44E-01	4.10E-01	0.035	
5/15 20:00	-2000	-2300	-0.085	-0.085	0.1020	0.1904	9.72E+00	5.83E+00	4.43E-01	4.10E-01	0.035	
5/15 23:00	-2000	-2300	-0.085	-0.085	0.1024	0.1911	9.66E+00	5.77E+00	4.42E-01	4.09E-01	0.035	
5/16 2:00	-2000	-2300	-0.085	-0.087	0.1024	0.1911	1.02E+01	5.72E+00	4.41E-01	4.08E-01	0.037	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Feedwater Nozzle N4B	RPV Bottom Head	RPV Flange	Reactor Pressure Vessel Bottom Part	RPV Stud	RPV Flange Lower Part	Safety Relief Valve 2-71D Leakage	Safety Relief Valve 2-71F	Main Steam Isolation Valve 2-86A Leak-off	D/W HVH Return Duct Air	RPV Bellows Air	S/C Pool Water A	S/C Pool Water B	note
3/19 6:30	335	286	231	328	329	332	189	271	89	313	349			
3/19 8:20	331	295	228	352			189	271	90	312	346			
3/19 8:30	331	296	230	350			189	271	90	312	346			
3/19 17:00	339	327	228	333			164	281	89	322	316			
3/20 0:25	312	295	261	323	347	275	173	267	95	299	319			
3/20 0:50		291							94	297				
3/20 1:00		288							94	294				
3/20 3:10	306	277	272	304	356	264	176	249	92	284	329			
3/20 3:50				301					93	282				
3/20 4:20				300					93	278				
3/20 10:00	241	215	309	251	287	252	269	197	93	225	342			
3/20 10:10	216.9			249.2					92.9	223.9				
3/20 10:35				246.6					92.6	221.9				
3/20 15:00				220					90.9	186.5				
3/20 15:00	139.4	163	347		371	225	303	155			363			
3/20 15:35	138.8			217.7					90.7	183.5				
3/20 16:00	135			216.1					90.5	181.2				
3/20 16:30		307					307	154						
3/20 19:40				198.3					89.7	156.9				
3/20 19:40	95.4	136.7	393		359.9	228.2	296.9	137.7			382.1			
3/20 20:00	90.3			198.2					89.6	156.2				
3/21 1:25	175			219.8					85.6	138				
3/21 1:25		165.7	558.8		327.7	360.4	559.3				382.7			
3/21 1:45	-131.4			217				-133.2	85.1	136.5				
3/21 2:30	171			214				202.7	85.5	134.8				
3/21 4:00	170.4			223.6				172.6	85	130.1				
3/21 8:00	155.3			139.3				169.3	85.9	167.2				
3/21 10:00	155.3	-131.6	-131.5	139.3	218	404.2	532.3	169.3	85.9	171.1	280.3			
3/21 12:15	133.4			146.8				177.2	86.6	126.3				
3/22 22:39														
3/22 22:40				218						403.4	-141.1			
3/22 22:40	-139.4	128.1	-139.7		-138.4	533.1	-141.3	-106.2	69.6					
3/23 3:00							-134.7	-78.4		353.1	-133.5			
3/23 3:30	278.6	49.4	-135	253.4	-129.1	504.3	-134.6	-75.9	71.6	356	-133.3			
3/23 4:00	279		-135	253			-135	-76		356	-134			
3/23 8:45	316.4	122.3	-132.2	221.5	-129.2	481.4	-134.3	0.1	73	304.8	-133.5			
3/23 9:10	304.8		-132.2	225.5			-134.2	-14.2		317.5	-133.6			
3/23 13:40	271.2		-132.3	203.1			-74.2	55.2		337	-133.4			
3/23 13:50	271.2	121.4	-132.3	203.1	-129.6	417.5	-74.2	55.2	73.5	337	-133.4			
3/23 21:10	215.4		-87.4	195.6			21.5	71		225.7	-133.6			
3/23 21:25	215.7	110.1	-65.3	195.8	-78.5	385.9	22	70.2	73.2	225.5	-133.6			
3/23 21:40	212.4		-64.8	195.3			20.4	68.7		223.8	-133.6			
3/24 2:20	80.7		-108	185.4			58.3	79.3		214	-133.6			
3/24 2:25	70.7	93.6	-115.2	183.6	-128.6	347.5	60.6	78.7	72.4	210.8	-133.6			
3/24 6:20	99.5		-81.8	193.3			82.8	70.7		194.8	-2.4			
3/24 6:45	104.9		-80.9	194.8			85.6	65.6		193.2	7.3			
3/24 10:00	33.3		-107	186			82.2	66.3		152.1	-108.7			
3/24 10:00		27.9			-43.7	316.1			70.7					
3/24 10:20	14.1		-124.6	185.5			81.1	72.8		156.4	-102.3			
3/24 18:00	65.6		-124.6	155.7			101.5	85.6		151.9	-33.9			
3/24 18:00				155.7					70.5					
3/24 21:00	54.1	35.8	-81	156.4	171.8	329	125.9	88.9	69.7	138	-28.4			
3/24 21:20	53	33.9	-87	155	173.3	324.6	131.5	90.3	69.6	137	-24.9			
3/24 21:40	60.5		-85.4	150.9			131.5	91.2		137.3	-21.5			
3/24 21:40		38.7			168.4	318.1			69.8					
3/24 22:00	22.4		-83.7	147.5			136.6	87.8		138.4	-18			
3/24 22:00		45.9			163.8	312.1			69.8					
3/24 23:30	55.9		-57.9	135.2			148	97.1		138.7	1.4			
3/24 23:30		63.1			167.8	277.5			69.7					
3/25 0:30	11		-57.3	133.8			151.9	94.8		-32.2	7.4			
3/25 0:30		62			183	270.9			69.7					
3/25 5:30	43.8		-14.5	115.9			191	107.3		-8.9	25.6			
3/25 5:30		20.9			153.2	243			68.9					
3/25 6:10	42.8		-1.5	111.6			193.4	107.1		-28.4	30			
3/25 9:30	43.3		47.3	107.8			216.6	100.4		-40.7	28.9			
3/25 14:10	19.7		31.6	104.4			213.7	85		-88.2	19.4			
3/25 14:10		2			120.9	202.7			74.5					
3/25 16:10	-33.4		41.3	111			31.7	74.3		-109.6	-36.4			
3/25 16:10		-132.9			521.1	266.5			73.6					
3/25 18:10	-8.4		29.4	86.1			120.9	65.9		-135.6	-135.2			
3/25 18:10		-133			220.9	256			72.3					
3/25 19:10	-5.3		23.3	99.2			150.4	70.6		-135.7	-135.2			

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Feedwater Nozzle N4B	RPV Bottom Head	RPV Flange	Reactor Pressure Vessel Bottom Part	RPV Stud	RPV Flange Lower Part	Safety Relief Valve 2-71D Leakage	Safety Relief Valve 2-71F Leakage	Main Steam Isolation Valve 2-86A Leak-off	D/W HVH Return Duct Air	RPV Bellows Air	S/C Pool Water A	S/C Pool Water B	note
3/25 19:10		-133			164.6	238.6			72.4					
3/25 21:10	-0.8		13	93.9			178.4	74.2		-135.7	-63.8			
3/25 21:10		-100.3			132.8	226.9			72.5					
3/25 22:00	-2.5		4.2	95.8			173.5	71.4		-135.6	-33.3			
3/25 23:00	3.9		16.3	97			177.8	73.3		-135.6	-19.2			
3/25 23:00		-52.8			129.5	219.4			72.4					
3/26 4:20	21.2		37.9	99.4			173.7	75.3		-106.6	6.6			
3/26 4:20		-17.6			119.2	195.8			71.8					
3/26 5:05	26.1		41.2	102.5			169.2	83.8		-119.8	9			
3/26 10:00	37.6		48.4	106.1			172	79.2		-49.7	39.7			
3/26 10:00		-49.9			97.5	216.5			71.7					
3/26 11:15	33.7		46.4	100.4			169	79.3		-57.8	45			
3/26 14:30	35.7		55.2	99.4			163.5	78.5		-23.7	35.1			
3/26 16:00	35.3		57.8	102.8			160.2	78.2		-46.4	27.5			
3/26 16:00		41.6			105.6	212.5			71.1					
3/26 20:00	41.9		61.9	107			161.4	83		3.7	40.6			
3/26 21:00	41.7	66.4	62.4	106.5	88.2	201.1	156.7	83.1	70.8	8.4	43.3			
3/26 21:20	41.7		62.4	106.5			156.7	83.1		8.4	43.3			
3/26 23:00	15.1	75.5	66.2	104.8	87.6	201.2	151.4	81.7	70.4	2.4	49			
3/26 23:10	15.1		66.2	104.8			151.4	81.7		2.4	49			
3/27 4:15	-7.9		67.2	106.5			139.9	85.3		49.3	45.8			
3/27 4:15		79.7			91.1	197.1			69.1					
3/27 4:45	-1.7		66.7	106.8			138.6	85.6		48.8	49.9			
3/27 9:25	16.3		73	122.7			135.3	90.5		38.3	73.3			
3/27 9:25		71.6			85.3	184.8			68.5					
3/27 10:10	13.6		72.7	121.6			133.1	90.2		38.4	74			
3/27 16:00	33.1		75.1	123.8			125.5	86.4		33.5	71.1	59.1		
3/27 16:00		101.4			82.9	187.2			67.4					
3/27 16:25	28.2		75.4	124.6			123.3	85.6		34.7	73.1	59.1		
3/27 17:30	33.8		75	123.1			132.2	82		35.8	55.9	59.1		
3/27 17:30		97.2			81.9	200.3			67					
3/27 18:30	39.1		76.2	122.5			127	81.5		41.4	43.4	59		
3/27 19:00	41.9		77.5	121.7			139.7	78		40.1	25.2	59		
3/28 0:00	38.1		82	123.6			131.9	90.1		56.7	82.9	58.7		
3/28 0:00		102.9			82.8	170			66.3					
3/28 0:50	38.2		82.6	122.6			132.7	90.2		61.1	81	58.7		
3/28 5:00	36.7		83.7	124			130.5	91.2		67.4	71.8	58.4		
3/28 5:00		100.5			81.6	173.4			65.4					
3/28 5:30	38		84.5	123			130.7	91.5		64.9	72.9	58.4		
3/28 10:00	39.1		83.6	123.8			125.5	92.1		59.2	74.3	58.2		
3/28 10:00		98.2			81.6	156.7			65					
3/28 10:30	41.9		83.1	124.4			125.5	91.2		59.6	75.4	58.1		
3/28 15:00	48		81.5	123.1			122.5	92.3		41.5	76.6	57.9		
3/28 15:00		100.4			82.0	157.3			65.0					
3/28 16:00	47.6		82.3	121.8			111.7	92.6		48.6	75.7	57.9		
3/28 19:30	46.3		81	122.7			-4.4	93.8		37.7	77.9	57.7		
3/28 19:30		110.6			81.6	155.0			65.0					
3/28 20:35	49.6		81.5	122.8			41.3	94.4		43.7	79.4	57.6		
3/28 20:35		68.2			82.8	155.2			64.7					
3/28 21:10	48.2		82.2	122.8			41.9	94.3		33.8	80	57.6		
3/28 21:20	49.7		82.3	122.9			42.3	94.5		21.7	79.6	57.6		
3/28 21:40	52.4		82	121.7			41.6	94.5		27.8	80	57.6		
3/28 23:00	53.7	73.7	81.5	121.9	77.9	153.5	40.5	94.8	64.3	40	81.1			
3/28 23:30	53.7		81.5	121.9			40.5	94.8		40	81.1	57.5		
3/29 0:00	53.8		81.6	121.8			43	95.1		37.2	81.1	57.5		
3/29 4:45	61.5		82	120.9			37.8	96.7		45.3	80.1	57.2		
3/29 4:45		80.8			79.5	157.6			64.1					
3/29 5:15	61.6		82	120.4			36.4	95.7		45	79.9	57.2		
3/29 10:15	63.8		82.6	118.9	49.6	156.5				21.5	82.4	57		
3/29 10:15		82.8					29	96.3	63.9					
3/29 10:45	62.9		83.2	111.1	51.1	148.8				29	82.2	57		
3/29 12:00	62.2		83.4	121.2	51.7	150.4				18.1	82.3	56.9		
3/29 14:30	62.3		82.9	120.7	49.3	152.3				36.3	81.1	56.8		
3/29 14:30		82.9					19.8	96.7	64.5					
3/29 15:15	63.2		82.3	120.9	34.2	153.4				36.4	80.4	56.8		
3/29 15:45	64.5		82	120.5	36.2	153.1				29.3	80.4	56.8		
3/29 16:10	64.6	85.7	82	120.7	37.7	152.7	17.5	96.5	64.6	38.9	80.5			
3/29 16:50	64.1		80.7	119.7	40.4	154.5				31.9	79.9	56.7		
3/29 22:10	77.2		70.1	114.6	71.5	163.2				39.1	62.9	56.5		
3/29 22:10		93.6					38.2	87	64.6					
3/29 23:00	77.5		69.9	113.7	73	162.1				38.6	59.9	56.5		
3/29 23:00		93.2					36.8	86.9	64.6					

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Feedwater Nozzle N4B	RPV Bottom Head	RPV Flange	Reactor Pressure Vessel Bottom Part	RPV Stud	RPV Flange Lower Part	Safety Relief Valve 2-71D Leakage	Safety Relief Valve 2-71F Leakage	Main Steam Isolation Valve 2-86A Leak-off	D/W HVH Return Duct Air	RPV Bellows Air	S/C Pool Water A	S/C Pool Water B	note
3/30 3:20	76.8		67.5	115.4	72	172.2				38.5	100.5	56.3		
3/30 3:20		81.2					35.4	94.9	64.5					
3/30 3:50	75.3		67.3	116	72.5	170.7				41.5	102.7	56.3		
3/30 8:30	75.2		62.7	115.9	72.6	165.4				52.5	87.3	56.2		
3/30 8:30		79.8					45.9	98.7	64.4					
3/30 13:00	77.1		63.5	115	74	165.8				56.4	89.5	55.9		
3/30 13:00		80.9					47.8	98.7	64.8					
3/30 13:30	76.7		64.4	115.4	73.7	165				57.8	90.3	55.9		
3/30 18:20	78.7		52.1	114.2	77	164				56.7	90.7	55.7		
3/30 18:20		86.8					53.8	98.6	65.1					
3/30 19:00	79.5		49.5	114.5	77.5	164				55.7	90.8	55.7		
3/30 23:20	81.5		50.4	113.1	76.3	157.4				49.7	93.4	55.5		
3/30 23:30	82.9	91.2	50.1	113.1	76.1	157.8	53.7	99.1	64.8	43.1	93.2			
3/30 23:50	83.5		50.5	113.2	76.9	158.3				39.1	93.7	55.5		
3/31 4:10	85		50.7	113.8	77	156.5				69.2	95.3	55.4		
3/31 4:20	87.8	90.9	50.5	113.9	76.8	156.1	58.9	98.9	64.6	69.3	95.3			
3/31 4:40	88.5		53.7	114.2	76.6	157.7				69.7	93.7	55.3		
3/31 9:40	88.6		57.4	114.4	78	155.5				73.8	96.7	55.2		
3/31 9:40		92.2					70.3	98.7	64.6					
3/31 16:10	93.4		52.5	115	80.2	156.2				72.4	99	55		
3/31 16:10		97					70.9	98.6	65					
3/31 16:45	93		53.2	115.4	80.2	155.4				72.8	98.9	55		
3/31 19:00	92.2		53.8	114.8	81.5	157.2				72.6	97.8	54.9		
3/31 19:00		97.8					73.8	96.9	64.4					
3/31 19:30	93.9		54.7	114.6	81.3	161.2				73.1	109.8	54.9		
3/31 19:50	94.4		55.3	114.1	80.9	163.5				73.6	104.2	54.9		
4/1 0:00	100.9		61.8	112.4	80.4	155.5				77.3	117.4	54.7		
4/1 0:00		98.1					84.9	93.2	63.8					
4/1 0:45	100.8		60.6	112.3	80.8	156.5				79.2	110.9	54.7		
4/1 5:15	92.7		59.4	115.9	83.6	158.8				73.5	105.9	54.6		
4/1 5:15		98.6					57.9	97.6	63.8					
4/1 5:45	92.6		59	116.3	83.4	159.1				73.6	103.4	54.6		
4/1 11:10	89.2		63	117.5	85.1	156				74.8	98.2	54.4		
4/1 11:10		98.8					67.1	98.3	64.1					
4/1 11:45	90.2		63.8	117.8	84.7	155.8				73.5	98.1	54.4		
4/1 15:00	90.9		63.8	118.6	86	151.2				75.5	98.6	54.3		
4/1 15:00		98.6					74.4	98.2	64.5					
4/1 15:30	90		63.9	118.3	85.6	149				76.7	98.8	54.3		
4/1 20:00	91.6		71.3	118.5	86	156				81.4	101	54.1		
4/1 20:00		100.4					79.7	98.1	64.5					
4/1 20:30	91.5		71.3	118.6	85.8	155.9				81.7	101	54.1		
4/2 1:00	90.7		73.9	119.4	87.6	156.3				84.2	102.5	54		
4/2 1:00		101.6					81.4	98.3	64.3					
4/2 1:30	90.8		73.8	119.4	86.4	155.7				82.5	103.1	54		
4/2 5:55	91.9		77.2	119.4	87.3	153.8				83.1	103	53.8		
4/2 5:55		101.1					58.5	97.8	64.4					
4/2 6:25	91.9		79.7	119.6	87.7	153.6				83.2	103.5	53.8		
4/2 11:05	93.3		78	119.6	88	154.8				88.4	104.7	53.7		
4/2 11:05		98.9					79.1	97.8	64.7					
4/2 11:40	91.9		79.3	118.9	88.2	154.9				89.1	104.2	53.7		
4/2 12:10	92.3		78.7	117.8	88.2	156.3				90.5	103.9	53.7		
4/2 12:10		100.7					67.6	96.7	64.7					
4/2 16:00	96.3		81.5	115	85.8	165.1				91.1	119.3	53.6		
4/2 16:00		102.8					79.1	92.1	64.7					
4/2 16:30	96.7		81.3	114.6	85.4	165.4				90	123.8	53.6		
4/2 21:00	93.8		82	114.9	87	160.6				64	129.9	53.5		
4/2 21:00		101.0					69.9	95.3	64.4					
4/2 21:30	93.9		81.8	114.7	87.6	160.9				74	127.4	53.4		
4/3 2:00	90.7		78.7	115.7	88.4	155.1				83.2	104.9	53.3		
4/3 2:00		100.0					56.6	99.4	63.7					
4/3 2:30	90.6		72.4	115.9	88.4	155.5				80.7	104.8	53.3		
4/3 7:00	91.3		82	115.7	90.4	156.6				91	106.2	53.2		
4/3 7:00		99.9					69.4	98.9	63.0					
4/3 7:30	91.2		82.3	115.5	90.6	157.1				90.8	106	53.1		
4/3 9:15	90.5		81.6	114.8	90.5	156.4				91	105.9	53.1		
4/3 9:15		102.2					66.9	98.9	63.2					
4/3 10:00	89.5		83	115.1	90.8	156				91.1	106.3	53.1		
4/3 10:30	90.6		83	114.3	90.7	156.5				94.2	106.2	53.1		
4/3 10:30		101.4					66.5	98.5	63.3					
4/3 11:00	89.6		83.1	114	90.8	156				92.1	106.7	53.1		
4/3 12:00	88.7		82.8	114.1	90.8	155.4				94.2	106.3	53		
4/3 12:00		101.7					59.5	98.6	63.3					

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	Feedwater Nozzle N4B	RPV Bottom Head	RPV Flange	Reactor Pressure Vessel Bottom Part	RPV Stud	RPV Flange Lower Part	Safety Relief Valve 2-71D Leakage	Safety Relief Valve 2-71F Leakage	Main Steam Isolation Valve 2-86A Leak-off	D/W HVH Return Duct Air	RPV Bellows Air	S/C Pool Water A	S/C Pool Water B	note
4/3 12:30	89.6		82.2	114.1	91	155.3				94.3	106.4	53		
4/3 13:00	89.7		82.9	114.3	91.4	154.7				94.5	106.4	53		
4/3 13:30	89.7		81.7	113.9	91.3	154.6				95	106.2	53		
4/3 17:00	89.9		79.7	113.4	91.6	155.1				95.9	107.8	52.9		
4/3 17:00		100.2					34.8	98.5	63.8					
4/3 17:35	89.9		79.3	113.5	91.5	154.9				93.8	108.4	52.9		
4/3 18:00	88		80.1	113.4	91.3	155.2				95.3	108.3	52.9		
4/3 18:00		99.3					35.1	98.7	63.7					
4/3 21:00	88.3		81.5	113.8	91.7	155.8				91.6	108.3	52.8		
4/3 21:00		100.6					37.7	98.5	63.5					
4/3 22:00	88.8		79	113.8	91.4	155.1				93.2	108.5	52.8		
4/4 3:00	89.6		81.5	114.1	92.8	154.7				92.8	109.2	52.6		
4/4 3:00		100.9					41.0	98.8	62.5					
4/4 3:30	89.8		80.1	114.1	92.2	155.4				94.9	109.4	52.6		
4/4 8:00	89.4		78.7	114.4	93.2	154.8				94.1	109.6	52.5		
4/4 8:00		104.7					44.0	99.0	62.3					
4/4 8:30	89.4		80.1	113.3	93.4	154.9				93	109.6	52.5		
4/4 9:30	90		80.8	113.7	93.6	154.3				93.7	109.8	52.5		
4/4 14:30	89.8		80.4	113.5	94.6	155.9				95.6	109.8	52.3		
4/4 14:30		104.2					48.5	99.0	63.3					
4/4 18:30	88.0		81.5	113.7	96.4	157.4				94.8	110.0	52.2		
4/4 18:30		105.1					51.1	98.7	63.4					
4/4 19:00	88.8		80.4	113.5	96.4	156.4				93.6	110.1	52.2		
4/5 0:00	90.2		82.5	106.7	97.7	167.4	52.2	95.3	62.3	89.3	124.5	52.1		
4/5 0:30	89.9		81.3	107.4	97.9	167.7	44.8	95.2	62.3	89.7	128.3	52.1		
4/5 5:10	81.5		79.2	113.5	98.4	160.5				94.2	110.5	51.9		
4/5 5:10		105.9					52.7	99.4	62.2					
4/5 5:40	84.7		80.1	113.7	98.1	159.9				92.7	109.9	51.9		
4/5 10:20	84.7		80.8	114.1	99.4	158.1				94.6	108.1	51.8		
4/5 10:20		106.5					59.4	99.5	62.7					
4/5 17:10	81.7		80	114.1	98.3	155.7				97.9	108.6	51.6		
4/5 17:10		107.7					46.1	99.3	63.5					
4/5 18:30	83.5		81.1	114.1	98.2	155.6				95.9	108.8	51.5		
4/6 0:00	84.4		84.1	114.1	99.2	154.9				97.3	109.5	51.4		
4/6 0:00		107.4					63.5	99.4	63.7					
4/6 6:30	74.6		83.6	114.7	99	154.6				94.6	110	51.2		
4/6 6:30		109.5					52.3	100.5	63.4					
4/6 12:30	78.8		84.9	115	99.3	152.7				94.9	110.6	51		
4/6 12:30		104.1					42.0	99.1	64.0					
4/6 18:00	83		85.2	114.2	99.9	153.6				97.3	110.7	50.8		
4/6 18:00		108.6					51.7	89.8	64.1					
4/7 0:00	78.2		85.8	115.6	100	153.9				96.8	111.9	50.6		
4/7 0:00		108.6					51.9	98.7	64					
4/7 6:00	83.4		86.2	115.8	99.8	152.5				96.8	114.2	50.4		
4/7 6:15	82.9		84.8	116.0	98.3	152.2	46.8	98.6	63.7	96.6	114.1			
4/7 12:00	88.3		84.8	112.3	97.6	153.3				97.3	189.6	50.2		
4/7 12:00		108.6					47.9	97.6	63.8					
4/7 12:40										95.5	197.3			
4/7 12:40							46.6	97.6		95.5				
4/7 18:00	85.7		84.7	111.6	98	145				93.3	138.1	50.1		
4/7 18:00		107.7					44.4	99.4	63.7					
4/7 19:30	86.6		84	111.6	98.4	144.5				91.9	135.1	50		
4/8 1:30	88.2		80.9	110.8	103.7	135.2				86.6	140	49.8		
4/8 1:35	87.8		80.6	111.1	103.4	135.7	95.1	99.9	113.4	86.3	144.4			
4/8 6:00	85.9		84.2	111.2	101.9	134.9				83.6	140.2	49.7		
4/8 6:15	85.8		84.7	110.9	102.5	135.1	82.3	99.4	63.3	83.9	140.4			
4/8 6:40	86.3		84.6	110.5	102.3	135.7				85.3	141	49.6		
4/8 12:00	88.8		84.3	110.7	120	134.2				83.8	144.6	49.5		
4/8 12:00		104.4					86.5	98.6	63.8					
4/8 18:00	86.3		84	111.1	109.1	139				85.4	145.1	49.3		
4/8 18:00		104.9					86.1	99.5	63.6					
4/9 0:00	99.2		84.3	107.5	102.4	144.3				86.1	182.8	49.1		
4/9 0:00		104					92.7	97.7	63.8					
4/9 6:15	96.6		75.5	109.4	100.6	141.1				76.2	146.9	48.9		
4/9 6:15		100.5					81.1	100.5	63.5					
4/9 12:25	96.6		73.4	109.2	100.4	140.4				83.5	138.8	48.8		
4/9 12:25		99.8					81.1	100.9	63.3					
4/9 18:25	97.3		68.9	109.8	100.1	140				81.6	144.5	48.6		
4/9 18:25		103.6					88.5	100.7	63.1					
4/10 0:00	98.7		68.1	110.4	102.3	139.9				87	149.7	48.4		
4/10 0:00		105.2					84.8	100.9	62.0					
4/10 6:00	91.7		58.9	110.8	104.8	139.5				89.1	153.9	48.3		

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/14 21:15	175.0	55.0	150.0	54.3
2011/3/15 10:00		55.3		54.5
2011/3/15 11:20		55.8		55.0
2011/3/15 12:00	188.1	56.1	150.0	55.5
2011/3/15 12:30	188.4	56.3	150.5	55.5
2011/3/15 13:00	189.3	56.4	150.7	55.5
2011/3/15 13:30	190.1	56.6	150.9	55.5
2011/3/15 14:00	190.9	56.7	151.3	55.5
2011/3/15 14:30	191.6	56.9	151.6	55.5
2011/3/15 15:00	192.4	57.0	151.8	56.0
2011/3/15 15:30	193.3	57.2	152.2	56.0
2011/3/15 16:00	194.0	57.3	152.5	56.0
2011/3/15 17:00	195.5	57.6	153.2	56.0
2011/3/15 18:00	196.9	57.9	153.9	56.0
2011/3/15 19:00	199.1	58.1	154.5	57.0
2011/3/15 20:00	170.6	58.5	155.0	57.0
2011/3/15 21:00	167.0	58.7	155.7	57.0
2011/3/15 22:00	168.4	58.9	156.2	57.0
2011/3/15 23:00	170.9	59.2	156.8	57.5
2011/3/16 0:00	172.8	59.5	157.4	57.5
2011/3/16 1:00	175.0	59.7	154.9	58.0
2011/3/16 2:00	177.1	60.0	148.2	58.0
2011/3/16 3:00	178.4	60.2	147.6	58.5
2011/3/16 4:00	180.0	60.4	148.3	58.5
2011/3/16 5:00	182.2	60.7	149.4	59.0
2011/3/16 6:00	183.4	60.9	149.9	59.0
2011/3/16 7:00	185.0	61.1	150.2	59.5
2011/3/16 8:00	186.8	61.4	150.9	59.5
2011/3/16 9:00	188.2	61.6	151.6	59.5
2011/3/16 10:00	189.9	61.8	152.3	59.5
2011/3/16 11:00	191.8	62.1	153.1	59.5
2011/3/16 12:00	193.4	62.3	153.9	60.0
2011/3/16 13:00	194.6	62.4	154.4	60.0
2011/3/16 14:00	196.2	62.7	150.0	60.0
2011/3/16 15:00	197.4	62.9	155.8	60.0
2011/3/16 16:00	199.7	63.2	156.3	60.0
2011/3/16 17:00	181.2	63.3	156.9	60.0
2011/3/16 18:00	153.1	63.6	157.5	60.0
2011/3/16 19:00	151.2	63.8	158.2	60.0
2011/3/16 20:00	154.0	64.1	158.6	60.0
2011/3/16 21:00	156.6	64.2	159.1	60.0
2011/3/16 22:00	159.2	64.4	159.6	60.0
2011/3/16 23:00	161.7	64.6	160.1	60.5
2011/3/17 0:00	165.7	64.6	160.7	60.5
2011/3/17 1:00	166.3	64.6	161.2	61.0
2011/3/17 2:00	167.2	64.6	161.7	61.0
2011/3/17 3:00	168.1	64.5	162.2	61.0
2011/3/17 4:00	168.8	64.5	162.7	61.0
2011/3/17 5:00	169.0	65.0	163.0	61.5
2011/3/17 6:00	170.7	64.8	163.7	62.0
2011/3/17 7:00	171.7	64.2	164.3	62.0
2011/3/17 8:00	173.1	64.2	164.9	62.0
2011/3/17 9:00	175.0	64.2	165.0	62.0
2011/3/17 10:00	178.0	64.2	167.0	62.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/17 11:00	178.0	64.2	167.0	62.5
2011/3/17 12:00	179.1	64.2	167.3	62.5
2011/3/17 13:00	180.4	64.3	162.1	63.0
2011/3/17 14:00	182.6	64.3	154.3	63.5
2011/3/17 15:00	183.7	64.4	153.8	63.5
2011/3/17 16:00	184.7	64.4	153.5	63.5
2011/3/17 17:00	186.2	64.5	153.5	64.0
2011/3/17 18:00	187.7	64.6	154.3	64.0
2011/3/17 19:00	189.7	64.7	155.5	62.5
2011/3/17 20:00	190.5	64.8	156.1	62.5
2011/3/17 21:00	192.5	64.9	157.4	62.0
2011/3/17 22:00	193.5	64.9	158.0	61.5
2011/3/17 23:00	194.7	65.1	158.7	61.5
2011/3/18 0:00	196.5	65.1	159.7	61.5
2011/3/18 1:00	175.6	65.3	160.1	61.5
2011/3/18 2:00	163.7	65.3	163.7	61.5
2011/3/18 3:00	163.1	65.5	157.1	62.0
2011/3/18 4:00	165.2	65.5	157.3	62.0
2011/3/18 5:00	167.6	65.6	158.0	62.0
2011/3/18 6:00	169.6	65.7	158.6	62.5
2011/3/18 7:00	171.5	65.8	159.2	62.5
2011/3/18 8:00	173.3	65.9	159.9	63.0
2011/3/18 9:00	175.0	66.0	160.5	63.0
2011/3/18 10:00	176.5	66.1	161.0	63.0
2011/3/18 11:00	178.5	66.2	161.8	63.5
2011/3/18 12:00	180.4	66.3	162.7	63.5
2011/3/18 13:00	181.8	66.3	161.2	64.0
2011/3/18 14:00	183.0	66.6	158.0	64.5
2011/3/18 15:00	185.2	66.6	157.7	64.5
2011/3/18 16:00	187.1	66.9	156.7	64.5
2011/3/18 17:00	188.6	66.9	156.9	64.5
2011/3/18 18:00	190.1	67.1	157.4	65.0
2011/3/18 19:00	191.8	67.3	158.0	65.0
2011/3/18 20:00	193.0	67.4	158.7	65.0
2011/3/18 21:00	194.8	67.6	159.2	65.0
2011/3/18 22:00	196.5	67.8	159.8	65.0
2011/3/18 23:00	197.9	67.9	160.4	65.0
2011/3/19 0:00	166.5	68.1	161.0	65.5
2011/3/19 1:00	163.0	68.2	161.5	66.0
2011/3/19 2:00	164.2	68.4	162.0	66.0
2011/3/19 3:00	166.5	68.6	162.5	66.0
2011/3/19 4:00	168.5	68.7	163.0	66.0
2011/3/19 5:00	171.0	68.8	163.6	66.5
2011/3/19 6:00	173.1	68.8	164.1	66.5
2011/3/19 7:00	175.3	68.5	164.6	66.5
2011/3/19 8:00	177.2	68.1	165.2	66.5
2011/3/19 9:00	179.1	67.6	165.8	66.5
2011/3/19 10:00	181.2	67.0	166.6	66.5
2011/3/19 11:00	183.0	66.6	167.2	66.5
2011/3/19 12:00	185.4	65.5	167.9	66.5
2011/3/19 13:00	186.2	65.2	168.2	66.5
2011/3/19 14:00	188.2	63.8	156.6	67.0
2011/3/19 15:00	190.1	56.1	153.6	67.0
2011/3/19 16:00	192.2	50.3	152.5	67.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/19 17:00	193.3	48.7	152.1	67.0
2011/3/19 18:00	194.5	48.1	152.4	67.0
2011/3/19 19:00	196.3	47.6	153.3	67.0
2011/3/19 20:00	197.7	47.5	154.2	67.0
2011/3/19 21:00	172.8	46.7	154.8	67.5
2011/3/19 22:00	165.5	46.2	155.8	67.5
2011/3/19 23:00	164.5	45.7	156.6	67.5
2011/3/20 0:00	166.2	44.8	157.2	66.5
2011/3/20 1:00	157.9	43.5	157.9	56.0
2011/3/20 2:00	171.0	41.7	158.7	54.0
2011/3/20 3:00	173.5	40.1	159.4	52.0
2011/3/20 4:00	175.5	39.0	160.0	48.0
2011/3/20 5:00	177.5	38.3	160.6	46.0
2011/3/20 6:00	179.2	37.7	161.1	44.0
2011/3/20 7:00	181.3	37.1	161.8	41.0
2011/3/20 8:00	183.0	36.7	162.5	38.5
2011/3/20 9:00	185.0	36.1	163.1	36.5
2011/3/20 10:00	186.0	35.7	163.5	35.0
2011/3/20 11:00	188.0	35.1	164.1	33.5
2011/3/20 12:00	154.9	35.3	164.7	32.0
2011/3/20 13:00	124.7	35.2	165.3	30.5
2011/3/20 14:00	107.2	35.2	166.0	30.0
2011/3/20 15:00	92.9	35.2	166.6	29.5
2011/3/20 16:00	76.5	35.1	167.2	28.0
2011/3/20 17:00	69.4	34.6	145.6	27.5
2011/3/20 18:00	62.5	34.9	141.8	27.5
2011/3/20 19:00	57.2	35.3	113.5	27.5
2011/3/20 20:00	52.3	35.7	87.6	28.0
2011/3/20 21:00	47.8	36.3	67.5	28.5
2011/3/20 22:00	44.8	36.7	56.3	29.0
2011/3/20 23:00	43.0	37.0	50.8	29.5
2011/3/21 0:00	41.2	37.3	45.0	30.0
2011/3/21 1:00	39.0	37.9	39.2	30.0
2011/3/21 2:00	37.6	38.3	35.4	30.0
2011/3/21 3:00	36.3	38.6	32.3	31.0
2011/3/21 4:00	35.2	39.1	29.9	31.0
2011/3/21 5:00	34.4	39.5	28.2	32.0
2011/3/21 6:00	33.6	39.9	26.7	32.0
2011/3/21 7:00	32.9	40.2	25.4	32.5
2011/3/21 8:00	32.4	40.6	24.8	33.0
2011/3/21 9:00	32.0	41.0	24.1	33.5
2011/3/21 10:00	31.5	41.5	23.4	34.0
2011/3/21 11:00	31.2	41.9	23.1	34.0
2011/3/21 12:00	45.0	42.2	22.8	35.0
2011/3/21 13:00	47.0	42.6	22.4	35.0
2011/3/21 14:00	49.1	42.6	22.2	35.5
2011/3/21 15:00	51.2	42.6	21.9	36.0
2011/3/21 16:00	53.2	42.3	23.6	36.0
2011/3/21 17:00	55.2	42.3	23.0	36.5
2011/3/21 18:00	57.7	42.1	22.8	37.0
2011/3/21 19:00	59.6	39.7	38.2	37.5
2011/3/21 20:00	62.6	37.8	40.1	37.5
2011/3/21 21:00	65.0	37.0	41.2	35.5
2011/3/21 22:00	68.4	36.4	42.4	33.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/21 23:00	70.9	36.1	43.3	32.5
2011/3/22 0:00	57.9	35.9	45.1	30.5
2011/3/22 1:00	53.9	35.8	46.0	30.0
2011/3/22 2:00	49.3	35.7	49.3	29.0
2011/3/22 3:00	45.0	35.7	50.9	27.5
2011/3/22 4:00	42.2	36.0	53.6	26.0
2011/3/22 5:00	39.3	36.3	55.3	25.5
2011/3/22 6:00	38.2	36.7	56.5	25.0
2011/3/22 7:00	36.7	37.1	58.0	24.0
2011/3/22 8:00	46.3	37.4	59.6	23.5
2011/3/22 9:00	48.6	37.7	47.0	23.5
2011/3/22 10:00	51.0	37.6	39.7	24.0
2011/3/22 11:00	53.2	37.5	34.1	25.0
2011/3/22 12:00	55.5	37.4	31.3	25.5
2011/3/22 13:00	58.4	37.3	28.3	26.0
2011/3/22 14:00	61.7	36.9	26.5	26.0
2011/3/22 15:00	64.4	35.5	24.3	26.5
2011/3/22 16:00	67.9	34.1	23.9	27.0
2011/3/22 17:00	70.6	33.5	21.6	27.5
2011/3/22 18:00	73.5	33.3	35.9	28.0
2011/3/22 19:00	75.6	33.1	37.1	28.5
2011/3/22 20:00	62.7	32.9	38.0	28.5
2011/3/22 21:00	56.1	33.2	39.2	28.5
2011/3/22 22:00	51.6	33.5	40.3	26.5
2011/3/22 23:00	47.7	33.8	41.7	26.0
2011/3/23 0:00	44.3	34.2	43.1	24.5
2011/3/23 1:00	41.8	34.6	44.6	24.0
2011/3/23 2:00	39.3	35.1	48.0	23.0
2011/3/23 3:00	37.8	35.4	49.9	22.5
2011/3/23 4:00	36.6	35.7	51.1	22.0
2011/3/23 5:00	35.3	36.2	52.4	21.5
2011/3/23 6:00	34.2	36.6	54.0	21.0
2011/3/23 7:00	33.4	36.9	55.3	20.5
2011/3/23 8:00	32.6	37.3	57.0	20.0
2011/3/23 9:00	31.9	37.8	59.1	20.0
2011/3/23 10:00	31.4	38.1	60.6	20.0
2011/3/23 11:00	31.1	38.6	62.5	20.0
2011/3/23 12:00	30.7	39.0	64.6	20.0
2011/3/23 13:00	30.4	39.3	66.4	20.0
2011/3/23 14:00	30.2	39.6	68.1	19.5
2011/3/23 15:00	29.9	40.1	70.3	19.5
2011/3/23 16:00	29.9	40.3	72.3	19.5
2011/3/23 17:00	38.5	40.7	74.0	19.0
2011/3/23 18:00	40.9	41.1	75.7	19.0
2011/3/23 19:00	43.1	41.5	56.1	19.5
2011/3/23 20:00	45.4	41.8	47.5	20.0
2011/3/23 21:00	47.8	42.2	40.6	20.5
2011/3/23 22:00	50.7	42.6	35.7	20.5
2011/3/23 23:00	53.5	43.0	31.9	21.0
2011/3/24 0:00	56.9	43.2	28.6	21.5
2011/3/24 1:00	59.4	43.6	26.7	21.5
2011/3/24 2:00	62.7	44.0	25.0	22.0
2011/3/24 3:00	65.3	44.3	23.9	23.0
2011/3/24 4:00	68.0	44.6	23.3	23.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/24 5:00	71.4	45.1	24.1	23.5
2011/3/24 6:00	73.5	45.4	24.2	24.0
2011/3/24 7:00	76.4	45.7	24.3	24.0
2011/3/24 8:00	79.2	46.1	24.3	24.5
2011/3/24 9:00	81.7	46.4	24.3	25.0
2011/3/24 10:00	84.3	46.9	24.4	25.5
2011/3/24 11:00	86.8	47.2	24.4	26.0
2011/3/24 12:00	89.2	47.5	23.8	26.5
2011/3/24 13:00	92.0	47.7	22.3	27.0
2011/3/24 14:00	94.5	48.1	21.5	27.0
2011/3/24 15:00	96.5	48.4	21.2	27.5
2011/3/24 16:00	97.8	48.7	20.8	28.0
2011/3/24 17:00	82.7	49.0	21.3	28.5
2011/3/24 18:00	72.0	49.4	30.5	29.0
2011/3/24 19:00	61.4	49.8	31.8	28.5
2011/3/24 20:00	55.9	50.1	33.3	26.5
2011/3/24 21:00	52.0	50.3	34.5	26.0
2011/3/24 22:00	47.8	50.6	35.9	25.0
2011/3/24 23:00	44.8	50.9	37.1	24.0
2011/3/25 0:00	48.8	51.1	39.4	23.0
2011/3/25 1:00	51.4	50.9	42.3	22.5
2011/3/25 2:00	54.3	50.6	44.0	22.0
2011/3/25 3:00	57.3	50.2	45.5	21.5
2011/3/25 4:00	59.9	49.4	46.8	21.0
2011/3/25 5:00	62.8	45.2	48.4	20.5
2011/3/25 6:00	65.8	43.4	50.2	20.5
2011/3/25 7:00	68.9	42.6	52.0	20.0
2011/3/25 8:00	71.2	42.1	53.5	20.0
2011/3/25 9:00	74.3	40.9	55.5	20.0
2011/3/25 10:00	77.0	39.5	57.4	19.5
2011/3/25 11:00	79.4	38.3	44.0	19.5
2011/3/25 12:00	82.0	37.5	39.0	20.0
2011/3/25 13:00	66.0	37.1	33.9	20.5
2011/3/25 14:00	59.1	37.0	30.4	20.5
2011/3/25 15:00	53.9	36.9	29.9	21.0
2011/3/25 16:00	49.8	37.2	32.5	21.5
2011/3/25 17:00	46.4	37.5	29.4	22.0
2011/3/25 18:00	43.2	37.9	26.9	22.0
2011/3/25 19:00	40.7	38.3	25.2	22.5
2011/3/25 20:00	38.6	38.8	23.8	23.0
2011/3/25 21:00	37.1	39.0	22.9	23.5
2011/3/25 22:00	35.5	39.4	23.0	23.5
2011/3/25 23:00	34.5	39.8	27.6	24.0
2011/3/26 0:00	33.6	40.1	27.3	24.5
2011/3/26 1:00	32.8	40.5	26.2	24.5
2011/3/26 2:00	32.1	40.9	25.0	25.0
2011/3/26 3:00	31.6	41.2	24.1	25.5
2011/3/26 4:00	31.1	41.6	23.2	26.0
2011/3/26 5:00	30.6	42.0	22.6	26.5
2011/3/26 6:00	30.3	42.3	22.1	27.0
2011/3/26 7:00	30.0	42.9	21.7	27.5
2011/3/26 8:00	29.7	43.0	21.4	28.0
2011/3/26 9:00	29.4	43.4	21.3	28.0
2011/3/26 10:00	34.3	43.8	21.4	29.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/26 11:00	36.5	43.7	21.3	29.0
2011/3/26 12:00	39.7	43.5	21.4	29.5
2011/3/26 13:00	44.2	43.2	21.3	29.5
2011/3/26 14:00	43.8	42.8	21.3	30.0
2011/3/26 15:00	47.6	39.5	21.4	30.0
2011/3/26 16:00	49.6	38.6	21.4	30.5
2011/3/26 17:00	52.7	38.1	21.4	30.5
2011/3/26 18:00	55.1	37.7	29.4	31.0
2011/3/26 19:00	58.0	36.7	30.6	31.0
2011/3/26 20:00	61.2	35.6	32.1	29.5
2011/3/26 21:00	63.4	34.8	33.3	28.5
2011/3/26 22:00	66.2	34.1	34.8	27.0
2011/3/26 23:00	68.8	33.6	36.6	26.0
2011/3/27 0:00	57.8	33.2	39.3	25.0
2011/3/27 1:00	52.5	33.0	41.2	24.0
2011/3/27 2:00	48.0	33.2	42.9	23.5
2011/3/27 3:00	44.9	33.4	44.4	23.0
2011/3/27 4:00	41.6	33.9	46.3	22.0
2011/3/27 5:00	39.6	34.2	47.8	21.0
2011/3/27 6:00	37.6	34.6	49.4	20.5
2011/3/27 7:00	36.1	34.9	51.2	20.5
2011/3/27 8:00	34.8	35.3	53.2	20.5
2011/3/27 9:00	33.3	35.8	55.8	20.0
2011/3/27 10:00	32.6	36.1	57.1	20.0
2011/3/27 11:00	31.9	36.5	43.9	20.0
2011/3/27 12:00	31.3	36.8	38.0	20.0
2011/3/27 13:00	30.7	37.4	32.6	21.0
2011/3/27 14:00	30.3	37.8	29.1	21.0
2011/3/27 15:00	30.0	38.0	27.7	21.5
2011/3/27 16:00	29.7	38.4	25.8	22.0
2011/3/27 17:00	29.5	38.8	24.9	22.5
2011/3/27 18:00	29.3	39.1	24.3	22.5
2011/3/27 19:00	29.1	39.5	23.8	23.0
2011/3/27 20:00	28.9	39.9	23.3	24.0
2011/3/27 21:00	32.7	40.2	23.1	24.0
2011/3/27 22:00	35.3	40.2	22.8	24.0
2011/3/27 23:00	38.1	40.0	22.6	24.5
2011/3/28 0:00	39.9	39.9	22.5	25.0
2011/3/28 1:00	43.1	39.7	22.3	25.5
2011/3/28 2:00	46.1	37.5	22.2	26.0
2011/3/28 3:00	49.5	36.0	22.0	26.5
2011/3/28 4:00	51.9	35.5	22.0	26.5
2011/3/28 5:00	54.9	35.1	22.0	27.0
2011/3/28 6:00	57.7	34.5	21.9	27.5
2011/3/28 7:00	60.4	33.7	22.0	28.0
2011/3/28 8:00	63.5	32.9	22.1	28.0
2011/3/28 9:00	66.4	32.3	22.2	28.5
2011/3/28 10:00	68.5	31.7	22.3	29.0
2011/3/28 11:00	71.3	31.2	22.4	29.5
2011/3/28 12:00	60.1	30.9	22.4	30.0
2011/3/28 13:00	55.4	30.7	22.4	30.0
2011/3/28 14:00	50.6	30.9	22.3	30.5
2011/3/28 15:00	47.1	31.3	22.3	30.5
2011/3/28 16:00	44.3	31.6	22.4	31.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/28 17:00	41.4	32.1	22.4	31.5
2011/3/28 18:00	39.5	32.5	22.4	32.0
2011/3/28 19:00	37.8	32.8	29.1	32.0
2011/3/28 20:00	36.4	33.3	30.3	31.0
2011/3/28 21:00	35.1	33.7	32.0	29.0
2011/3/28 22:00	34.2	33.9	33.7	28.5
2011/3/28 23:00	33.2	34.4	35.8	27.0
2011/3/29 0:00	32.5	34.8	38.4	26.0
2011/3/29 1:00	32.0	35.1	40.0	25.0
2011/3/29 2:00	31.4	35.5	41.7	24.5
2011/3/29 3:00	30.9	35.9	43.4	24.0
2011/3/29 4:00	30.4	36.3	45.3	23.0
2011/3/29 5:00	30.1	36.8	47.2	22.5
2011/3/29 6:00	29.8	37.1	48.9	22.0
2011/3/29 7:00	29.0	37.4	50.9	21.5
2011/3/29 8:00	29.3	37.8	53.1	21.0
2011/3/29 9:00	29.1	38.3	55.3	20.5
2011/3/29 10:00	29.0	38.5	56.9	20.5
2011/3/29 11:00	32.5	38.9	43.6	20.5
2011/3/29 12:00	35.0	38.8	37.7	21.0
2011/3/29 13:00	37.5	38.8	33.5	21.0
2011/3/29 14:00	40.5	38.6	30.3	21.5
2011/3/29 15:00	43.4	38.4	28.9	22.0
2011/3/29 16:00	46.3	37.5	30.1	22.5
2011/3/29 17:00	48.9	35.5	28.5	22.5
2011/3/29 18:00	51.8	34.5	27.1	23.0
2011/3/29 19:00	54.2	34.2	26.1	23.5
2011/3/29 20:00	57.1	33.9	25.1	24.0
2011/3/29 21:00	59.6	33.4	24.4	24.5
2011/3/29 22:00	54.8	32.6	23.8	24.5
2011/3/29 23:00	51.2	32.4	23.3	25.0
2011/3/30 0:00	49.8	32.1	22.9	25.5
2011/3/30 1:00	46.8	32.4	22.6	26.0
2011/3/30 2:00	43.7	32.7	22.2	26.5
2011/3/30 3:00	41.7	33.0	22.1	27.0
2011/3/30 4:00	37.4	33.4	21.8	27.0
2011/3/30 5:00	35.9	33.7	21.7	27.5
2011/3/30 6:00	34.7	34.2	21.6	28.0
2011/3/30 7:00	33.7	34.5	21.5	28.5
2011/3/30 8:00	32.8	34.9	21.4	28.5
2011/3/30 9:00	32.0	35.3	21.3	29.0
2011/3/30 10:00	31.5	35.7	27.2	29.0
2011/3/30 11:00	31.0	36.1	28.2	29.5
2011/3/30 12:00	30.6	36.5	29.5	29.5
2011/3/30 13:00	30.2	36.8	30.9	27.0
2011/3/30 14:00	29.9	37.2	32.6	26.5
2011/3/30 15:00	29.7	37.5	34.7	25.5
2011/3/30 16:00	29.4	37.9	37.6	24.5
2011/3/30 17:00	29.3	38.3	39.2	23.5
2011/3/30 18:00	29.2	38.7	40.9	23.0
2011/3/30 19:00	31.6	39.0	42.5	22.5
2011/3/30 20:00	33.7	39.0	44.2	22.0
2011/3/30 21:00	38.3	38.8	47.0	21.5
2011/3/30 22:00	39.4	38.8	47.8	21.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/3/30 23:00	42.3	38.5	37.2	21.0
2011/3/31 0:00	45.4	37.2	32.7	21.5
2011/3/31 1:00	48.2	35.6	29.6	22.0
2011/3/31 2:00	51.0	34.6	27.1	22.5
2011/3/31 3:00	53.9	34.2	25.4	22.5
2011/3/31 4:00	56.3	33.9	26.9	23.0
2011/3/31 5:00	58.7	33.3	27.7	23.0
2011/3/31 6:00	61.9	32.4	26.0	24.0
2011/3/31 7:00	64.8	31.7	24.8	24.5
2011/3/31 8:00	67.4	31.2	23.8	25.0
2011/3/31 9:00	69.4	30.8	23.3	25.0
2011/3/31 10:00	71.4	30.4	22.9	25.5
2011/3/31 11:00	62.4	30.0	22.3	26.0
2011/3/31 12:00	56.8	29.9	22.0	26.5
2011/3/31 13:00	51.8	30.2	21.7	27.0
2011/3/31 14:00	47.4	30.6	21.4	27.0
2011/3/31 15:00	44.4	30.9	21.3	27.5
2011/3/31 16:00	41.8	31.2	21.2	28.0
2011/3/31 17:00	41.7	31.7	21.1	28.5
2011/3/31 18:00	37.7	32.0	21.1	29.0
2011/3/31 19:00	36.3	32.4	21.1	29.0
2011/3/31 20:00	34.9	33.0	26.9	29.5
2011/3/31 21:00	34.0	33.3	27.6	29.0
2011/3/31 22:00	33.3	33.6	28.8	29.0
2011/3/31 23:00	32.4	34.0	31.1	27.0
2011/4/1 0:00	31.9	34.3	32.7	26.0
2011/4/1 1:00	31.4	34.7	34.8	25.0
2011/4/1 2:00	30.9	35.1	37.4	24.0
2011/4/1 3:00	30.6	35.5	39.1	23.5
2011/4/1 4:00	30.3	35.8	40.6	23.0
2011/4/1 5:00	30.0	36.2	42.2	22.5
2011/4/1 6:00	29.8	36.6	44.1	22.0
2011/4/1 7:00	29.6	37.0	45.8	21.0
2011/4/1 8:00	29.5	37.3	47.9	20.5
2011/4/1 9:00	29.3	37.8	50.1	20.5
2011/4/1 10:00	29.2	38.2	51.8	20.0
2011/4/1 11:00	32.1	38.2	53.7	20.0
2011/4/1 12:00	34.5	38.4	44.7	20.0
2011/4/1 13:00	37.8	38.2	37.9	20.5
2011/4/1 14:00	40.9	38.1	33.3	21.0
2011/4/1 15:00	44.2	37.8	29.8	21.0
2011/4/1 16:00	46.7	35.9	27.7	21.5
2011/4/1 17:00	49.5	34.8	26.0	22.0
2011/4/1 18:00	52.3	34.4	24.6	22.5
2011/4/1 19:00	55.0	34.0	23.5	22.5
2011/4/1 20:00	57.5	33.6	22.4	23.0
2011/4/1 21:00	61.2	32.6	21.9	23.5
2011/4/1 22:00	63.1	32.1	22.0	24.0
2011/4/1 23:00	52.2	31.9	22.1	24.5
2011/4/2 0:00	48.5	32.0	22.1	24.5
2011/4/2 1:00	45.2	32.3	22.0	25.0
2011/4/2 2:00	42.4	32.6	22.0	25.5
2011/4/2 3:00	40.0	33.0	21.9	26.0
2011/4/2 4:00	38.0	33.3	21.8	26.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/2 5:00	36.7	33.7	21.7	26.5
2011/4/2 6:00	35.5	34.1	21.6	27.0
2011/4/2 7:00	34.4	34.5	21.5	27.5
2011/4/2 8:00	33.5	34.8	21.5	28.0
2011/4/2 9:00	32.6	35.4	21.5	28.5
2011/4/2 10:00	32.0	35.7	21.5	28.5
2011/4/2 11:00	31.5	36.0	27.4	28.5
2011/4/2 12:00	31.1	36.4	28.6	28.0
2011/4/2 13:00	30.7	36.8	30.0	26.5
2011/4/2 14:00	30.4	37.1	31.8	25.5
2011/4/2 15:00	30.1	37.5	33.8	24.5
2011/4/2 16:00	29.8	37.9	36.2	24.0
2011/4/2 17:00	29.6	38.2	38.0	23.0
2011/4/2 18:00	31.4	38.5	39.5	22.5
2011/4/2 19:00	34.5	38.5	31.2	22.5
2011/4/2 20:00	37.2	38.3	28.6	23.0
2011/4/2 21:00	41.0	37.0	25.9	23.5
2011/4/2 22:00	43.5	35.9	24.6	24.0
2011/4/2 23:00	46.6	35.2	23.3	24.5
2011/4/3 0:00	49.3	34.8	23.5	24.5
2011/4/3 1:00	52.3	33.9	23.7	25.0
2011/4/3 2:00	54.8	33.3	23.1	25.5
2011/4/3 3:00	57.7	32.7	23.6	26.0
2011/4/3 4:00	60.8	32.0	23.4	26.5
2011/4/3 5:00	63.0	31.6	23.2	26.5
2011/4/3 6:00	65.5	31.0	23.2	27.0
2011/4/3 7:00	68.3	30.6	23.1	27.5
2011/4/3 8:00	70.7	30.2	23.0	28.0
2011/4/3 9:00	73.4	29.6	22.9	28.5
2011/4/3 10:00	75.6	29.3	22.8	29.0
2011/4/3 11:00	62.9	29.1	22.8	29.0
2011/4/3 12:00	56.7	29.3	22.8	29.5
2011/4/3 13:00	51.5	29.7	22.7	29.5
2011/4/3 14:00	47.6	30.1	22.8	30.0
2011/4/3 15:00	44.4	30.4	22.8	30.0
2011/4/3 16:00	41.8	30.9	22.7	30.5
2011/4/3 17:00	39.7	31.2	22.7	31.0
2011/4/3 18:00	37.9	31.6	27.1	31.0
2011/4/3 19:00	36.2	32.0	27.8	31.0
2011/4/3 20:00	34.9	32.3	29.3	30.0
2011/4/3 21:00	34.0	32.8	31.1	29.0
2011/4/3 22:00	32.9	33.2	33.7	27.0
2011/4/3 23:00	32.4	33.6	35.5	26.5
2011/4/4 0:00	31.9	33.9	37.3	25.5
2011/4/4 1:00	31.4	34.2	38.9	25.0
2011/4/4 2:00	31.0	34.6	40.7	24.0
2011/4/4 3:00	30.7	35.0	42.2	23.5
2011/4/4 4:00	30.4	35.4	44.0	23.0
2011/4/4 5:00	30.1	35.7	46.0	22.5
2011/4/4 6:00	29.9	36.1	48.0	21.5
2011/4/4 7:00	29.6	36.5	50.2	21.0
2011/4/4 8:00	29.6	36.8	51.6	21.0
2011/4/4 9:00	29.4	37.2	53.4	20.5
2011/4/4 10:00	32.3	37.4	55.5	20.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/4 11:00	35.3	37.2	42.6	20.5
2011/4/4 12:00	38.5	37.1	37.6	21.0
2011/4/4 13:00	41.5	35.6	33.4	21.0
2011/4/4 14:00	44.4	34.6	30.1	21.5
2011/4/4 15:00	47.3	34.2	27.7	22.0
2011/4/4 16:00	50.2	33.6	25.9	22.5
2011/4/4 17:00	52.9	32.9	24.5	23.0
2011/4/4 18:00	55.5	32.4	25.2	23.5
2011/4/4 19:00	58.1	31.9	25.5	23.5
2011/4/4 20:00	48.7	31.5	24.9	24.0
2011/4/4 21:00	45.0	31.8	24.2	24.5
2011/4/4 22:00	42.3	32.2	23.8	25.0
2011/4/4 23:00	40.1	32.5	23.4	25.0
2011/4/5 0:00	38.2	33.0	23.0	25.5
2011/4/5 1:00	38.5	33.2	22.7	26.0
2011/4/5 2:00	37.3	33.6	22.7	26.5
2011/4/5 3:00	36.0	34.0	22.7	27.0
2011/4/5 4:00	35.0	34.3	22.7	27.0
2011/4/5 5:00	34.3	34.7	22.6	27.5
2011/4/5 6:00	33.3	35.2	22.6	28.0
2011/4/5 7:00	32.8	35.5	22.5	28.5
2011/4/5 8:00	31.1	35.8	22.5	29.0
2011/4/5 9:00	30.8	36.2	22.5	29.0
2011/4/5 10:00	32.6	36.4	26.9	29.5
2011/4/5 11:00	36.0	36.3	27.8	29.0
2011/4/5 12:00	39.4	36.1	29.2	28.5
2011/4/5 13:00	42.4	34.8	30.9	27.5
2011/4/5 14:00	45.4	34.0	32.9	26.5
2011/4/5 15:00	48.0	33.6	34.8	26.0
2011/4/5 16:00	51.0	33.0	37.2	25.0
2011/4/5 17:00	53.8	32.4	38.8	24.5
2011/4/5 18:00	56.4	31.9	40.3	24.0
2011/4/5 19:00	59.0	31.4	42.0	23.5
2011/4/5 20:00	49.9	31.1	44.0	23.0
2011/4/5 21:00	48.9	31.4	34.2	23.0
2011/4/5 22:00	43.3	31.7	31.2	23.0
2011/4/5 23:00	41.2	32.2	28.7	23.5
2011/4/6 0:00	39.1	32.5	26.7	24.0
2011/4/6 1:00	37.6	32.9	26.2	24.0
2011/4/6 2:00	36.1	33.2	25.6	25.0
2011/4/6 3:00	35.1	33.6	25.2	25.5
2011/4/6 4:00	34.1	33.9	24.4	26.0
2011/4/6 5:00	33.3	34.4	23.6	26.0
2011/4/6 6:00	32.6	34.8	22.9	26.5
2011/4/6 7:00	32.1	35.1	22.5	26.5
2011/4/6 8:00	31.6	35.5	22.0	27.0
2011/4/6 9:00	31.2	35.9	21.8	28.0
2011/4/6 10:00	33.0	36.2	21.5	28.5
2011/4/6 11:00	37.0	36.1	21.3	28.5
2011/4/6 12:00	39.0	36.0	21.2	29.0
2011/4/6 13:00	42.3	35.2	21.1	29.5
2011/4/6 14:00	45.1	34.1	21.1	29.5
2011/4/6 15:00	47.8	33.6	21.1	30.0
2011/4/6 16:00	50.4	33.2	21.1	30.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/6 17:00	53.3	32.5	21.1	30.5
2011/4/6 18:00	56.0	31.9	26.5	30.5
2011/4/6 19:00	58.5	31.5	27.7	30.0
2011/4/6 20:00	49.8	31.3	29.4	28.0
2011/4/6 21:00	46.2	31.5	31.2	27.5
2011/4/6 22:00	43.4	31.8	33.1	26.5
2011/4/6 23:00	43.1	32.2	36.0	26.0
2011/4/7 0:00	39.4	32.5	37.2	25.0
2011/4/7 1:00	37.7	32.9	38.9	24.0
2011/4/7 2:00	36.4	33.3	40.6	23.5
2011/4/7 3:00	35.0	33.8	42.7	23.0
2011/4/7 4:00	34.2	34.1	44.3	22.5
2011/4/7 5:00	34.4	34.4	46.3	22.0
2011/4/7 6:00	34.8	34.8	48.1	21.5
2011/4/7 7:00	32.3	35.3	50.0	21.0
2011/4/7 8:00	31.8	35.6	51.7	21.0
2011/4/7 9:00	32.3	35.8	53.6	20.5
2011/4/7 10:00	32.8	36.2	55.4	20.0
2011/4/7 11:00	36.0	36.1	42.0	20.5
2011/4/7 12:00	39.1	36.0	37.1	21.0
2011/4/7 13:00	42.5	35.1	33.3	21.5
2011/4/7 14:00	45.3	34.1	30.4	22.0
2011/4/7 15:00	48.1	33.6	28.2	22.0
2011/4/7 16:00	50.8	33.2	26.6	22.5
2011/4/7 17:00	53.4	32.7	25.4	23.0
2011/4/7 18:00	56.0	32.2	24.3	23.5
2011/4/7 19:00	58.7	31.6	23.5	24.0
2011/4/7 20:00	50.3	31.2	22.8	24.0
2011/4/7 21:00	46.6	31.6	22.2	24.5
2011/4/7 22:00	43.9	31.9	21.8	25.0
2011/4/7 23:00	41.5	32.3	21.5	25.5
2011/4/8 0:00	39.6	32.7	21.2	26.0
2011/4/8 1:00	38.2	33.1	21.0	26.5
2011/4/8 2:00	36.8	33.4	20.8	26.5
2011/4/8 3:00	35.8	33.7	20.6	27.0
2011/4/8 4:00	34.8	34.2	21.2	26.5
2011/4/8 5:00	33.9	34.5	21.8	27.5
2011/4/8 6:00	33.2	34.8	22.1	28.0
2011/4/8 7:00	32.6	35.2	22.1	28.5
2011/4/8 8:00	32.1	35.7	22.1	29.0
2011/4/8 9:00	31.7	36.0	22.2	29.0
2011/4/8 10:00	33.3	36.3	22.2	29.5
2011/4/8 11:00	37.2	36.5	22.2	30.0
2011/4/8 12:00	39.7	36.3	22.5	30.0
2011/4/8 13:00	42.5	36.1	22.6	30.5
2011/4/8 14:00	45.5	34.7	22.7	30.5
2011/4/8 15:00	49.7	33.9	22.7	31.0
2011/4/8 16:00	51.3	33.6	22.7	31.5
2011/4/8 17:00	54.0	33.2	22.8	32.0
2011/4/8 18:00	56.4	32.7	22.8	32.5
2011/4/8 19:00	59.5	32.1	26.7	33.0
2011/4/8 20:00	52.1	31.8	27.6	33.0
2011/4/8 21:00	47.7	32.0	29.5	31.5
2011/4/8 22:00	45.6	32.2	30.8	30.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/8 23:00	43.2	32.5	32.7	29.5
2011/4/9 0:00	41.2	33.0	34.8	28.5
2011/4/9 1:00	39.2	33.3	37.1	28.0
2011/4/9 2:00	37.8	33.7	38.7	27.0
2011/4/9 3:00	36.5	34.2	40.4	26.0
2011/4/9 4:00	35.5	34.4	42.1	25.0
2011/4/9 5:00	34.6	34.8	44.0	24.0
2011/4/9 6:00	33.8	35.2	45.9	24.0
2011/4/9 7:00	33.2	35.6	47.7	23.0
2011/4/9 8:00	32.6	35.9	49.7	22.5
2011/4/9 9:00	31.8	36.3	51.4	22.5
2011/4/9 10:00	31.4	36.7	53.2	22.0
2011/4/9 11:00	35.6	36.6	42.6	22.0
2011/4/9 12:00	38.4	36.4	37.4	22.5
2011/4/9 13:00	41.3	36.0	33.3	22.5
2011/4/9 14:00	43.8	34.7	30.5	23.0
2011/4/9 15:00	47.0	34.1	27.8	23.5
2011/4/9 16:00	49.6	33.7	26.1	24.0
2011/4/9 17:00	51.9	33.0	24.9	24.0
2011/4/9 18:00	54.3	32.6	23.9	24.5
2011/4/9 19:00	56.9	32.1	23.0	24.5
2011/4/9 20:00	50.9	31.8	23.1	25.0
2011/4/9 21:00	46.2	32.1	22.9	26.0
2011/4/9 22:00	44.8	32.2	22.9	26.0
2011/4/9 23:00	42.4	32.7	22.8	26.5
2011/4/10 0:00	40.4	32.9	22.6	27.0
2011/4/10 1:00	38.8	33.3	22.6	27.5
2011/4/10 2:00	37.4	33.7	22.6	28.0
2011/4/10 3:00	36.2	34.0	22.4	28.0
2011/4/10 4:00	35.2	34.4	22.4	28.5
2011/4/10 5:00	34.4	34.4	22.3	28.5
2011/4/10 6:00	33.6	35.2	22.3	29.0
2011/4/10 7:00	33.1	35.5	22.2	29.5
2011/4/10 8:00	32.4	36.0	22.2	30.0
2011/4/10 9:00	32.0	36.3	22.2	30.0
2011/4/10 10:00	33.6	36.5	22.2	30.5
2011/4/10 11:00	36.4	36.4	22.2	31.0
2011/4/10 12:00	39.3	36.3	22.2	31.5
2011/4/10 13:00	42.3	35.4	22.2	32.0
2011/4/10 14:00	44.9	34.4	22.2	32.0
2011/4/10 15:00	48.2	33.9	22.3	32.5
2011/4/10 16:00	50.5	33.4	22.5	33.0
2011/4/10 17:00	53.0	32.8	22.6	33.5
2011/4/10 18:00	55.0	32.5	22.6	34.0
2011/4/10 19:00	50.5	32.0	27.3	33.5
2011/4/10 20:00	47.8	32.2	28.3	33.5
2011/4/10 21:00	44.8	32.4	30.0	30.5
2011/4/10 22:00	42.4	32.8	31.9	29.5
2011/4/10 23:00	40.3	33.2	33.7	29.0
2011/4/11 0:00	38.7	33.5	35.9	28.0
2011/4/11 1:00	37.4	33.8	37.5	27.0
2011/4/11 2:00	36.3	34.2	38.9	26.5
2011/4/11 3:00	35.3	34.6	40.6	25.5
2011/4/11 4:00	34.5	35.0	42.3	25.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/11 5:00	33.8	35.3	44.1	24.0
2011/4/11 6:00	33.1	35.8	45.9	24.0
2011/4/11 7:00	32.8	36.1	47.4	23.0
2011/4/11 8:00	32.3	36.4	49.4	23.0
2011/4/11 9:00	31.8	36.8	51.2	22.5
2011/4/11 10:00	33.5	37.1	52.0	22.0
2011/4/11 11:00	36.6	37.1	41.5	22.5
2011/4/11 12:00	39.5	36.9	37.2	23.0
2011/4/11 13:00	42.6	36.3	33.4	23.0
2011/4/11 14:00	45.6	34.9	30.5	23.5
2011/4/11 15:00	48.3	34.4	28.4	24.0
2011/4/11 16:00	50.7	33.9	27.0	24.5
2011/4/11 17:00	53.3	33.4	25.7	24.5
2011/4/11 18:00	55.9	32.8	25.8	25.0
2011/4/11 19:00	58.9	32.3	25.7	25.5
2011/4/11 20:00	49.2	32.0	24.9	24.9
2011/4/11 21:00	47.4	32.2	24.7	26.0
2011/4/11 22:00	44.6	32.4	24.3	26.5
2011/4/11 23:00	41.5	33.0	23.8	27.0
2011/4/12 0:00	40.4	33.2	23.7	27.5
2011/4/12 1:00	38.8	33.6	23.5	28.0
2011/4/12 2:00	37.4	33.9	23.3	28.0
2011/4/12 3:00	36.3	34.2	23.2	28.5
2011/4/12 4:00	35.2	34.7	23.0	29.0
2011/4/12 5:00	34.4	35.0	22.9	29.5
2011/4/12 6:00	33.6	35.4	22.9	29.5
2011/4/12 7:00	33.1	35.7	22.7	30.0
2011/4/12 8:00	32.8	36.0	22.6	30.0
2011/4/12 9:00	32.1	36.4	22.6	30.5
2011/4/12 10:00	34.1	36.6	22.6	31.0
2011/4/12 11:00	37.3	36.5	22.6	31.5
2011/4/12 12:00	41.0	36.2	22.5	32.0
2011/4/12 13:00	43.5	35.8	22.5	32.0
2011/4/12 14:00	46.2	34.3	22.5	32.5
2011/4/12 15:00	48.7	34.0	22.5	33.0
2011/4/12 16:00	51.5	33.4	22.5	33.0
2011/4/12 17:00	54.0	32.8	22.6	33.5
2011/4/12 18:00	56.5	32.4	26.8	33.5
2011/4/12 19:00	59.1	32.0	27.8	33.5
2011/4/12 20:00	48.0	32.0	30.0	31.0
2011/4/12 21:00	46.6	32.0	31.1	30.0
2011/4/12 22:00	43.7	32.5	33.2	29.5
2011/4/12 23:00	41.5	32.7	35.5	29.0
2011/4/13 0:00	39.7	33.1	37.0	28.0
2011/4/13 1:00	37.9	33.6	38.9	27.0
2011/4/13 2:00	37.1	33.8	39.8	26.0
2011/4/13 3:00	36.0	34.2	41.4	25.0
2011/4/13 4:00	35.1	34.5	43.1	24.5
2011/4/13 5:00	34.2	34.9	45.1	24.0
2011/4/13 6:00	33.6	35.2	46.7	23.5
2011/4/13 7:00	32.9	35.6	48.6	23.0
2011/4/13 8:00	32.5	36.0	50.3	23.0
2011/4/13 9:00	32.0	36.3	51.9	22.5
2011/4/13 10:00	34.1	36.6	53.8	22.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/13 11:00	37.2	36.5	42.6	22.0
2011/4/13 12:00	40.2	36.2	38.0	22.5
2011/4/13 13:00	43.4	35.1	34.2	23.0
2011/4/13 14:00	46.1	34.4	31.6	23.5
2011/4/13 15:00	49.0	33.9	29.3	24.0
2011/4/13 16:00	51.4	33.3	27.9	24.0
2011/4/13 17:00	54.4	32.8	26.5	24.5
2011/4/13 18:00	57.1	32.4	26.3	25.0
2011/4/13 19:00	59.2	32.0	26.0	25.5
2011/4/13 20:00	48.9	32.0	25.6	26.0
2011/4/13 21:00	46.1	32.2	25.4	26.0
2011/4/13 22:00	43.2	32.5	25.1	26.5
2011/4/13 23:00	41.4	32.8	24.9	27.0
2011/4/14 0:00	39.6	33.1	24.7	27.5
2011/4/14 1:00	38.2	33.6	24.6	28.0
2011/4/14 2:00	36.8	33.9	24.4	28.5
2011/4/14 3:00	35.9	34.2	24.3	29.0
2011/4/14 4:00	35.0	34.6	24.2	29.0
2011/4/14 5:00	34.2	35.0	24.1	29.5
2011/4/14 6:00	33.5	35.3	24.1	29.5
2011/4/14 7:00	33.0	35.7	24.0	30.0
2011/4/14 8:00	32.6	36.1	24.0	30.0
2011/4/14 9:00	32.1	36.5	23.9	30.5
2011/4/14 10:00	35.4	36.7	23.9	31.0
2011/4/14 11:00	37.5	36.6	23.9	31.5
2011/4/14 12:00	40.3	36.4	23.9	32.0
2011/4/14 13:00	43.2	35.5	23.9	32.0
2011/4/14 14:00	46.0	34.7	23.9	32.5
2011/4/14 15:00	48.9	34.1	24.0	33.0
2011/4/14 16:00	51.3	33.6	24.1	33.0
2011/4/14 17:00	53.8	33.2	24.0	33.5
2011/4/14 18:00	56.3	32.7	23.8	34.0
2011/4/14 19:00	58.6	32.3	27.9	34.0
2011/4/14 20:00	48.9	32.3	29.2	34.0
2011/4/14 21:00	45.6	32.6	31.1	31.0
2011/4/14 22:00	43.1	32.9	33.1	30.0
2011/4/14 23:00	41.3	33.4	35.3	29.5
2011/4/15 0:00	39.9	33.7	36.7	29.0
2011/4/15 1:00	38.6	34.0	38.2	28.5
2011/4/15 2:00	37.2	34.4	39.9	27.7
2011/4/15 3:00	36.3	34.7	41.3	27.0
2011/4/15 4:00	35.3	35.1	43.2	26.0
2011/4/15 5:00	34.6	35.4	45.1	25.0
2011/4/15 6:00	33.9	35.8	47.1	24.5
2011/4/15 7:00	33.4	36.1	48.7	24.0
2011/4/15 8:00	32.9	36.6	50.5	23.5
2011/4/15 9:00	32.4	37.0	52.4	23.0
2011/4/15 10:00	33.5	37.2	45.6	23.0
2011/4/15 11:00	36.7	37.1	39.8	23.0
2011/4/15 12:00	39.0	37.1	36.7	24.0
2011/4/15 13:00	42.3	36.6	33.0	24.5
2011/4/15 14:00	45.1	35.2	30.4	25.0
2011/4/15 15:00	48.1	34.8	28.2	25.5
2011/4/15 16:00	51.2	34.1	26.8	26.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/15 17:00	52.9	33.7	26.1	26.0
2011/4/15 18:00	55.8	33.2	25.9	26.5
2011/4/15 19:00	58.3	32.7	25.7	26.5
2011/4/15 20:00	49.6	32.5	25.4	27.0
2011/4/15 21:00	46.5	32.8	25.2	27.5
2011/4/15 22:00	44.1	33.1	25.0	28.0
2011/4/15 23:00	42.2	33.4	24.9	28.5
2011/4/16 0:00	40.5	33.8	24.6	29.0
2011/4/16 1:00	38.8	34.2	24.4	29.0
2011/4/16 2:00	37.7	34.5	24.2	29.5
2011/4/16 3:00	36.6	34.9	24.1	30.0
2011/4/16 4:00	35.6	35.2	24.0	30.0
2011/4/16 5:00	34.9	35.6	23.9	30.0
2011/4/16 6:00	34.2	36.0	23.8	30.5
2011/4/16 7:00	33.6	36.3	23.8	31.0
2011/4/16 8:00	33.1	36.8	23.8	31.5
2011/4/16 9:00	32.7	37.3	23.7	32.0
2011/4/16 10:00	32.3	37.3	23.7	32.0
2011/4/16 11:00	35.6	37.5	23.7	32.0
2011/4/16 12:00	38.5	37.4	23.7	32.5
2011/4/16 13:00	41.8	37.0	23.8	33.0
2011/4/16 14:00	45.3	35.7	23.8	33.5
2011/4/16 15:00	47.6	35.1	23.9	34.0
2011/4/16 16:00	49.9	34.7	24.0	34.0
2011/4/16 17:00	52.6	34.2	23.9	34.5
2011/4/16 18:00	55.3	33.7	23.8	35.0
2011/4/16 19:00	57.7	33.2	27.8	35.5
2011/4/16 20:00	48.2	33.1	29.3	35.0
2011/4/16 21:00	45.9	33.3	30.7	32.0
2011/4/16 22:00	43.5	33.7	32.9	31.5
2011/4/16 23:00	41.7	34.1	34.8	31.0
2011/4/17 0:00	40.1	34.3	36.8	30.0
2011/4/17 1:00	38.7	34.8	38.3	29.0
2011/4/17 2:00	37.7	35.1	39.8	28.0
2011/4/17 3:00	36.6	35.3	41.4	27.5
2011/4/17 4:00	35.5	35.9	43.5	27.0
2011/4/17 5:00	34.7	36.2	45.2	26.0
2011/4/17 6:00	34.0	36.6	47.0	25.0
2011/4/17 7:00	33.5	36.9	48.8	24.5
2011/4/17 8:00	33.0	37.2	50.4	24.5
2011/4/17 9:00	32.6	37.7	52.1	24.0
2011/4/17 10:00	33.3	37.9	53.8	24.0
2011/4/17 11:00	36.0	37.9	44.6	24.0
2011/4/17 12:00	38.9	37.8	39.6	24.0
2011/4/17 13:00	42.2	36.9	35.5	24.5
2011/4/17 14:00	44.4	35.9	33.3	24.5
2011/4/17 15:00	47.2	35.4	30.8	25.0
2011/4/17 16:00	49.5	34.9	29.3	26.0
2011/4/17 17:00	51.9	34.4	28.1	26.0
2011/4/17 18:00	55.1	33.7	26.8	26.5
2011/4/17 19:00	57.0	33.4	26.1	27.0
2011/4/17 20:00	47.5	33.3	25.4	27.5
2011/4/17 21:00	45.5	33.5	24.9	28.0
2011/4/17 22:00	43.4	33.9	24.5	28.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/17 23:00	41.4	34.3	24.1	28.5
2011/4/18 0:00	39.8	34.6	23.7	29.0
2011/4/18 1:00	38.5	35.0	23.4	29.0
2011/4/18 2:00	37.5	35.3	23.1	29.5
2011/4/18 3:00	36.4	35.6	22.9	29.5
2011/4/18 4:00	35.5	36.1	22.6	30.0
2011/4/18 5:00	34.8	36.3	22.5	30.5
2011/4/18 6:00	34.2	36.7	22.4	30.5
2011/4/18 7:00	33.5	37.2	22.3	31.0
2011/4/18 8:00	33.2	37.4	22.2	31.5
2011/4/18 9:00	32.8	37.9	22.1	32.0
2011/4/18 10:00	33.6	38.1	22.1	32.5
2011/4/18 11:00	36.8	38.0	22.1	33.0
2011/4/18 12:00	39.9	37.9	22.1	33.0
2011/4/18 13:00	42.4	37.2	22.1	33.5
2011/4/18 14:00	45.5	35.9	22.0	34.0
2011/4/18 15:00	48.0	35.5	22.0	34.0
2011/4/18 16:00	50.9	34.8	22.0	34.5
2011/4/18 17:00	53.0	34.4	22.0	35.0
2011/4/18 18:00	55.4	33.9	21.9	35.5
2011/4/18 19:00	57.9	33.4	26.9	35.5
2011/4/18 20:00	50.2	33.1	28.4	33.5
2011/4/18 21:00	47.7	33.3	29.8	32.5
2011/4/18 22:00	45.0	33.5	31.7	31.0
2011/4/18 23:00	44.5	34.0	33.8	30.5
2011/4/19 0:00	42.7	34.3	35.8	29.5
2011/4/19 1:00	39.6	34.6	37.5	29.0
2011/4/19 2:00	38.5	34.9	38.7	28.0
2011/4/19 3:00	37.1	35.3	40.6	27.5
2011/4/19 4:00	36.2	35.7	42.3	26.5
2011/4/19 5:00	35.3	36.2	44.0	26.0
2011/4/19 6:00	34.6	36.4	46.0	25.5
2011/4/19 7:00	34.0	36.8	47.7	25.0
2011/4/19 8:00	33.6	37.2	49.4	24.5
2011/4/19 9:00	33.2	37.5	50.9	24.5
2011/4/19 10:00	33.7	37.8	52.8	24.0
2011/4/19 11:00	35.2	37.9	44.0	24.0
2011/4/19 12:00	38.3	37.6	39.1	24.5
2011/4/19 13:00	41.2	37.2	35.4	25.0
2011/4/19 14:00	43.7	36.0	32.6	25.0
2011/4/19 15:00	46.3	35.4	30.3	25.5
2011/4/19 16:00	48.4	34.9	28.9	26.0
2011/4/19 17:00	51.0	34.3	27.4	26.5
2011/4/19 18:00	53.1	33.8	26.4	26.5
2011/4/19 19:00	55.6	33.2	25.5	27.0
2011/4/19 20:00	48.3	33.2	24.7	27.0
2011/4/19 21:00	44.9	33.4	24.0	28.0
2011/4/19 22:00	43.2	33.6	23.7	28.0
2011/4/19 23:00	41.6	34.0	23.4	28.5
2011/4/20 0:00	40.0	34.5	23.1	29.0
2011/4/20 1:00	38.6	34.7	22.8	29.5
2011/4/20 2:00	37.4	35.1	22.7	29.5
2011/4/20 3:00	36.5	35.5	22.5	30.0
2011/4/20 4:00	35.6	35.8	22.4	30.0

Fukushima Daiichi Nuclear Power Station Unit5·6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/20 5:00	34.9	36.1	22.4	30.5
2011/4/20 6:00	34.2	36.6	22.5	31.0
2011/4/20 7:00	33.7	36.9	22.5	31.0
2011/4/20 8:00	33.4	37.2	22.6	32.0
2011/4/20 9:00	33.0	37.7	22.6	32.0
2011/4/20 10:00	34.2	37.9	26.6	32.5
2011/4/20 11:00	37.1	37.6	27.3	33.0
2011/4/20 12:00	39.9	37.5	28.8	33.0
2011/4/20 13:00	42.4	36.7	30.3	33.5
2011/4/20 14:00	45.2	35.7	32.1	34.0
2011/4/20 15:00	47.7	35.3	33.9	34.5
2011/4/20 16:00	50.1	34.9	35.9	35.0
2011/4/20 17:00	52.4	34.3	29.6	35.0
2011/4/20 18:00	54.8	33.8	28.2	35.5
2011/4/20 19:00	57.3	33.5	30.8	35.5
2011/4/20 20:00	50.5	33.1	31.5	35.5
2011/4/20 21:00	46.5	33.5	33.0	33.0
2011/4/20 22:00	45.5	33.7	35.3	32.0
2011/4/20 23:00	43.4	34.0	36.9	31.5
2011/4/21 0:00	41.6	34.3	38.6	30.5
2011/4/21 1:00	40.3	34.7	39.9	30.0
2011/4/21 2:00	39.0	35.1	41.6	29.5
2011/4/21 3:00	37.9	35.4	43.3	29.0
2011/4/21 4:00	37.1	35.6	44.7	28.0
2011/4/21 5:00	36.1	36.2	46.7	27.5
2011/4/21 6:00	35.3	36.4	48.8	27.0
2011/4/21 7:00	34.7	36.9	50.3	26.5
2011/4/21 8:00	34.0	37.2	51.5	26.0
2011/4/21 9:00	33.9	37.5	53.5	25.5
2011/4/21 10:00	34.4	37.9	47.1	25.5
2011/4/21 11:00	37.8	37.8	40.8	25.5
2011/4/21 12:00	38.6	37.7	38.1	26.0
2011/4/21 13:00	42.7	37.2	35.2	26.5
2011/4/21 14:00	45.5	36.2	32.7	27.0
2011/4/21 15:00	47.8	35.8	31.0	27.0
2011/4/21 16:00	50.5	35.3	29.5	27.0
2011/4/21 17:00	52.7	34.8	28.3	28.0
2011/4/21 18:00	55.2	34.4	27.3	28.0
2011/4/21 19:00	57.4	34.0	26.5	29.0
2011/4/21 20:00	50.9	33.8	25.7	29.0
2011/4/21 21:00	47.9	34.0	25.3	29.0
2011/4/21 22:00	45.5	34.4	24.9	29.5
2011/4/21 23:00	43.5	34.7	24.6	30.0
2011/4/22 0:00	42.0	35.0	24.3	30.0
2011/4/22 1:00	40.6	35.4	24.1	30.5
2011/4/22 2:00	39.3	35.7	23.9	31.0
2011/4/22 3:00	38.3	36.1	23.8	31.5
2011/4/22 4:00	37.4	36.4	23.7	31.5
2011/4/22 5:00	36.6	36.8	23.6	32.0
2011/4/22 6:00	35.9	37.1	23.6	32.0
2011/4/22 7:00	35.4	37.5	23.5	32.5
2011/4/22 8:00	34.9	37.9	23.5	33.0
2011/4/22 9:00	34.4	38.2	23.4	33.5
2011/4/22 10:00	35.0	38.5	23.4	33.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/22 11:00	38.1	38.4	23.4	34.0
2011/4/22 12:00	40.9	38.2	23.3	34.5
2011/4/22 13:00	43.6	37.7	23.3	35.0
2011/4/22 14:00	46.3	36.6	23.3	35.5
2011/4/22 15:00	48.9	36.2	23.3	36.0
2011/4/22 16:00	51.6	35.7	23.3	36.0
2011/4/22 17:00	53.8	35.2	23.3	36.5
2011/4/22 18:00	56.5	34.7	27.2	36.5
2011/4/22 19:00	58.7	34.3	28.5	36.5
2011/4/22 20:00	50.0	34.2	30.3	34.0
2011/4/22 21:00	47.5	34.5	31.9	33.0
2011/4/22 22:00	45.2	34.9	34.2	32.0
2011/4/22 23:00	43.4	35.1	35.8	31.0
2011/4/23 0:00	41.9	35.5	37.3	30.5
2011/4/23 1:00	40.3	35.8	38.9	29.5
2011/4/23 2:00	39.1	36.3	40.4	29.0
2011/4/23 3:00	38.2	36.5	42.0	28.5
2011/4/23 4:00	37.3	36.9	43.9	28.0
2011/4/23 5:00	36.5	37.3	45.5	27.5
2011/4/23 6:00	35.8	37.6	47.5	27.0
2011/4/23 7:00	35.3	37.9	49.1	26.5
2011/4/23 8:00	34.8	38.3	50.9	26.0
2011/4/23 9:00	34.4	38.7	52.3	25.5
2011/4/23 10:00	34.9	39.0	53.8	25.0
2011/4/23 11:00	38.3	38.9	46.8	25.0
2011/4/23 12:00	40.4	38.8	43.0	25.5
2011/4/23 13:00	43.5	38.2	39.2	26.0
2011/4/23 14:00	46.4	36.9	36.1	26.5
2011/4/23 15:00	48.8	36.6	34.1	27.0
2011/4/23 16:00	51.5	36.1	32.1	27.0
2011/4/23 17:00	53.8	35.6	30.8	27.5
2011/4/23 18:00	56.3	35.1	29.5	28.0
2011/4/23 19:00	58.6	34.8	28.6	28.5
2011/4/23 20:00	48.7	34.8	27.8	29.0
2011/4/23 21:00	46.3	35.1	27.1	29.0
2011/4/23 22:00	44.4	35.4	26.6	29.5
2011/4/23 23:00	42.7	35.8	26.1	29.5
2011/4/24 0:00	41.4	36.1	25.8	30.0
2011/4/24 1:00	40.2	36.4	25.5	30.0
2011/4/24 2:00	39.0	36.8	25.2	30.5
2011/4/24 3:00	38.2	37.1	25.0	31.0
2011/4/24 4:00	37.4	37.5	24.8	31.0
2011/4/24 5:00	36.7	37.8	24.4	31.5
2011/4/24 6:00	36.1	38.1	24.6	32.0
2011/4/24 7:00	35.6	38.6	24.4	32.5
2011/4/24 8:00	35.1	38.9	24.4	33.0
2011/4/24 9:00	34.7	39.2	24.3	33.5
2011/4/24 10:00	35.6	39.6	24.2	33.5
2011/4/24 11:00	39.7	39.3	24.2	34.0
2011/4/24 12:00	40.8	39.2	24.1	34.5
2011/4/24 13:00	43.4	38.4	24.1	34.5
2011/4/24 14:00	46.3	37.5	24.1	35.0
2011/4/24 15:00	48.5	37.1	24.1	35.5
2011/4/24 16:00	50.6	36.7	24.1	36.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/24 17:00	53.7	35.9	24.1	36.5
2011/4/24 18:00	56.1	35.5	24.2	37.0
2011/4/24 19:00	58.1	35.2	28.1	36.5
2011/4/24 20:00	60.8	34.7	30.1	35.0
2011/4/24 21:00	62.6	34.4	31.6	34.5
2011/4/24 22:00	58.4	34.1	33.3	34.0
2011/4/24 23:00	55.0	34.1	35.3	32.5
2011/4/25 0:00	51.8	34.4	36.9	32.0
2011/4/25 1:00	49.0	34.8	38.4	31.0
2011/4/25 2:00	46.8	35.1	39.9	30.0
2011/4/25 3:00	44.9	35.5	41.5	29.5
2011/4/25 4:00	43.3	35.8	43.3	29.5
2011/4/25 5:00	41.8	36.2	45.0	28.5
2011/4/25 6:00	40.5	36.6	46.9	28.5
2011/4/25 7:00	39.4	37.0	48.8	28.0
2011/4/25 8:00	38.7	37.3	50.2	27.5
2011/4/25 9:00	37.5	37.9	52.6	27.0
2011/4/25 10:00	37.2	38.0	53.5	26.5
2011/4/25 11:00	36.6	38.3	44.5	26.5
2011/4/25 12:00	36.1	38.6	41.2	27.0
2011/4/25 13:00	37.2	39.0	38.1	27.5
2011/4/25 14:00	39.7	39.3	36.1	28.0
2011/4/25 15:00	43.0	39.6	34.0	28.5
2011/4/25 16:00	45.9	40.0	32.3	28.5
2011/4/25 17:00	48.1	40.3	31.2	29.0
2011/4/25 18:00	50.5	40.1	30.1	29.5
2011/4/25 19:00	52.9	39.9	29.3	29.5
2011/4/25 20:00	55.6	39.0	28.5	30.0
2011/4/25 21:00	58.0	38.5	27.9	30.0
2011/4/25 22:00	60.6	38.0	27.3	30.5
2011/4/25 23:00	62.2	37.8	27.0	31.0
2011/4/26 0:00	53.3	37.5	26.6	31.5
2011/4/26 1:00	50.5	37.8	26.3	32.0
2011/4/26 2:00	48.0	38.1	26.1	32.5
2011/4/26 3:00	46.0	38.4	25.9	32.5
2011/4/26 4:00	44.2	38.8	25.7	33.0
2011/4/26 5:00	42.7	39.1	25.5	33.0
2011/4/26 6:00	41.1	39.5	25.4	33.5
2011/4/26 7:00	39.9	40.0	25.2	34.0
2011/4/26 8:00	39.1	40.3	25.1	34.5
2011/4/26 9:00	39.0	40.6	25.0	35.0
2011/4/26 10:00	40.6	40.6	25.0	35.5
2011/4/26 11:00	43.1	40.4	24.9	36.0
2011/4/26 12:00	45.9	40.0	24.9	36.0
2011/4/26 13:00	48.6	39.1	24.8	36.5
2011/4/26 14:00	51.1	38.7	24.8	37.0
2011/4/26 15:00	53.7	38.3	24.8	37.0
2011/4/26 16:00	55.8	37.9	24.8	37.5
2011/4/26 17:00	58.3	37.5	24.8	37.5
2011/4/26 18:00	60.6	37.1	27.6	38.0
2011/4/26 19:00	63.0	36.8	28.7	38.0
2011/4/26 20:00	54.9	36.8	30.2	37.0
2011/4/26 21:00	51.6	37.1	32.2	35.0
2011/4/26 22:00	49.0	37.3	34.3	34.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/26 23:00	46.7	37.7	36.3	34.0
2011/4/27 0:00	44.8	38.0	37.9	33.0
2011/4/27 1:00	43.2	38.3	39.3	32.0
2011/4/27 2:00	42.0	38.7	40.8	31.0
2011/4/27 3:00	41.0	39.0	42.3	31.0
2011/4/27 4:00	39.9	39.4	44.2	30.0
2011/4/27 5:00	39.0	39.7	45.9	29.5
2011/4/27 6:00	38.3	40.1	47.9	28.5
2011/4/27 7:00	37.6	40.4	49.5	28.5
2011/4/27 8:00	37.0	40.8	51.1	28.0
2011/4/27 9:00	35.4	41.1	52.8	27.5
2011/4/27 10:00	37.5	41.3	54.3	27.0
2011/4/27 11:00	40.4	41.1	44.3	27.0
2011/4/27 12:00	42.8	40.8	40.9	27.5
2011/4/27 13:00	45.8	39.5	37.6	28.5
2011/4/27 14:00	48.1	39.1	35.5	29.0
2011/4/27 15:00	50.4	38.8	33.6	29.0
2011/4/27 16:00	52.7	38.3	32.1	29.5
2011/4/27 17:00	55.0	37.8	30.9	30.0
2011/4/27 18:00	58.2	37.5	29.8	30.0
2011/4/27 19:00	59.4	37.1	29.2	30.0
2011/4/27 20:00	53.4	37.0	28.6	30.5
2011/4/27 21:00	50.5	37.4	32.6	30.5
2011/4/27 22:00	48.2	37.6	34.1	30.0
2011/4/27 23:00	47.5	37.9	35.9	29.5
2011/4/28 0:00	45.7	38.3	37.5	29.0
2011/4/28 1:00	43.3	38.6	39.0	29.0
2011/4/28 2:00	41.9	39.0	40.7	28.5
2011/4/28 3:00	41.0	39.2	42.1	28.0
2011/4/28 4:00	40.1	39.6	43.9	27.0
2011/4/28 5:00	39.4	39.9	45.6	27.0
2011/4/28 6:00	38.7	40.4	47.5	27.0
2011/4/28 7:00	38.1	40.7	49.3	26.5
2011/4/28 8:00	37.6	41.0	50.9	26.5
2011/4/28 9:00	37.1	41.3	52.5	26.0
2011/4/28 10:00	38.7	41.6	46.2	26.0
2011/4/28 11:00	41.3	41.4	43.2	26.5
2011/4/28 12:00	43.9	41.1	40.3	27.0
2011/4/28 13:00	46.4	40.1	37.7	27.5
2011/4/28 14:00	48.9	39.5	35.6	28.0
2011/4/28 15:00	51.4	39.1	33.7	28.0
2011/4/28 16:00	53.8	38.7	32.2	28.5
2011/4/28 17:00	55.8	38.3	31.2	29.0
2011/4/28 18:00	58.0	37.9	30.2	29.5
2011/4/28 19:00	60.5	37.5	29.3	30.0
2011/4/28 20:00	57.7	37.1	28.7	30.0
2011/4/28 21:00	54.2	37.2	28.2	30.0
2011/4/28 22:00	51.3	37.5	27.7	30.5
2011/4/28 23:00	48.7	37.9	27.2	30.5
2011/4/29 0:00	46.6	38.2	26.8	31.0
2011/4/29 1:00	45.1	38.5	26.6	31.0
2011/4/29 2:00	43.3	38.9	26.2	32.0
2011/4/29 3:00	42.0	39.2	26.0	32.5
2011/4/29 4:00	41.0	39.5	25.7	33.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/4/29 5:00	40.0	39.9	25.5	33.0
2011/4/29 6:00	39.1	40.3	25.3	33.5
2011/4/29 7:00	38.4	40.6	25.2	34.0
2011/4/29 8:00	37.9	41.1	25.1	34.0
2011/4/29 9:00	37.3	41.4	25.0	34.5
2011/4/29 10:00	38.2	41.6	24.9	35.0
2011/4/29 11:00	41.2	41.4	24.9	35.5
2011/4/29 12:00	43.7	41.2	24.8	36.0
2011/4/29 13:00	47.0	40.1	24.8	36.5
2011/4/29 14:00	48.9	39.6	24.8	36.5
2011/4/29 15:00	51.3	39.2	24.9	37.0
2011/4/29 16:00	53.7	38.9	24.9	37.0
2011/4/29 17:00	55.9	38.4	24.9	37.5
2011/4/29 18:00	58.4	38.0	24.9	38.0
2011/4/29 19:00	60.8	37.7	28.6	37.5
2011/4/29 20:00	62.7	37.3	30.1	37.5
2011/4/29 21:00	64.9	37.0	31.9	35.0
2011/4/29 22:00	57.1	36.9	33.8	35.0
2011/4/29 23:00	53.7	37.1	36.0	34.0
2011/4/30 0:00	50.7	37.4	37.6	33.0
2011/4/30 1:00	48.4	37.8	39.2	32.0
2011/4/30 2:00	46.3	38.1	40.8	31.0
2011/4/30 3:00	44.8	38.4	42.1	30.5
2011/4/30 4:00	42.7	38.9	44.6	30.0
2011/4/30 5:00	42.0	39.1	45.6	29.5
2011/4/30 6:00	40.7	39.6	47.7	29.0
2011/4/30 7:00	40.0	39.9	49.2	28.5
2011/4/30 8:00	39.3	40.3	50.7	28.0
2011/4/30 9:00	38.5	40.6	52.6	28.0
2011/4/30 10:00	40.9	40.6	54.2	27.5
2011/4/30 11:00	42.5	40.5	46.0	28.0
2011/4/30 12:00	46.1	40.1	42.5	28.0
2011/4/30 13:00	48.5	39.3	39.5	28.0
2011/4/30 14:00	51.4	38.6	36.7	29.0
2011/4/30 15:00	53.0	38.4	35.3	29.0
2011/4/30 16:00	55.5	38.0	33.4	29.5
2011/4/30 17:00	57.7	37.6	32.1	29.5
2011/4/30 18:00	59.7	37.3	31.0	30.0
2011/4/30 19:00	61.9	37.0	30.1	30.1
2011/4/30 20:00	64.0	36.8	30.0	29.3
2011/4/30 21:00	56.3	36.8	28.5	31.0
2011/4/30 22:00	53.4	37.0	28.1	31.0
2011/4/30 23:00	50.5	37.3	27.5	32.0
2011/5/1 0:00	48.2	37.6	27.1	32.0
2011/5/1 1:00	46.1	37.9	26.8	32.5
2011/5/1 2:00	44.5	38.3	26.4	33.0
2011/5/1 3:00	42.8	38.7	26.0	33.5
2011/5/1 4:00	41.8	38.9	25.8	33.5
2011/5/1 5:00	40.7	39.3	25.5	34.0
2011/5/1 6:00	39.7	39.7	25.3	34.5
2011/5/1 7:00	39.1	40.0	25.2	35.0
2011/5/1 8:00	38.4	40.5	25.0	35.0
2011/5/1 9:00	37.7	40.9	24.9	35.5
2011/5/1 10:00	40.0	40.8	27.8	36.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/1 11:00	42.9	40.5	28.9	36.0
2011/5/1 12:00	45.4	40.2	30.2	35.0
2011/5/1 13:00	48.2	39.4	32.1	33.5
2011/5/1 14:00	50.3	39.0	33.6	33.5
2011/5/1 15:00	53.1	38.6	36.1	32.0
2011/5/1 16:00	55.1	38.2	37.4	31.0
2011/5/1 17:00	57.6	37.8	39.0	30.0
2011/5/1 18:00	59.5	37.4	40.3	29.5
2011/5/1 19:00	62.5	37.0	42.2	29.0
2011/5/1 20:00	64.3	36.7	38.9	29.0
2011/5/1 21:00	56.0	36.9	36.8	29.0
2011/5/1 22:00	52.4	37.1	34.5	29.5
2011/5/1 23:00	50.0	37.4	32.8	30.0
2011/5/2 0:00	47.7	37.8	31.5	30.0
2011/5/2 1:00	46.3	38.0	30.5	30.5
2011/5/2 2:00	44.4	38.4	29.4	31.0
2011/5/2 3:00	43.1	38.7	28.6	31.0
2011/5/2 4:00	41.2	39.3	27.5	32.0
2011/5/2 5:00	40.8	39.4	27.3	32.0
2011/5/2 6:00	39.8	39.8	26.7	32.5
2011/5/2 7:00	39.2	40.1	26.4	32.5
2011/5/2 8:00	38.6	40.6	26.0	33.0
2011/5/2 9:00	38.0	40.8	25.7	33.5
2011/5/2 10:00	40.2	40.9	25.4	34.0
2011/5/2 11:00	43.0	40.7	25.2	34.5
2011/5/2 12:00	45.7	40.4	29.1	35.0
2011/5/2 13:00	48.3	39.6	30.3	35.5
2011/5/2 14:00	50.5	39.0	31.8	36.0
2011/5/2 15:00	53.1	39.1	30.4	36.0
2011/5/2 16:00	55.7	39.1	29.1	36.0
2011/5/2 17:00	58.0	39.0	28.3	36.5
2011/5/2 18:00	60.3	38.6	27.5	37.0
2011/5/2 19:00	63.0	37.9	26.8	37.5
2011/5/2 20:00	64.8	37.5	26.4	38.0
2011/5/2 21:00	59.0	37.1	29.7	37.5
2011/5/2 22:00	55.0	37.2	31.0	37.0
2011/5/2 23:00	51.8	37.5	32.7	35.5
2011/5/3 0:00	48.9	37.8	34.9	34.0
2011/5/3 1:00	46.7	38.2	36.3	33.0
2011/5/3 2:00	44.7	38.5	37.8	32.5
2011/5/3 3:00	43.0	38.9	39.2	32.0
2011/5/3 4:00	41.6	39.3	40.7	31.0
2011/5/3 5:00	40.4	39.5	42.2	30.0
2011/5/3 6:00	39.3	39.9	44.0	30.0
2011/5/3 7:00	38.4	40.2	45.7	29.0
2011/5/3 8:00	37.7	40.6	47.5	28.5
2011/5/3 9:00	37.1	41.0	49.0	28.0
2011/5/3 10:00	37.9	41.3	50.7	28.0
2011/5/3 11:00	40.4	41.1	42.1	28.0
2011/5/3 12:00	43.2	40.8	39.0	28.5
2011/5/3 13:00	46.4	39.9	36.2	29.0
2011/5/3 14:00	48.6	39.2	34.5	29.0
2011/5/3 15:00	51.4	39.0	32.6	29.5
2011/5/3 16:00	54.1	38.5	31.1	30.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/3 17:00	57.1	38.0	29.8	30.0
2011/5/3 18:00	58.6	37.5	29.2	30.5
2011/5/3 19:00	60.2	37.3	28.7	30.5
2011/5/3 20:00	62.9	36.8	27.9	31.0
2011/5/3 21:00	54.5	36.8	27.4	31.5
2011/5/3 22:00	51.4	37.1	26.9	32.0
2011/5/3 23:00	49.0	37.4	26.6	32.5
2011/5/4 0:00	47.0	37.7	26.3	33.0
2011/5/4 1:00	45.2	38.0	26.0	33.5
2011/5/4 2:00	43.8	38.3	25.8	33.5
2011/5/4 3:00	42.4	38.7	25.6	34.0
2011/5/4 4:00	41.1	39.1	25.4	34.5
2011/5/4 5:00	40.2	39.4	25.2	35.0
2011/5/4 6:00	39.3	39.7	25.1	35.0
2011/5/4 7:00	38.6	40.1	25.1	35.0
2011/5/4 8:00	37.9	40.5	24.9	35.5
2011/5/4 9:00	37.4	40.8	24.8	36.0
2011/5/4 10:00	36.3	41.1	24.8	36.5
2011/5/4 11:00	40.2	41.0	28.4	36.5
2011/5/4 12:00	42.9	40.8	29.9	36.0
2011/5/4 13:00	45.8	40.0	31.9	34.0
2011/5/4 14:00	48.0	39.0	33.5	33.5
2011/5/4 15:00	50.3	38.6	35.7	32.5
2011/5/4 16:00	52.8	38.3	37.3	31.5
2011/5/4 17:00	55.0	38.1	38.7	30.5
2011/5/4 18:00	57.0	37.6	40.1	30.5
2011/5/4 19:00	59.1	37.3	41.5	30.0
2011/5/4 20:00	61.7	36.8	43.4	29.5
2011/5/4 21:00	56.6	36.5	44.8	29.0
2011/5/4 22:00	53.4	36.8	37.5	29.0
2011/5/4 23:00	50.8	37.0	35.4	29.0
2011/5/5 0:00	48.7	37.4	33.8	29.5
2011/5/5 1:00	46.6	37.8	32.2	30.0
2011/5/5 2:00	45.0	38.1	32.1	30.0
2011/5/5 3:00	43.6	38.4	30.1	31.0
2011/5/5 4:00	42.2	38.7	29.2	31.0
2011/5/5 5:00	41.2	39.0	28.5	31.5
2011/5/5 6:00	40.2	39.4	27.9	32.0
2011/5/5 7:00	39.2	39.8	27.4	32.5
2011/5/5 8:00	38.6	40.1	27.0	33.0
2011/5/5 9:00	38.1	40.5	26.7	33.0
2011/5/5 10:00	39.1	40.7	26.3	33.5
2011/5/5 11:00	40.9	40.5	26.2	34.0
2011/5/5 12:00	43.4	40.3	26.0	34.5
2011/5/5 13:00	45.9	39.7	25.8	34.5
2011/5/5 14:00	48.4	39.1	25.6	35.0
2011/5/5 15:00	50.6	38.8	25.5	35.5
2011/5/5 16:00	53.1	38.5	25.4	36.0
2011/5/5 17:00	55.1	38.0	25.4	36.0
2011/5/5 18:00	57.5	37.7	25.4	36.5
2011/5/5 19:00	59.6	37.3	29.0	36.5
2011/5/5 20:00	61.7	37.0	30.5	35.5
2011/5/5 21:00	63.8	36.8	32.3	34.5
2011/5/5 22:00	65.8	36.5	34.1	33.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/5 23:00	57.7	36.2	36.2	32.5
2011/5/6 0:00	58.2	36.4	37.7	32.0
2011/5/6 1:00	55.4	36.7	36.7	31.5
2011/5/6 2:00	52.5	36.9	40.4	31.0
2011/5/6 3:00	50.1	37.4	41.9	30.5
2011/5/6 4:00	47.8	37.7	43.7	30.0
2011/5/6 5:00	46.1	38.0	45.3	29.5
2011/5/6 6:00	44.5	38.4	47.1	29.0
2011/5/6 7:00	42.8	38.9	49.3	28.5
2011/5/6 8:00	42.0	39.1	50.3	28.5
2011/5/6 9:00	41.1	39.4	52.0	28.0
2011/5/6 10:00	42.5	39.6	53.5	28.0
2011/5/6 11:00	45.1	39.5	44.3	28.0
2011/5/6 12:00	47.6	39.3	41.2	28.5
2011/5/6 13:00	50.3	38.7	38.3	29.0
2011/5/6 14:00	52.3	38.4	36.5	29.0
2011/5/6 15:00	54.8	38.1	34.6	29.5
2011/5/6 16:00	56.9	37.7	33.3	29.5
2011/5/6 17:00	59.2	37.5	32.1	30.0
2011/5/6 18:00	61.3	37.1	31.1	30.5
2011/5/6 19:00	63.6	36.7	30.2	30.5
2011/5/6 20:00	65.7	36.5	29.6	31.0
2011/5/6 21:00	67.6	36.4	29.0	31.5
2011/5/6 22:00	61.0	36.2	28.5	32.0
2011/5/6 23:00	57.6	36.5	28.1	32.0
2011/5/7 0:00	54.0	36.8	27.7	33.0
2011/5/7 1:00	51.9	37.1	27.5	33.0
2011/5/7 2:00	49.6	37.6	27.2	33.5
2011/5/7 3:00	47.8	37.8	27.0	34.0
2011/5/7 4:00	46.1	38.3	26.8	34.5
2011/5/7 5:00	44.8	38.6	26.7	34.5
2011/5/7 6:00	43.6	38.8	26.5	35.0
2011/5/7 7:00	42.6	39.3	26.4	35.0
2011/5/7 8:00	41.8	39.6	26.3	35.5
2011/5/7 9:00	41.1	39.9	26.2	36.0
2011/5/7 10:00	42.1	40.0	26.1	36.5
2011/5/7 11:00	44.9	40.0	26.1	37.0
2011/5/7 12:00	47.6	39.6	26.1	37.0
2011/5/7 13:00	50.0	39.2	26.1	37.5
2011/5/7 14:00	52.6	38.9	26.1	38.0
2011/5/7 15:00	55.0	38.5	26.1	38.0
2011/5/7 16:00	57.3	38.2	26.1	38.5
2011/5/7 17:00	59.4	38.0	26.1	38.5
2011/5/7 18:00	61.7	37.7	26.1	39.0
2011/5/7 19:00	64.0	37.3	29.7	39.0
2011/5/7 20:00	66.0	37.2	31.2	38.5
2011/5/7 21:00	59.4	37.1	32.9	36.5
2011/5/7 22:00	56.1	37.4	34.6	36.0
2011/5/7 23:00	53.3	37.6	36.8	35.0
2011/5/8 0:00	52.1	38.1	38.5	34.5
2011/5/8 1:00	50.1	38.4	39.9	33.5
2011/5/8 2:00	47.4	38.6	41.3	33.0
2011/5/8 3:00	46.0	39.1	42.8	32.5
2011/5/8 4:00	44.6	39.4	44.6	31.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/8 5:00	43.5	39.7	46.4	30.5
2011/5/8 6:00	42.5	40.1	47.9	30.0
2011/5/8 7:00	41.6	40.4	50.0	29.5
2011/5/8 8:00	40.9	40.7	51.2	29.0
2011/5/8 9:00	40.4	41.1	52.8	29.0
2011/5/8 10:00	42.3	41.3	54.3	29.5
2011/5/8 11:00	45.0	41.1	43.6	29.0
2011/5/8 12:00	47.4	40.8	40.7	29.0
2011/5/8 13:00	51.5	39.9	36.8	29.5
2011/5/8 14:00	52.9	39.6	35.7	30.0
2011/5/8 15:00	55.0	39.4	34.2	30.0
2011/5/8 16:00	57.1	39.2	32.9	30.5
2011/5/8 17:00	57.0	38.9	31.7	31.0
2011/5/8 18:00	61.7	38.5	30.8	31.0
2011/5/8 19:00	63.9	38.2	30.0	31.5
2011/5/8 20:00	66.0	38.0	29.4	32.0
2011/5/8 21:00	68.1	37.7	28.7	32.5
2011/5/8 22:00	60.4	37.6	28.3	33.0
2011/5/8 23:00	57.1	38.0	27.9	33.5
2011/5/9 0:00	54.5	38.3	27.5	34.0
2011/5/9 1:00	52.4	38.6	27.2	34.0
2011/5/9 2:00	50.3	39.0	27.0	34.5
2011/5/9 3:00	48.8	39.3	26.8	34.5
2011/5/9 4:00	47.2	39.6	26.5	35.0
2011/5/9 5:00	45.9	39.9	26.3	35.5
2011/5/9 6:00	44.8	40.3	26.2	35.5
2011/5/9 7:00	43.8	40.6	26.0	36.0
2011/5/9 8:00	42.5	41.2	25.9	36.5
2011/5/9 9:00	42.3	41.4	25.9	36.5
2011/5/9 10:00	44.7	41.3	25.7	37.0
2011/5/9 11:00	48.0	41.0	25.6	37.5
2011/5/9 12:00	50.5	40.6	25.6	38.0
2011/5/9 13:00	52.3	40.2	25.5	38.0
2011/5/9 14:00	54.5	40.0	25.5	38.5
2011/5/9 15:00	56.7	39.7	25.5	38.5
2011/5/9 16:00	59.2	39.4	25.6	39.0
2011/5/9 17:00	61.7	39.1	25.6	39.5
2011/5/9 18:00	63.5	38.9	26.0	39.5
2011/5/9 19:00	65.8	38.6	29.6	39.5
2011/5/9 20:00	67.9	38.4	31.3	38.0
2011/5/9 21:00	62.3	38.3	33.0	37.0
2011/5/9 22:00	58.4	38.5	35.1	36.0
2011/5/9 23:00	56.1	38.7	36.8	35.5
2011/5/10 0:00	53.7	39.1	38.3	35.0
2011/5/10 1:00	51.7	39.5	39.7	34.0
2011/5/10 2:00	50.0	39.8	41.2	33.0
2011/5/10 3:00	48.5	40.1	42.8	32.0
2011/5/10 4:00	47.2	40.5	44.5	32.0
2011/5/10 5:00	46.1	40.8	46.1	31.5
2011/5/10 6:00	45.2	41.1	47.8	30.5
2011/5/10 7:00	44.2	41.6	49.6	30.0
2011/5/10 8:00	43.4	41.8	51.2	30.0
2011/5/10 9:00	42.8	42.1	52.7	29.5
2011/5/10 10:00	44.9	42.2	54.1	29.0

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/10 11:00	47.8	42.0	44.0	29.5
2011/5/10 12:00	49.9	41.8	41.6	29.5
2011/5/10 13:00	52.7	41.1	38.6	30.0
2011/5/10 14:00	55.1	40.8	36.7	30.5
2011/5/10 15:00	57.3	40.4	34.9	31.0
2011/5/10 16:00	59.4	40.1	33.5	31.0
2011/5/10 17:00	61.6	39.8	32.3	31.5
2011/5/10 18:00	63.9	39.6	31.3	32.0
2011/5/10 19:00	65.8	39.3	30.5	32.0
2011/5/10 20:00	68.1	38.9	29.7	32.5
2011/5/10 21:00	70.1	38.7	29.1	33.0
2011/5/10 22:00	61.3	38.9	28.6	33.5
2011/5/10 23:00	58.2	39.2	28.1	34.0
2011/5/11 0:00	55.7	39.4	27.7	34.5
2011/5/11 1:00	53.4	39.7	27.4	34.5
2011/5/11 2:00	51.4	40.1	27.1	35.0
2011/5/11 3:00	49.8	40.5	26.9	35.0
2011/5/11 4:00	48.4	40.7	26.7	35.0
2011/5/11 5:00	47.0	41.2	26.5	36.0
2011/5/11 6:00	46.0	41.5	26.3	36.5
2011/5/11 7:00	44.8	41.8	26.2	37.0
2011/5/11 8:00	44.1	42.1	26.1	37.0
2011/5/11 9:00	42.7	42.5	26.0	37.5
2011/5/11 10:00	43.8	42.7	26.0	37.5
2011/5/11 11:00	46.3	42.5	25.9	38.0
2011/5/11 12:00	49.0	42.3	25.8	38.5
2011/5/11 13:00	51.5	41.8	25.9	39.0
2011/5/11 14:00	53.6	41.3	25.9	39.0
2011/5/11 15:00	55.9	40.9	25.9	39.5
2011/5/11 16:00	58.3	40.7	25.9	40.0
2011/5/11 17:00	60.1	40.4	25.9	40.0
2011/5/11 18:00	62.4	40.0	29.6	40.0
2011/5/11 19:00	64.4	39.7	31.2	39.0
2011/5/11 20:00	66.4	39.5	32.9	37.5
2011/5/11 21:00	62.1	39.2	35.2	36.0
2011/5/11 22:00	58.9	39.4	37.1	35.5
2011/5/11 23:00	56.5	39.7	38.4	34.5
2011/5/12 0:00	54.3	40.1	39.8	34.0
2011/5/12 1:00	52.2	40.4	41.3	33.5
2011/5/12 2:00	50.4	40.7	42.8	33.0
2011/5/12 3:00	49.0	41.0	44.4	32.5
2011/5/12 4:00	47.6	41.4	46.2	31.0
2011/5/12 5:00	46.4	41.7	47.8	30.5
2011/5/12 6:00	45.3	42.0	49.6	30.0
2011/5/12 7:00	44.6	42.4	51.1	29.5
2011/5/12 8:00	43.7	42.8	52.5	29.0
2011/5/12 9:00	43.0	43.0	54.3	29.0
2011/5/12 10:00	44.4	43.2	55.8	28.5
2011/5/12 11:00	47.1	43.0	46.1	29.0
2011/5/12 12:00	49.5	42.9	42.7	29.0
2011/5/12 13:00	52.1	42.2	39.8	29.5
2011/5/12 14:00	54.4	41.7	37.5	29.5
2011/5/12 15:00	56.7	41.3	35.5	30.0
2011/5/12 16:00	58.8	41.1	33.9	30.5

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/12 17:00	61.1	40.8	32.4	30.5
2011/5/12 18:00	63.4	40.4	31.2	31.0
2011/5/12 19:00	65.1	40.1	30.5	31.5
2011/5/12 20:00	67.3	39.8	29.6	32.0
2011/5/12 21:00	69.2	39.6	29.0	32.5
2011/5/12 22:00	60.4	39.6	28.5	33.0
2011/5/12 23:00	57.6	39.9	27.9	33.0
2011/5/13 0:00	55.2	40.3	27.6	33.5
2011/5/13 1:00	53.2	40.5	27.2	34.0
2011/5/13 2:00	51.5	40.9	27.0	34.5
2011/5/13 3:00	50.0	41.2	26.8	35.0
2011/5/13 4:00	48.6	41.5	26.6	35.0
2011/5/13 5:00	47.4	41.9	26.5	35.5
2011/5/13 6:00	46.3	42.2	26.5	35.5
2011/5/13 7:00	45.5	42.5	26.4	36.0
2011/5/13 8:00	44.5	42.8	26.4	36.5
2011/5/13 9:00	43.3	43.1	26.3	36.5
2011/5/13 10:00	45.0	43.3	26.3	37.0
2011/5/13 11:00	47.4	43.2	26.2	37.0
2011/5/13 12:00	50.0	42.8	26.2	37.5
2011/5/13 13:00	52.3	42.2	26.2	38.0
2011/5/13 14:00	54.9	41.8	26.2	38.0
2011/5/13 15:00	57.1	41.6	26.1	38.5
2011/5/13 16:00	58.7	41.3	26.1	39.0
2011/5/13 17:00	60.9	41.0	26.1	39.0
2011/5/13 18:00	63.0	40.6	26.1	39.5
2011/5/13 19:00	65.3	40.3	29.7	39.5
2011/5/13 20:00	67.8	40.0	31.8	38.0
2011/5/13 21:00	68.9	39.9	32.8	37.0
2011/5/13 22:00	62.2	39.8	34.5	36.5
2011/5/13 23:00	59.1	40.1	36.7	35.5
2011/5/14 0:00	56.5	40.3	38.2	34.5
2011/5/14 1:00	54.6	40.7	39.6	34.0
2011/5/14 2:00	52.5	41.1	41.1	33.5
2011/5/14 3:00	51.0	41.4	42.4	33.0
2011/5/14 4:00	49.3	41.6	44.2	32.0
2011/5/14 5:00	48.0	42.1	45.9	31.5
2011/5/14 6:00	46.7	42.4	47.8	30.5
2011/5/14 7:00	45.8	42.7	49.5	30.0
2011/5/14 8:00	44.9	43.0	51.0	30.0
2011/5/14 9:00	44.2	43.4	52.7	29.5
2011/5/14 10:00	44.9	43.7	54.1	29.5
2011/5/14 11:00	47.7	43.4	44.6	29.0
2011/5/14 12:00	49.9	43.3	41.8	29.5
2011/5/14 13:00	52.4	42.7	39.1	30.0
2011/5/14 14:00	54.6	42.3	37.0	30.0
2011/5/14 15:00	56.7	41.9	35.4	30.5
2011/5/14 16:00	58.9	41.5	33.8	31.0
2011/5/14 17:00	61.1	41.3	32.5	31.5
2011/5/14 18:00	63.0	41.0	31.6	32.0
2011/5/14 19:00	65.3	40.6	30.7	32.0
2011/5/14 20:00	67.4	40.3	29.9	32.5
2011/5/14 21:00	69.0	40.1	29.4	33.0
2011/5/14 22:00	62.4	40.1	29.0	33.0

Fukushima Daiichi Nuclear Power Station Unit5·6 Reactor water/spent fuel pool temperature

Date	Unit5 reactor water temperature	Unit5 spent fuel pool temperature	Unit6 reactor water temperature	Unit6 spent fuel pool temperature
2011/5/14 23:00	58.9	40.4	28.5	34.0
2011/5/15 0:00	56.4	40.6	28.2	34.0
2011/5/15 1:00	54.4	41.0	27.9	34.5
2011/5/15 2:00	52.3	41.3	27.7	35.0
2011/5/15 3:00	50.7	41.7	27.4	35.0
2011/5/15 4:00	49.1	41.9	27.3	35.5
2011/5/15 5:00	47.8	42.4	27.1	36.0
2011/5/15 6:00	46.6	42.7	27.0	36.0
2011/5/15 7:00	45.7	42.9	26.9	36.5
2011/5/15 8:00	44.8	43.3	26.8	37.0
2011/5/15 9:00	44.1	43.7	26.7	37.5
2011/5/15 10:00	45.4	43.8	26.6	38.0
2011/5/15 11:00	47.9	43.6	26.6	38.0
2011/5/15 12:00	50.4	43.4	26.6	38.5
2011/5/15 13:00	53.1	42.8	26.6	38.5
2011/5/15 14:00	55.3	42.4	26.5	39.0
2011/5/15 15:00	57.3	42.0	26.6	39.0
2011/5/15 16:00	59.6	41.8	26.6	39.5
2011/5/15 17:00	61.7	41.5	26.6	40.0
2011/5/15 18:00	63.8	41.0	26.7	40.0
2011/5/15 19:00	65.7	40.8	29.8	40.5
2011/5/15 20:00	67.7	40.5	31.2	40.0
2011/5/15 21:00	69.1	40.3	32.6	38.0
2011/5/15 22:00	61.8	40.2	34.6	37.0
2011/5/15 23:00	59.1	40.4	36.6	37.0
2011/5/16 0:00	56.2	40.8	38.2	36.0