

Fixed point Monitoring Status by Temporary Monitoring Post at Fukushima Daiichi Nuclear Power Station

Date	Radiation Dose Rate (mSv/h) At the Main Buiding	Radiation Dose Rate (μ Sv/h) At the Main Gate	Radiation Dose Rate (μ Sv/h) At the West Gate
2011/4/4 9:00	0.78	121	55
2011/4/4 8:30	0.79	122	56
2011/4/4 8:00	0.79	121	56
2011/4/4 7:30	0.80	121	56
2011/4/4 7:00	0.80	121	56
2011/4/4 6:30	0.81	120	56
2011/4/4 6:00	0.81	122	56
2011/4/4 5:30	0.81	120	56
2011/4/4 5:00	0.81	122	57
2011/4/4 4:30	0.81	121	56
2011/4/4 4:00	0.81	123	57
2011/4/4 3:30	0.81	120	56
2011/4/4 3:00	0.81	121	56
2011/4/4 2:30	0.81	120	57
2011/4/4 2:00	0.81	121	57
2011/4/4 1:30	0.81	120	56
2011/4/4 1:00	0.81	119	57
2011/4/4 0:30	0.81	121	56
2011/4/4 0:00	0.81	121	57

Monitoring data by a monitoring car* at Fukushima Daiichi Nuclear Power Station

* The car supplements fixed point Monitoring Status by Temporary Monitoring Post

Measurement Date : 04/04/2011

Measurement Time	Measured Place	γ Ray	Neutron Ray	Wind Direction	Wind Velocity (m/s)
9:00 AM	West Gate	74.1 μ Sv/h	under 0.01 μ Sv/h	north	1.9
8:50 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	northwest	2.0
8:40 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	north	1.3
8:30 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	north	1.8
8:20 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	north	1.7
8:10 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	west	1.7
8:00 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	northwest	1.2
7:50 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	west	1.2
7:40 AM	West Gate	74.2 μ Sv/h	under 0.01 μ Sv/h	west	0.8
7:30 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	northeast	0.8
7:20 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	west	0.7
7:10 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	northeast	0.5
7:00 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	west	0.5
6:50 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	west	0.4
6:40 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	west	0.4
6:30 AM	West Gate	74.3 μ Sv/h	under 0.01 μ Sv/h	south	0.4
6:20 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	southwest	0.5
6:10 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	northwest	0.6
6:00 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	west	0.7
5:50 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	northwest	0.8
5:40 AM	West Gate	74.4 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.7
5:30 AM	West Gate	74.5 μ Sv/h	under 0.01 μ Sv/h	west	0.6
5:20 AM	West Gate	74.5 μ Sv/h	under 0.01 μ Sv/h	northwest	0.5
5:10 AM	West Gate	74.5 μ Sv/h	under 0.01 μ Sv/h	west	0.4
5:00 AM	West Gate	74.5 μ Sv/h	under 0.01 μ Sv/h	west	0.5
4:50 AM	West Gate	74.6 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.5
4:40 AM	West Gate	74.6 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.8
4:30 AM	West Gate	74.6 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.6
4:20 AM	West Gate	74.5 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.8
4:10 AM	West Gate	74.7 μ Sv/h	under 0.01 μ Sv/h	west	0.7
4:00 AM	West Gate	74.8 μ Sv/h	under 0.01 μ Sv/h	northwest	0.4
3:50 AM	West Gate	74.9 μ Sv/h	under 0.01 μ Sv/h	west	1.0
3:40 AM	West Gate	74.8 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.6
3:30 AM	West Gate	75.0 μ Sv/h	under 0.01 μ Sv/h	west	0.8
3:20 AM	West Gate	75.0 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.6
3:10 AM	West Gate	75.1 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.7
3:00 AM	West Gate	75.1 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.8
2:50 AM	West Gate	75.2 μ Sv/h	under 0.01 μ Sv/h	north-northwest	0.6
2:40 AM	West Gate	75.1 μ Sv/h	under 0.01 μ Sv/h	west-northwest	1.0
2:30 AM	West Gate	75.2 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.7
2:20 AM	West Gate	75.3 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.6
2:10 AM	West Gate	75.2 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.8
2:00 AM	West Gate	75.3 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.7
1:50 AM	West Gate	75.3 μ Sv/h	under 0.01 μ Sv/h	west-southwest	0.9
1:40 AM	West Gate	75.5 μ Sv/h	under 0.01 μ Sv/h	west	0.5
1:30 AM	West Gate	75.4 μ Sv/h	under 0.01 μ Sv/h	south-southwest	0.6
1:20 AM	West Gate	75.4 μ Sv/h	under 0.01 μ Sv/h	northwest	0.5
1:10 AM	West Gate	75.5 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.6
1:00 AM	West Gate	75.6 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.5
0:50 AM	West Gate	75.6 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.7
0:40 AM	West Gate	75.6 μ Sv/h	under 0.01 μ Sv/h	west	0.4
0:30 AM	West Gate	75.6 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.8
0:20 AM	West Gate	75.6 μ Sv/h	under 0.01 μ Sv/h	west-northwest	0.9
0:10 AM	West Gate	75.9 μ Sv/h	under 0.01 μ Sv/h	north-northeast	0.6
0:00 AM	West Gate	75.9 μ Sv/h	under 0.01 μ Sv/h	west	0.4

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station (μ Sv/h)

※Until the recovery of automated transfer of measurement data, data will be reported based on visual observation by regular patrol of monitoring posts.

Date of measurement	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/4/3 13:00-15:00	17	53	57	58	130	190	350	270
2011/4/2 13:00-15:00	18	56	61	62	130	200	370	280
2011/4/1 13:00-15:00	19	59	69	68	150	210	390	300