

Fukushima Daiichi Nuclear Power Station : Results of Nuclide Analysis of sub-drain

Reference

Data summarized on April 14th)

Time and Date of sample collection	11:40, April 13th, 2011	11:50, April 13th, 2011	11:25, April 13th, 2011	11:20, April 13th, 2011	12:00, April 13th, 2011	12:10, April 13th, 2011	10:05, April 13th, 2011
Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	4.0E+02	6.1E+02	3.6E+00	1.7E+01	1.6E-01	1.9E-01	ND
Cs-134 (about 2 years)	5.3E+01	7.9E+00	2.4E+00	2.7E+00	2.7E-01	2.6E-01	ND
Cs-137 (about 30 years)	6.0E+01	9.1E+00	2.4E+00	2.7E+00	2.8E-01	2.8E-01	ND

※ 〇.〇E-〇 means 〇.〇 × 10^{-〇}.

※ Data of other nuclides are under evaluation.