

Reference
-----------

<Fukushima Daiichi Nuclear Power Station>  
Result of Nuclide Analysis of the seawater at the shallow draft quay, Unit 2 screen, and the water intake canal of Unit 1-4

(Data summarized on April 26th)

Place of Collection	Shallow Draft Quay of 1F		Bar screen of 1F's Unit 2 (inside the silt fence)		Bar screen of 1F's Unit 2 (outside the silt fence)		South side of the water intake canal of 1F's Unit 1-4		North side of the water intake canal of 1F's Unit 1-4		Density limit by the announcement of Reactor Regulation (Bq/cm <sup>3</sup> ) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	6:15, April 25th, 2011		6:48, April 25th, 2011		6:43, April 25th, 2011		6:58, April 25th, 2011		6:34, April 25th, 2011		
Detected nuclide (half-life)	Density of sample (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Density of sample (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Density of sample (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Density of sample (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Density of sample (Bq/cm <sup>3</sup> )	Scaling factor ( / )	
I-131 (about 8 days)	7.6E-01	19	5.6E+01	1,400	1.1E+01	280	6.7E+00	170	4.0E+00	100	4E-02
Cs-134 (about 2 years)	7.8E-01	13	2.6E+01	430	3.7E+00	62	1.1E+01	180	2.8E+00	47	6E-02
Cs-137 (about 30 years)	8.1E-01	9.0	2.7E+01	300	3.9E+00	43	1.1E+01	120	2.8E+00	31	9E-02

. E+ means . × 1 0<sup>+</sup> .

Data of other nuclides are under evaluation.