

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 10)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/5/9 14:23	2011/5/9 14:28	2011/5/9 14:35	2011/5/9 11:50	2011/5/9 14:14	2011/5/9 14:06	2011/5/9 9:15
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	4.2E+00	9.6E+01	1.9E-01	ND	ND	2.8E-02	ND
Cs-134 (about 2 years)	1.0E+01	1.3E+01	2.6E-01	5.3E-02	ND	5.8E-02	ND
Cs-137 (about 30 years)	1.2E+01	1.5E+01	2.5E-01	4.6E-02	7.4E-03	4.9E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.