

Result of Nuclide Analysis at Kashiwazaki Kariwa Nuclear Power Station

sampling date : May 23rd, 2011

measurement date : May 26th, 2011

Sampling spot		Nuclide	Density (Bq/kg fresh weight※)	Detectable Lower Limit (Bq/kg fresh weight※)	Ingestion Limit (Bq/kg fresh weight※)
Sargasso	Near the discharge canal (South)	Iodine-131	0.23	0.21	2,000
	Near the discharge canal (North)	Iodine-131	0.18	0.16	2,000

※ "Bq/kg fresh weight" is an amount of radioactivity contained in the 1kg of fresh seaweed.